

# CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9709150075 DOC. DATE: 97/09/03 NOTARIZED: NO DOCKET #  
 FACIL: STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Public 05000529  
 AUTH. NAME AUTHOR AFFILIATION  
 LEVINE, J.M. Arizona Public Service Co. (formerly Arizona Nuclear Power  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Submits addl info in support of request for amend to TS  
 4.3.2.1 for Main Steam Isolation Sys logic surveillance  
 testing, submitted 970828.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES: Standardized plant.

05000529

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD4-2 LA		1			PD4-2 PD		1	
	THOMAS, K		1						
INTERNAL:	ACRS		1			FILE CENTER 01		1	
	NRR/DE/ECGB/A		1			NRR/DE/EMCB		1	
	NRR/DRCH/HICB		1			NRR/DSSA/SPLB		1	
	NRR/DSSA/SRXB		1			NUDOCS-ABSTRACT		1	
	OGC/HDS2		1						
EXTERNAL:	NOAC		1			NRC PDR		1	

## NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 14 ENCL 13

C  
A  
T  
E  
G  
O  
R  
Y  
1  
D  
O  
C  
U  
M  
E  
N  
T

AA



10 CFR 50.90  
10 CFR 50.91

Palo Verde Nuclear  
Generating Station

James M. Levine  
Senior Vice President  
Nuclear

TEL (602)393-5300  
FAX (602)393-6077

Mail Station 7602  
P.O. Box 52034  
Phoenix, AZ 85072-2034

102-04007-JML/SAB/RMW  
September 3, 1997

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, DC 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Unit 2  
Docket No. STN 50-529  
Request for Amendment to Technical Specification (TS) Table 4.3-2,  
"Engineered Safety Features Actuation System Instrumentation  
Surveillance Requirements," Additional Information**

Arizona Public Service Company (APS) requested an amendment to Technical Specification 4.3.2.1 for Main Steam Isolation System (MSIS) logic surveillance testing for PVNGS Unit 2 on August 28, 1997. In support of this request, APS has performed a historical review spanning the last three years of Licensee Event Reports, Condition Report/Disposition Request and Equipment Failure Data Trending for all three units pertaining to the equipment for which this amendment is requested. This review has determined that there have been no failures of the matrix logic, initiation logic, automatic actuation logic or manual actuation that would have prevented the Engineered Safety Features Actuation System (ESFAS) MSIS from performing its design function. As such, delaying the surveillance by five days is not expected to miss identification of a condition that would result in the inability of the equipment to perform its intended function.

Should you have any questions, please contact Scott A. Bauer at (602) 393-5978.

Sincerely,

1/0  
A001

JML/SAB/RMW/rjh

cc: E. W. Merschoff  
K. E. Perkins  
K. M. Thomas  
PVNGS Sr. Resident  
A. V. Godwin (ARRA)

9709150075 970903  
PDR ADOCK 05000529  
PDR



