

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9801220031 DOC.DATE: 98/01/14 NOTARIZED: NO DOCKET #

FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528

STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529

STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH.NAME AUTHOR AFFILIATION

OVERBECK, G.R. Arizona Public Service Co. (formerly Arizona Nuclear Power

RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards MOR for Dec 1997 for PVNGS, Units 1, 2 & 3 & revised
MOR for Nov 1997 for PVNGS, Unit 3.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 4

TITLE: Monthly Operating Report (per Tech Specs)

NOTES: STANDARDIZED PLANT 05000528
Standardized plant. 05000529
Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD4-2 PD	1 1	CLIFFORD, J	1 1	Y
INTERNAL:	ACRS	1 1	AEOD/SPD/RRAB	1 1	
	FILE CENTER-01	1 1	OC/DBA/PAD	1 1	1
	RGN4	1 1			
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1	
	NRC PDR	1 1			

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

mR



Palo Verde Nuclear
Generating Station

Gregg R. Overbeck
Vice President
Nuclear Production

TEL 602/393-5148
FAX 602/393-6077

Mail Station 7602
P.O. Box 52034
Phoenix, AZ 85072-2034

035-00494-GRO/JDF
January 14, 1998

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Monthly Operating Reports for DECEMBER 1997

Enclosed are the Monthly Operating Reports for December 1997, prepared and submitted pursuant to Specification 6.9.1.6 of Appendix A (Technical Specifications) to the PVNGS Units 1, 2, and 3 Operating Licenses.

Also enclosed is one revised page to the November 1997 report. The revision is to page 3. This correction is to Unit Shutdowns, although the reactor was not tripped, the main turbine was off line for 8.2 hours to balance a coupling in bearing #6.

By copy of this letter, Arizona Public Service Company is also forwarding the Monthly Operating Reports to the Regional Administrator, NRC Region IV.

If you have any questions, please contact Judy Fulton at (602) 250-3549.

Sincerely,

GRO/JDF/clj

Enclosures: DECEMBER 1997 Monthly Operating Reports

cc: E. W. Merschoff (all w/enclosures)
K. E. Perkins
INPO Records Center
Utility Data Institute

9801220031 980114
PDR ADDCK 05000528
R PDR



IE241