

NRC MONTHLY OPERATING DATA REPORT - CORRECTION -

DOCKET NO.: 50-530
 UNIT NAME: PVNGS-3
 DATE: 12/8/97
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: November 1997

1. Design Electrical Rating (Net MWe): 1269
2. Maximum Dependable Capacity (Net MWe): 1247

	Unit 3 Generating Statistics	This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	720.0	7,124.9	68,581.7
4.	Hours Generator was On-Line	711.8	7,078.1	67,755.6
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	875,497	8,520,037	81,819,182

UNIT SHUTDOWNS

No.	Date	Type ¹	Outage Duration Hours	Reason ²	Method of Shutting Down Reactor ³	Cause and Corrective Action to Prevent Occurrence
97-02	11/8/97	F	8.2	B	5	Power was reduced to 23% and Main Turbine taken off line to balance coupling in bearing #6 due to a high vibration.

¹F-Forced
S-Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Trip / Scram
 3-Automatic Trip / Scram
 4-Continuation
 5-Other-(Explain)

SUMMARY: Reactor was not shutdown and continued to operate at power. The turbine was taken out of service to allow balancing of the coupling at the #6 bearing. This maintenance resulted in lowering turbine vibration at the #6 bearing.

9801220051 980114
 PDR ADOCK 05000528
 R PDR

