



Palo Verde Nuclear  
Generating Station

Gregg R. Overbeck  
Vice President  
Nuclear Production

TEL 602/393-5148  
FAX 602/393-6077

Mail Station 7602  
P.O. Box 52034  
Phoenix, AZ 85072-2034

192-01010 -GRO/DGM/KR  
February 5, 1998

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, D.C. 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)**  
**Units 1, 2, and 3**  
**Docket Nos. STN 50-528/529/530**  
**License Nos. NPF-41/51/74**  
**Licensee Event Report 97-006-00**

Attached please find Licensee Event Report (LER) 97-006-00 prepared and submitted pursuant to 10CFR50.73. This LER reports a violation of Technical Specification due to missing the performance of a surveillance requirement for an ASME Section XI inservice inspection pressure test. In accordance with 10CFR50.73(d), a copy of this LER is being forwarded to the Regional Administrator, NRC Region IV. If you have any questions, please contact Daniel G. Marks, Section Leader, Nuclear Regulatory Affairs, at (602) 393-6492.

Sincerely,

GRO/DGM/KR/mah

Attachment

cc: E. W. Merschoff (all with attachment)  
K. E. Perkins  
J. H. Moorman  
INPO Records Center

111  
1222

9802130057 980205  
PDR ADDCK 05000528  
S PDR



