

CATEGORY

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9803250374 DOC. DATE: 98/03/12 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 AUTH. NAME AUTHOR AFFILIATION
 OVERBECK, G.R. Arizona Public Service Co. (formerly Arizona Nuclear Power
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 98-002-00, which repts an automatic reactor trip
 on low SG level due to insufficient main feedwater flow. LER
 do not contain commitments.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+5
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: STANDARDIZED PLANT

05000528

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD4-2 PD	1 1	CLIFFORD, J	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	2 2
	AEOD/SPD/RRAB	1 1	FTTE-GENTER	1 1
	NRR/DE/ECGB	1 1	NRR/DE/EELB	1 1
	NRR/DE/EMEB	1 1	NRR/DRCH/HHFB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRCH/HOLB	1 1
	NRR/DRCH/HQMB	1 1	NRR/DRPM/PECB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	RES/DET/EIB	1 1	RGN4 FILE 01	1 1
EXTERNAL:	L ST LOBBY WARD	1 1	LITCO BRYCE, J H	1 1
	NOAC POORE, W.	1 1	NOAC QUEENER, DS	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 25

A04



Palo Verde Nuclear
Generating Station

Gregg R. Overbeck
Vice President
Nuclear Production

TEL 602/393-5148
FAX 602/393-6077

Mail Station 7602
P.O. Box 52034
Phoenix, AZ 85072-2034

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, D.C. 20555-0001

192-01014 -GRO/DGM/KR
March 12, 1998

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 1
Docket No. STN 50-528
License No. NPF-41
Licensee Event Report 98-002-00

Attached please find Licensee Event Report (LER) 98-002-00 prepared and submitted pursuant to 10 CFR 50.73. This LER reports an automatic reactor trip on low steam generator (SG) level due to insufficient main feedwater flow. In addition to the reactor trip, the unit received an engineered safety feature actuation system actuation of the auxiliary feedwater system 2 (AFAS-2) on low SG-2 water level. Both emergency diesel generators started and ran unloaded as designed. This LER does not contain any commitments.

In accordance with 10CFR50.73(d), a copy of this LER is being forwarded to the Regional Administrator, NRC Region IV. If you have any questions, please contact Daniel G. Marks, Section Leader, Nuclear Regulatory Affairs, at (602) 393-6492.

Sincerely,

GRO/DGM/KR/mah

Attachment

cc: E. W. Merschoff (all with attachment)
K. E. Perkins
J. H. Moorman
INPO Records Center

9803250374 980312
PDR ADOCK 05000528
S PDR

Tezz

11

