

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9807160116      DOC. DATE: ~~98/06/30~~ NOTARIZED: NO      DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528  
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529  
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530  
 AUTH. NAME      AUTHOR AFFILIATION  
 FULTON, J.D.      Arizona Public Service Co. (formerly Arizona Nuclear Power  
 OVERBECK, G.R.      Arizona Public Service Co. (formerly Arizona Nuclear Power  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for June 1998 for Palo Verde Nuclear  
 Generating Station, Units 1, 2 & 3. W/980710 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: STANDARDIZED PLANT      05000528  
 Standardized plant.      05000529  
 Standardized plant.      05000530

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
PD4-2 PD	1 1	FIELDS, M	1 1	
INTERNAL: <u>ACRS</u>	1 1	AEOD/SPD/RRAB	1 1	1
<u>FILE CENTER-01</u>	1 1	OC/DBA/PAD	1 1	
RGN4	1 1			
EXTERNAL: LITCO BRYCE, J H	1 1	NOAC	1 1	D
NRC PDR	1 1			

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR





Palo Verde Nuclear  
Generating Station

Gregg R. Overbeck  
Vice President  
Nuclear Production

TEL 602/393-5148  
FAX 602/393-6077

Mail Station 7602  
P.O. Box 52034  
Phoenix, AZ 85072-2034

035-00509-GRO/JDF  
July 10, 1998

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, DC 20555

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Units 1, 2, and 3  
Docket Nos. STN 50-528/529/530  
Monthly Operating Reports for JUNE 1998**

Enclosed are the Monthly Operating Reports for June 1998, prepared and submitted pursuant to Specification 6.9.1.6 of Appendix A (Technical Specifications) to the PVNGS Units 1, 2, and 3 Operating Licenses.

By copy of this letter, Arizona Public Service Company is also forwarding the Monthly Operating Reports to the Regional Administrator, NRC Region IV.

If you have any questions, please contact Judy Fulton at (602) 250-3549.

Sincerely,

1/1  
IE24

GRO/JDF/cj

Enclosures: JUNE 1998 Monthly Operating Reports

cc: E. W. Merschoff (all w/enclosures)  
K. E. Perkins  
INPO Records Center  
Utility Data Institute

9807160116 980630  
PDR ADDCK 05000528  
R PDR

# NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-528  
 UNIT NAME: PVNGS-1  
 DATE: 7/10/98  
 COMPLETED BY: J. D. Fulton  
 TELEPHONE: (602) 250-3549

Reporting Period: June 1998

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

	Unit 1 Generating Statistics	This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	720.0	3,456.9	77,453.2
4.	Hours Generator was On-Line	720.0	3,403.5	76,214.6
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	895,656	4,129,989	90,333,257

## UNIT SHUTDOWNS

No.	Date	Type <sup>1</sup>	Outage Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause and Corrective Action to Prevent Occurrence
-----	------	-------------------	-----------------------	---------------------	--	---

No reactor shutdowns occurred during the month of June 1998.

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training / License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>Method:  
 1-Manual  
 2-Manual Trip / Scram  
 3-Automatic Trip / Scram  
 4-Continuation  
 5-Other-(Explain)

SUMMARY: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



# NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-529  
 UNIT NAME: PVNGS-2  
 DATE: 7/10/98  
 COMPLETED BY: J. D. Fulton  
 TELEPHONE: (602) 250-3549

Reporting Period: June 1998

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

Unit 2 Generating Statistics		This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	720.0	4,344.0	77,769.7
4.	Hours Generator was On-Line	720.0	4,344.0	76,576.8
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	909,478	5,514,151	91,943,710

## UNIT SHUTDOWNS

No.	Date	Type <sup>1</sup>	Outage Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause and Corrective Action to Prevent Occurrence
No reactor shutdowns occurred during the month of June 1998.						

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training / License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

<sup>3</sup>Method:

- 1-Manual
- 2-Manual Trip / Scram
- 3-Automatic Trip / Scram
- 4-Continuation
- 5-Other-(Explain)

SUMMARY: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



# NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-530  
 UNIT NAME: PVNGS-3  
 DATE: 7/10/98  
 COMPLETED BY: J. D. Fulton  
 TELEPHONE: (602) 250-3549

Reporting Period: June 1998

1. Design Electrical Rating (Net MWe): 1269
2. Maximum Dependable Capacity (Net MWe): 1247

Unit 3 Generating Statistics		This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	720.0	4,344.0	73,669.7
4.	Hours Generator was On-Line	720.0	4,344.0	72,843.6
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	894,814	5,420,222	88,173,193

## UNIT SHUTDOWNS

No.	Date	Type <sup>1</sup>	Outage Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause and Corrective Action to Prevent Occurrence
No reactor shutdowns occurred during the month of June 1998.						

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training / License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

<sup>3</sup>Method:

- 1-Manual
- 2-Manual Trip / Scram
- 3-Automatic Trip / Scram
- 4-Continuation
- 5-Other-(Explain)

SUMMARY: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_





10-10-10

10-10-10

10-10-10