

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 2

Revision 2



## PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

## Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Cover Page	2	1
Table of Contents	2	2
Affected Technical Specifications	1	4
CORE Operating Limits		
3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open	1	4
3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed	1	4
3.1.4 Moderator Temperature Coefficient (MTC)	1	5
3.1.5 Control Element Assembly (CEA) Alignment	1	5
3.1.7 Regulating CEA Insertion Limits	1	5
3.1.8 Part Length CEA Insertion Limits	1	5
3.2.1 Linear Heat Rate (LHR)	1	6
3.2.3 Azimuthal Power Tilt (Tq)	1	6
3.2.4 Departure From Nucleate Boiling Ratio (DNBR)	1	6
3.2.5 Axial Shape Index (ASI)	2	7
3.3.12 Boron Dilution Alarm System (BDAS)	1	7
3.9.1 Boron Concentration	1	7
List of Figures	1	8
Figure 3.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	1	9
Figure 3.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	1	10
Figure 3.1.4-1 MTC Acceptable Operation, Modes 1 and 2	1	11
Figure 3.1.5-1 Core Power Limit After CEA Deviation	1	12
Figure 3.1.7-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	1	13
Figure 3.1.7-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	1	14
Figure 3.1.8-1 Part Length CEA Insertion Limits Versus Thermal Power	1	15



# PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

## Table of Contents (Continued)

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	1	16
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable	1	17
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Operable)	1	18
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)	1	19
List of Tables	1	20
Table 3.3.12-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	1	21
Table 3.3.12-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	1	22
Table 3.3.12-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	1	23
Table 3.3.12-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	1	24
Table 3.3.12-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	1	25



## PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS - CONTINUED3.2.5 - Axial Shape Index (ASI)

The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

## COLSS OPERABLE

$-0.18 \leq \text{ASI} \leq +0.16$  for power  $\geq 50\%$

$-0.28 \leq \text{ASI} \leq +0.16$  for power  $< 50\%$

## COLSS OUT OF SERVICE (CPC)

$-0.10 \leq \text{ASI} \leq 0.10$

3.3.12 - Boron Dilution Alarm System (BDAS)

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.3.12-1 through 3.3.12-5.

3.9.1 - Boron Concentration

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration  $\geq 3000$  ppm.

