







Palo Verde Nuclear  
Generating Station

Gregg R. Overbeck  
Vice President  
Nuclear Production

TEL 602/393-5148  
FAX 602/393-6077

Mail Station 7602  
P.O. Box 52034  
Phoenix, AZ 85072-2034

192-01044-GRO/DGM/REB  
April 14, 1999

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, D.C. 20555-0001

Dear Sirs:

**Subject:** Palo Verde Nuclear Generating Station (PVNGS)  
Units 1, 2, and 3  
Docket No. STN 50-528, 50-529, 50-530  
License No. NPF-41, NPF-51, NPF-74  
Licensee Event Report 99-003-00

Attached please find Licensee Event Report (LER) 99-003-00 prepared and submitted pursuant to 10 CFR 50.73. This LER reports a condition prohibited by the Technical Specifications that existed when the surveillance requirement to verify essential chilled water system valve positions was not met. This LER does not contain any commitments.

In accordance with 10CFR50.73(d), a copy of this LER is being forwarded to the Regional Administrator, NRC Region IV. If you have any questions, please contact Daniel G. Marks, Section Leader, Nuclear Regulatory Affairs, at (623) 393-6492.

Sincerely,

GRO/DGM/REB/rjh

Attachment

cc: E. W. Merschoff (all with attachment)  
M. B. Fields  
P. H. Harrell  
J. H. Moorman  
INPO Records Center

9904220198 990414  
PDR ADDCK 05000528  
S PDR

*Terz*

