

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9905170020 DOC. DATE: ~~99/04/30~~ NOTARIZED: NO DOCKET #

FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528

STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529

STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH. NAME AUTHOR AFFILIATION

FULTON, J.D. Arizona Public Service Co. (formerly Arizona Nuclear Power

OVERBECK, G.R. Arizona Public Service Co. (formerly Arizona Nuclear Power

RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Apr 1999 for PVNGS, Units 1, 2 &
3. With 990512 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4

TITLE: Monthly Operating Report (per Tech Specs)

NOTES: STANDARDIZED PLANT 05000528

Standardized plant. 05000529

Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	DLPM/LPD4-2	1 1	FIELDS, M	1 1
INTERNAL: ACRS		1 1	AEOD/SPD/RRAB	1 1
	<u>FILE CENTER 01</u>	1 1	OC/DBA/PAD	1 1
	RGN4	1 1		
EXTERNAL: LMITCO MARSHALL		1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

ml



[Faint, illegible text covering the majority of the page]



Palo Verde Nuclear
Generating Station

Gregg R. Overbeck
Vice President
Nuclear Production

TEL 602/393-5148
FAX 602/393-6077

Mail Station 7602
P.O. Box 52034
Phoenix, AZ 85072-2034

035-00538-GRO/JDF
May 12, 1999

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Monthly Operating Reports for APRIL 1999**

Enclosed are the Monthly Operating Reports for April 1999, prepared and submitted pursuant to Specification 6.9.1.6 of Appendix A (Technical Specifications) to the PVNGS Units 1, 2, and 3 Operating Licenses.

By copy of this letter, Arizona Public Service Company is also forwarding the Monthly Operating Reports to the Regional Administrator, NRC Region IV.

If you have any questions, please contact Judy Fulton at (602) 250-3549.

Sincerely,

GRO/JDF/cj

170014

Enclosures: APRIL 1999 Monthly Operating Reports

cc: E. W. Merschoff (all w/enclosures)
P. H. Harrell
INPO Records Center
Utility Data Institute

IE24'1

9905170020 990430
PDR ADOCK 05000528
R PDR



1. 2. 3. 4. 5. 6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 26. 27. 28. 29. 30. 31. 32. 33. 34. 35. 36. 37. 38. 39. 40. 41. 42. 43. 44. 45. 46. 47. 48. 49. 50. 51. 52. 53. 54. 55. 56. 57. 58. 59. 60. 61. 62. 63. 64. 65. 66. 67. 68. 69. 70. 71. 72. 73. 74. 75. 76. 77. 78. 79. 80. 81. 82. 83. 84. 85. 86. 87. 88. 89. 90. 91. 92. 93. 94. 95. 96. 97. 98. 99. 100.

1. 2. 3. 4. 5. 6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 26. 27. 28. 29. 30. 31. 32. 33. 34. 35. 36. 37. 38. 39. 40. 41. 42. 43. 44. 45. 46. 47. 48. 49. 50. 51. 52. 53. 54. 55. 56. 57. 58. 59. 60. 61. 62. 63. 64. 65. 66. 67. 68. 69. 70. 71. 72. 73. 74. 75. 76. 77. 78. 79. 80. 81. 82. 83. 84. 85. 86. 87. 88. 89. 90. 91. 92. 93. 94. 95. 96. 97. 98. 99. 100.

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-528
 UNIT NAME: PVNGS-1
 DATE: 5/10/99
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: April 1999

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

| | Unit 1 Generating Statistics | This Month | Yr. to Date | Cumulative |
|----|---------------------------------------|------------|-------------|------------|
| 3. | Hours Reactor was Critical | 720.0 | 2,827.8 | 84,697.0 |
| 4. | Hours Generator was On-Line | 720.0 | 2,820.1 | 83,450.7 |
| 5. | Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 6. | Net Electrical Energy Generated (MWh) | 907,840 | 3,510,069 | 99,288,350 |

UNIT SHUTDOWNS

| No. | Date | Type ¹ | Outage
Duration
Hours | Reason ² | Method of
Shutting Down
Reactor ³ | Cause and Corrective Action
to Prevent Occurrence |
|-----|------|-------------------|-----------------------------|---------------------|--|--|
|-----|------|-------------------|-----------------------------|---------------------|--|--|

No reactor shutdowns occurred during the month of April 1999.

¹F-Forced
S-Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Trip / Scram
 3-Automatic Trip / Scram
 4-Continuation
 5-Other-(Explain)

SUMMARY: _____

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-529
 UNIT NAME: PVNGS-2
 DATE: 5/10/99
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: April 1999

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

| Unit 2 Generating Statistics | | This Month | Yr. to Date | Cumulative |
|------------------------------|---------------------------------------|------------|-------------|-------------|
| 3. | Hours Reactor was Critical | 0.0 | 2,040.0 | 84,225.7 |
| 4. | Hours Generator was On-Line | 0.0 | 2,040.0 | 83,032.8 |
| 5. | Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 6. | Net Electrical Energy Generated (MWh) | 0 | 2,575,586 | 100,089,971 |

UNIT SHUTDOWNS

| No. | Date | Type ¹ | Outage Duration Hours | Reason ² | Method of Shutting Down Reactor ³ | Cause and Corrective Action to Prevent Occurrence |
|-------|------|-------------------|-----------------------|---------------------|--|---|
| 99-01 | 3/27 | S | 840.0 | C | 1 | Unit in eighth refueling outage. |

¹F-Forced
S-Scheduled

²Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training / License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

³Method:

- 1-Manual
- 2-Manual Trip / Scram
- 3-Automatic Trip / Scram
- 4-Continuation
- 5-Other-(Explain)

SUMMARY: _____

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-530
 UNIT NAME: PVNGS-3
 DATE: 5/10/99
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: April 1999

1. Design Electrical Rating (Net MWe): 1269
2. Maximum Dependable Capacity (Net MWe): 1247

| | Unit 3 Generating Statistics | This Month | Yr. to Date | Cumulative |
|----|---------------------------------------|------------|-------------|------------|
| 3. | Hours Reactor was Critical | 720.0 | 2,880.0 | 80,075.6 |
| 4. | Hours Generator was On-Line | 720.0 | 2,880.0 | 79,215.7 |
| 5. | Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 6. | Net Electrical Energy Generated (MWh) | 897,885 | 3,607,816 | 95,961,693 |

UNIT SHUTDOWNS

| No. | Date | Type ¹ | Outage
Duration
Hours | Reason ² | Method of
Shutting Down
Reactor ³ | Cause and Corrective Action
to Prevent Occurrence |
|-----|------|-------------------|-----------------------------|---------------------|--|--|
|-----|------|-------------------|-----------------------------|---------------------|--|--|

No reactor shutdowns occurred during the month of April 1999.

¹F-Forced
S-Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Trip / Scram
 3-Automatic Trip / Scram
 4-Continuation
 5-Other-(Explain)

SUMMARY: _____
