

A002

REGULATOR INFORMATION DISTRIBUTION STEM

DOCKET NBR: 50-315 COOK 1
RECIPIENT: KEPPLER, J.G.
ORIGINATOR: SHALLER, D.V.
COMPANY NAME: IN & MI PWR
SUBJECT:

DOC DATE: 781101
ACCESSION NBR: 7811090225
COPIES RECEIVED:
LTR 1 ENCL 1
SIZE: 1+4

LER#78-057/03L-0 on 781002: pump declared inoperable re pump data repeatability. Caused by pump's inability to achieve rated speed; inability traced to pump speed governor, which was replaced. Forwards #78-058/03L-0 & #78-059/03L-0.

DISTRIBUTION CODE: A002
DISTRIBUTION TITLE:
INCIDENT REPORTS

NOTARIZED _____

NAME	ENCL?
BR CHIEF	W/4 ENCL
REG FILE	W/ENCL
NRC PDR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
E. Jordan	W/ENCL
LPDR	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

FOR ACTION

ORB#1 BC

NOV 14 1978

TOTAL NUMBER OF COPIES REQUIRED:
LTR
ENCL

42
42

NOTES:

Ad 4
GD



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

IMPR

November 1, 1978

Mr. J.G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission-
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58
Docket No. 50-315

Dear Mr. Keppler:

Pursuant to the requirements of the Appendix A Technical Specifications
the following reports are submitted:

RO 78-057/03L-0
RO 78-058/03L-0
RO 78-059/03L-0

Sincerely,

for D.V. Shaller
Plant Manager

/bab

cc: J.E. Dolan
R.W. Jurgensen
R.F. Kroeger
R. Kilburn
R.J. Vollen BPI
K.R. Baker RO:III
R.C. Callen MPSC
P.W. Steketee, Esq.
R. Walsh, Esq.
G. Charnoff, Esq.
G. Olson
J.M. Hennigan
PNSRC
J.F. Stietzel
Dir., IE (30 copies)
Dir., MIPC (3 copies)

REGULATORY DOCKET FILE COPY

7811090 225

A002
5/11