

A002

REGULATOR INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-316 COOK 2
RECIPIENT: KEPPLER, J.G.
ORIGINATOR: SHALLER, D.V.
COMPANY NAME: IN & MI PWR
SUBJECT:

DOC DATE: 781128
ACCESSION NBR: 7812010210
COPIES RECEIVED:
LTR 1 ENCL 0
SIZE: 1

Confirms 781128 verbal rept. While investigating cause of water coming from upper containment spray header, 2 lower containment spray check valves were found installed backwards. Rept will be submitted 781212.

DISTRIBUTION CODE: A002
DISTRIBUTION TITLE:
INCIDENT REPORTS

NOTARIZED

NAME

ENCL?

FOR ACTION

BR CHIEF

W/4 ENCL

ORB#1 BC

REG FILE

W/ENCL

NRC PDR

W/ENCL

I & E

W/2 ENCL

MIPC

W/3 ENCL

I & C SYSTEMS BR

W/ENCL

NOVAK/CHECK

W/ENCL

EEB

W/ENCL

AD FOR ENG

W/ENCL

PLANT SYSTEMS BR

W/ENCL

HANAUER

W/ENCL

AD FOR PLANT SYSTEMS

W/ENCL

AD FOR SYS & PROJ

W/ENCL

REACTOR SAFETY BR

W/ENCL

ENGINEERING BR

W/ENCL

KREGER/J. COLLINS

W/ENCL

POWER SYS BR

W/ENCL

E. Jordan

W/ENCL

LPDR

W/ENCL

NSIC

W/ENCL

ACRS

W/16 ENCL

TOTAL NUMBER OF COPIES REQUIRED:

LTR
ENCL

42
42

DEC 4 1978

NOTES: SEND 3 CYS OF ALL MATERIAL TO I & E.

MA-4
BD



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

November 28, 1978

Mr. J. G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-74
Docket No. 50-316

Dear Mr. Keppler:

This is to confirm our verbal report to NRC Region III Inspector, Mr. K. R. Baker, at 1005 hours on November 28, 1978.

At that time we reported that while investigating the cause of water coming from the upper containment spray header we identified two lower containment spray check valves which had been installed backwards.

A followup report will be submitted by December 12, 1978, as required by Technical Specifications Section 6.9.1.8.

Sincerely,

D. V. Shaller
Plant Manager

REGULATORY DOCKET FILE COPY

DVS/jas

cc: J. E. Dolan
R. W. Jurgensen
R. F. Kroeger
R. Kilburn
R. J. Vollen BPI
K. R. Baker RO:III
R. C. Callen MPSC
P. W. Steketee, Esq.
R. Walsh, Esq.
G. Charnoff, Esq.

G. Olson
J. M. Hennigan
PNSRC
J. F. Stietzel
Dir., IE (40 copies)
Dir., MIPC (4 copies)

7812010210

A002
3/10