

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	1	1	0	9	7	8	8	1	2	0	7	7	8	9
60	61								68	69						74	75							80
DOCKET NUMBER										EVENT DATE										REPORT DATE				

UNIT WAS IN MODE 1 AT 90% POWER AND INCREASING TO 100% IN PREPARATION FOR A GENERAL TRIP TEST AND A SCHEDULED OUTAGE WHEN AN EMERGENCY LOAD REDUCTION WAS INITIATED RESULTING IN AXIAL FLUX DIFFERENCE OUTSIDE THE TARGET BAND FOR 3 MINUTES. REACTOR COOLANT AVERAGE TEMPERATURE ABOVE 576.2 DEGREES FOR 8 MINUTES. AND PRESSURIZER PRESSURE BELOW 2220 PSIA FOR 21 MINUTES IN VIOLATION OF TECHNICAL SPECIFICATIONS 3.2.1, 3.2.5a AND 3.2.5b RESPECTIVELY. SIMILAR OCCURRENCES INCLUDE RO-050/315-78-013 AND 051.

[illegible]

1 0 | THE EVENT WAS PRECIPITATED BY A LOSS OF ALL GENERATOR BUS DUCT COOLING. THE
1 1 | PRESSURE, TEMPERATURE, AND FLUX TRANSIENTS OBSERVED ARE EXPECTED CONDITIONS DURING
1 2 | SUCH A LOAD REDUCTION. EACH CONDITION WAS DEALT WITH AS IT OCCURRED AND RETURNED
1 3 | TO THE NORMAL RANGE WITHIN THE TIME LIMIT IN THE ACTION STATEMENTS.

7 8 9 80

FACILITY STATUS (28) 1 5 X
 % POWER (29) 0 9 0
 OTHER STATUS (30) Emergency Load Reduction
 METHOD OF DISCOVERY (31) A
 DISCOVERY DESCRIPTION (32) OPERATOR OBSERVATION

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 Z (33) Z (34) NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	(37) Z	(38) NA	(39)		

7		8	9	11 PERSONNEL INJURIES			12	13	
NUMBER			DESCRIPTION			(41)			
1	8	0	0	0	(40)		NA		

7		8	9	11		12
		LOSS OF OR DAMAGE TO FACILITY				(43)
		TYPE		DESCRIPTION		
1	9	Z	(42)	NA		

7 8 9 10
PUBLICITY
ISSUED (N) (44) DESCRIPTION (45) 7812120186
2 0
7 8 9 10 68 69 80
NRC USE ONLY

NAME OF PREPARER JOHN M. RANDOLPH

PHONE: (616) 465-5901 X-325