

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7812290083 DOC. DATE: 78/12/27 NOTARIZED: NO
 FACIL: 50-316 DONALD C COOK #2, INDIANA & MICHIGAN ELECTRIC CO..
 AUTH. NAME: SHALLER, D.V. AUTHOR AFFILIATION: IN & MI PWR
 RECIP. NAME: KEPPLER, J.G. RECIPIENT AFFILIATION: **REG. 3, CHICAGO, OFF. OF THE DIRECTOR

DOCKET #
05000316

SUBJECT: Confirms 781224 verbal rept re brief inoperability of control room pressurization fans, due to Fire Protec logic preventing fans from starting. Followup rept will be submitted 780106.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: INCIDENT REPORTS

NOTES: SEND 3 CYS ALL MATL TO I & E.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL		ID CODE/NAME	LTTR
	05 BC <u>ORB #1</u>	4	4			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 HANAUER	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 COLLINS	0	0	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 HOUSTON	0	0
	26 VOLLMER	1	1	E JORDAN/IE	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	27 ACRS	16	16			


DEC 29 1978

MA 4

GD

TOTAL NUMBER OF COPIES REQUIRED: LTTR 43 ENCL 0

DEC 29 1978





INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

December 26, 1978

Mr. J. G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-74
Docket No. 50-316

Dear Mr. Keppler:

This is to confirm our verbal report to NRC Region III Inspector, Mr. K. R. Baker, at 1653 hours on December 24, 1978.

At that time we reported that Unit 2 Control Room Pressurization Fans were inoperable, for a short period of time, due to Fire Protection logic preventing the fans from starting. (Tech. Spec. 3.7.5.1)

A followup report will be submitted by January 6, 1978 as required by Technical Specification Section 6.9.1.8.

Sincerely,

D. V. Shaller
Plant Manager

DVS/jas

cc: J. E. Dolan
R. W. Jurgensen
R. F. Kroeger
R. Kilburn
R. J. Vollen BPI
K. R. Baker RO:III
R. C. Callen MPSC
P. W. Steketee, Esq.
R. Walsh, Esq.
G. Charnoff, Esq.

G. Olson
J. M. Hennigan
PNSRC
J. F. Stietzel
Dir., IE (40 copies)
Dir., MIPC (4 copies)

REGULATORY DOCKET FILE COPY

7812290083

A002
1/0

P

