

LICENSEE EVENT REPORT

CONTRACT BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 1 2 1 4 7 8 8 0 1 0 9 7 9 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 WHILE PERFORMING A ROUTINE SURVEILLANCE TEST IT WAS DISCOVERED THAT THE INDICATED
0 3 POSITION OF ROD H-8 WAS GREATER THAN THE ALLOWABLE TWELVE STEP LIMIT IMPOSED BY
0 4 T.S. 3.1.3.2. PREVIOUS OCCURRENCES INCLUDE 050-0315/76-13,44,54; 0315/77-27,28,33,
0 5 34; 0315/78-04,07,38,46; 050-0316/78-07, 08,22, 31, 41, 64 and 75.
0 6
0 7
0 8

0 9 SYSTEM CODE I D 11 CAUSE CODE E 12 CAUSE SUBCODE G 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE I 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 7 8 EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 0 6 4 27 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN E 18 FUTURE ACTION 2 FUTURE ACTION 2 EFFECT ON PLANT 2 SHUTDOWN METHOD 2 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE VARIABLE SHUNT RESISTOR CONTAINED IN THE CONTROL BOARD INDICATOR FOR ROD H-8
1 1 WAS FOUND TO BE OUT OF ADJUSTMENT AND WAS CORRECTED TO ALLOW PROPER DISPLAY. NO
1 2 FURTHER ACTION IS PLANNED.
1 3
1 4

1 5 FACILITY STATUS E 28 % POWER 0 6 4 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION SURVEILLANCE TEST 32
7 8 9 10 12 13 44 45 46 80
1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 44 45 80
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 80
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 80
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80
2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

