

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 1 2 2 3 7 8 8 0 1 1 9 7 9 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 WHILE PERFORMING A ROUTINE SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM,  
0 3 SEVERAL LOGIC FUNCTIONS IN TRAIN B TESTED UNSATISFACTORILY. THE TIME LIMIT IMPOSED  
0 4 BY T.S. TABLE 3.3-1 ACTION ITEM #1 AND TABLE 3.3-3 ACTION ITEM #13 WAS OBSERVED  
0 5 WITH TRAIN B RETURNED TO SERVICE WITHIN SIX HOURS OF DISCOVERY.  
0 6 SIMILAR OCCURRENCES INCLUDE: 0316/78-076 AND 080.

0 7

0 8

0 9 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE G 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 7 8 21 22 EVENT YEAR 23 SEQUENTIAL REPORT NO. 0 6 7 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32  
ACTION TAKEN A 18 FUTURE ACTION B 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A TEST CARD (MODEL #6056033G01) WAS DISCOVERED TO HAVE FAILED AND WAS REPLACED.  
1 1 TRAIN B WAS RETESTED WITH SATISFACTORY RESULTS AND RETURNED TO SERVICE. NO FURTHER  
1 2 ACTION IS PLANNED.

1 3

1 4

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION SURVEILLANCE TEST 32  
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY RELEASED Z 33 CONTENT OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 80

2 0 ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

NRC USE ONLY

