

## LICENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

**(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)**

0	1	M	I	D	C	C	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5	
7	8	9					14	15														25	26							30	57	CAT	58
LICENSEE CODE		LICENSE NUMBER																LICENSE TYPE						CAT									

**CON'T**

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			
		L	6	0	5	0	0	0	3	1	6	7	0	1	1	1	7	9	8	0	1	3	1	7	9	9															

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | OPERATING AT 100% POWER THE QUADRANT POWER TILT RATIO ALARM PER TECH SPEC 4.2.4 WAS

0 3 | IN ERROR. THIS REQUIRES CALCULATION OF THE TILT RATIO EACH 12 HRS. THE FIRST 12 HOUR

0 4 | SURVEILLANCE WAS MISSED. REACTOR POWER WAS CONSTANT WITH EQUILIBRIUM XENON. NO

0 5 | PROBABLE CONSEQUENCES.

0 6 |

0 7 |

0 8 |

7 8 9 80

SYSTEM CODE 0 9		CAUSE CODE Z Z		CAUSE SUBCODE Z		COMPONENT CODE Z Z Z Z Z Z						COMP. SUBCODE Z		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20		
LER/RO REPORT NUMBER 17		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 0 1		OCCURRENCE CODE 0 3		REPORT TYPE 1 1		REVISION NO. 0					
ACTION TAKEN G		FUTURE ACTION G		EFFECT ON PLANT 7		SHUTDOWN METHOD 7		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N			
33	34	35	36	37	38	39	40	41	42	43	44	45	46		
PRIME COMP. SUPPLIER 7		COMPONENT MANUFACTURER 7 9 9 9													
47	48	49	50	51	52	53	54	55	56	57	58	59	60		

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE QUADRANT POWER TILT ALARM WAS OPERABLE BUT IN ERROR BECAUSE THE INSTRUMENTS FROM

1 1 WHICH THE ALARM CALCULATES WERE BEING CALIBRATED. MAXIMUM ERROR WOULD HAVE BEEN 0.003.

1 2 PROCEDURE HAS BEEN REVISED TO REQUIRE HAND CALCULATION WHILE THESE INSTRUMENTS ARE

1 3 BEING CALIBRATED.

1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	NA	30
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE		OPERATOR OBSERVATION	
1	6	7	33	7	34	NA	35	NA	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	7	38	NA	39
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	NA	41		
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	7	42	NA	43				
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	44	NA	45				

NRC USE ONLY

7902050122

NAME OF PREPARER R. S. Lease

PHONE: (616) 465-5901

