NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M I D C C I (2) | 0 0 0 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 5 (7) | 0 1 2 2 7 9 (8) | 0 2 0 9 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE IN MODE I THE INDICATED POSITION OF ROD F-6 INDICATED A
03 DEVIATION OF GREATER THAN TWELVE STEPS FROM DEMAND POSITION. THIS IS
04 IN EXCESS OF THE LIMIT IMPOSED BY T.S. 3.1.3.2. SIMILAR OCCURRENCES
05 OF THIS TYPE PREVIOUSLY SUBMITTED ARE: 050-0315/76-13, 44 AND 54;
06 0315/77-27,28,33 AND 34; 0315/78-04-07,38,40,46, AND 050-0316/78-07,
07 08,22,31,41,48,64,75,84, AND 93.
08

09 SYSTEM CODE: I E (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: I N S T R U (14) | COMP. SUBCODE: I (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 — SEQUENTIAL REPORT NO. 0 0 1 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN: E (18) | FUTURE ACTION: X (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: N (25) | COMPONENT MANUFACTURER: W I 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE CAUSE WAS TRACED TO THE SIGNAL CONDITIONING MODULE WHICH HAD
11 DRIFTED LOW. THE MODULE WAS RESPANNED AND THE INDICATED POSITION
12 OF THE ROD RETURNED TO WITHIN SPECIFICATIONS. THE ROOT CAUSE OF
13 THIS PROBLEM HAS NOT YET BEEN DETERMINED ALTHOUGH AN ENGINEERING
14 REVIEW IS IN PROGRESS.

15 FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): OPERATIONAL EVENT

16 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

Dupe of 7902130164

19 LOSS OF OR DAMAGE TO FACILITY — TYPE: Z (42) | DESCRIPTION (43): NA

20 PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): NA

NRC USE ONLY

NAME OF PREPARER: T. P. Beilman PHONE: 616-465-5901

GPO 917-926