

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 2 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 4 5  
7 8 9 14 15 25 26 30 57 58  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

**CON'T**

REPORT SOURCE L 6 0 5 0 0 0 3 1 6 7 0 8 0 2 7 8 8 0 2 1 3 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | ON 1-30-79, WHILE REVIEWING PAST CALIBRATION DATA IT WAS DISCOVERED THAT THE TURBINE

0 3 | LOW FLUID OIL PRESSURE SWITCHES HAD BEEN SET AT A NON-CONSERVATIVE VALUE WITH

0 4 | RESPECT TO T.S. TABLE 2.2-1 ITEM 17A FROM 3-20-78 (INITIAL TURBINE OPERATION)

0 5 | THROUGH 8-2-78. ON 8-2-78 THE SWITCHES WERE READJUSTED TO WITHIN THE T.S. LIMIT.

0 6 |

0 7 |

0 8 |

7 9 8

SYSTEM CODE I A (11)		CAUSE CODE A (12)		CAUSE SUBCODE B (13)		COMPONENT CODE I N S T R U (14)						COMP. SUBCODE S (15)		VALVE SUBCODE Z (16)			
LER/RO REPORT NUMBER 7 9 (17)		EVENT YEAR 7 9 (21 22)		SEQUENTIAL REPORT NO. 0 0 4 (24 25 26)		OCCURRENCE CODE 0 1 (28 29)		REPORT TYPE T (30)		REVISION NO. 0 (32)							
ACTION TAKEN E (18)		FUTURE ACTION X (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22 23 24 25)		ATTACHMENT SUBMITTED Y (23)		NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER M 2 3 5 (26 27 28 29)	

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE PRESSURE SWITCHES WERE INITIALLY CALIBRATED UTILIZING THE VENDORS RECOMMENDED

1 1 SET POINTS AND WERE NOT RECALIBRATED AS REQUIRED UPON RECEPT OF THE UNIT TWO

1 2 T.S. TO PREVENT RECURRENCE, THE PRESSURE SWITCHES HAVE BEEN ADDED TO A ROUTINE

1 3 CALIBRATION SCHEDULE TO REQUIRE PERIODICAL SETPOINT VERIFICATION AND INSURE

1 4 T.S. COMPLIANCE. SEE SUPPLEMENT.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		QUALITY CONTROL COORDINATOR REVIEW	
1	5	G	28	0	0	0	29	C	31		
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	33	Z	34						
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38				
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0	40						
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z	42								
PUBLICITY		ISSUED		DESCRIPTION							
2	0	N	44								

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

**NRC USE ONLY**

917-926



SUPPLEMENT TO LER # 79-004/01T-0

SUPPLEMENT TO CAUSE DESCRIPTION

CURRENT AND PAST CALIBRATION DATA FOR D. C. COOK UNIT ONE INDICATES THAT THE SET POINTS ARE CONSISTENT WITH THE T.S. REQUIREMENTS. THE PRESSURE SWITCHES FOR UNIT ONE HAVE ALSO BEEN ADDED TO A ROUTINE CALIBRATION SCHEDULE AS A PRECAUTIONARY MEASURE.

