

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C I 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 57 58

LICENSEE CODE

LICENSE NUMBER

LICENSE TYPE

CAT 58

CON'T

REPORT  
SOURCE

L

0 1 0 5 0 0 0 3 1 5 7 0 1 2 0 7 9 8 0 2 2 7 7 9 9  
7 8 60 61 68 69 74 75 80

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 ON 2-1-79, WHILE REVIEWING COMPLETED SURVEILLANCE TESTS IT WAS DISCOVERED THAT A  
0 3 TEST PERFORMED ON THE SOLID STATE PROTECTION SYSTEM (SSPS) TRAIN A EXCEEDED THE  
0 4 ONE HOUR LIMIT IMPOSED UNDER TABLE 3.3-3, ACTION ITEM THIRTEEN PRIOR TO TEST  
0 5 COMPLETION.

0 6

0 7

0 8

0 9 I B 11 A 12 B 13 I N S T R U 14 X 15 Z 16  
7 8 9 10 11 12 13 18 19 20

SYSTEM  
CODECAUSE  
CODECAUSE  
SUBCODE

COMPONENT CODE

COMP.  
SUBCODEVALVE  
SUBCODE(17) LER/RO  
REPORT  
NUMBER

EVENT YEAR

7 9

SEQUENTIAL  
REPORT NO.

0 0 3

OCCURRENCE  
CODEREPORT  
TYPE

L

REVISION  
NO.

0

ACTION  
TAKENFUTURE  
ACTION

H 18 X 19

EFFECT  
ON PLANT

Z 20

SHUTDOWN  
METHOD

Z 21

HOURS

0 0 0 0

ATTACHMENT  
SUBMITTED

N 23

NPRD-4  
FORM SUB.

N 24

PRIME COMP.  
SUPPLIER

N 25

COMPONENT  
MANUFACTURER

W I 2 0

26

26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE TECHNICIAN PERFORMING THE TEST INADVERTANTLY OVERLOOKED THE ONE HOUR LIMIT  
1 1 WHICH WAS IDENTIFIED AS A PRECAUTION IN THE BODY OF THE PROCEDURE. TO PREVENT RE-  
1 2 CURRENTENCE THE ERROR WAS DISCUSSED WITH THE RESPONSIBLE TECHNICIAN AND THE ONE HOUR  
1 3 LIMIT WAS ADDED TO THE PROCEDURE DATA SHEET TO FURTHER IDENTIFY THE TIME LIMIT.

1 4

1 5 E 28 I 0 0 29 NA 30 B 31 TEST REVIEW 32  
7 8 9 10 12 13 44 45 46 80

FACILITY  
STATUS

% POWER

OTHER STATUS

METHOD OF  
DISCOVERY

DISCOVERY DESCRIPTION

ACTIVITY  
RELEASEDCONTENT  
OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

1 6 Z 33 Z 34 NA 35 NA 36  
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES  
NUMBER

1 7 0 0 0 37 Z 38 NA 39  
7 8 9 10 11 12 13 44 45 80

PERSONNEL INJURIES  
NUMBER

1 8 0 0 0 40 NA 41  
7 8 9 10 11 12 13 44 45 80

LOSS OF OR DAMAGE TO FACILITY  
TYPE

1 9 Z 42 NA 43  
7 8 9 10 11 12 13 44 45 80

PUBLICITY  
ISSUED

2 0 N 44 NA 45  
7 8 9 10 11 12 13 44 45 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

