

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

01 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 2 0 7 7 9 8 0 3 1 3 7 9 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 THE CONTAINMENT ATMOSPHERE AIR PARTICULATE AND GASEOUS RADIATION MONITORING SYSTEM
03 PUMP WAS DISCOVERED TO BE CONTINUALLY TRIPPING DUE TO A HIGH FLOW CONDITION. THE
04 ACTION STATEMENT OF T.S. TABLE 3.3-3 ITEM 3c2 WAS OBSERVED WHILE ADJUSTMENTS WERE
05 PERFORMED. SIMILAR EVENTS INCLUDE 315/76-027.

06
07
08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
M C 11 E 12 B 13 P U M P X X 14 H 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 7 9 21 22 23 SEQUENTIAL REPORT NO. 0 0 8 24 26 27 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 N 25 W 1 2 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE CAUSE WAS TRACED TO THE PUMP BYPASS FLOW ADJUSTMENTS WHICH HAD BECOME MISALIGNED.
11 THE FLOW RATE WAS ADJUSTED TO THE PROPER VALUE AND CORRECT OPERATION WAS VERIFIED.
12 THE CAUSE OF THE EVENT HAS BEEN ATTRIBUTED TO NORMAL PUMP WEAR. NO FURTHER ACTION
13 IS CURRENTLY PLANNED.

14

15 FACILITY STATUS C 28 0 5 0 29 NA OTHER STATUS 30 METHOD OF DISCOVERY A 31 OPERATOR OBSERVATION 32
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
7 8 9 10 11 44 45 46 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 44 45 46 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA
7 8 9 10 11 12 13 44 45 46 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA
7 8 9 10 11 12 13 44 45 46 80

20 PUBLICITY ISSUED DESCRIPTION 45
N 44 NA
7 8 9 10 11 12 13 44 45 46 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

