

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

REPORT

REPORT SOURCE 7 0 1 8
DOCKET NUMBER 60 L 61 0 62 5 63 0 64 0 65 0 66 3 67 1 68 5 69 7 70 0 71 2 72 2 73 6 74 7 75 9 76 8 77 0 78 3 79 2 80 0 81 7 82 9 83 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING A PLANT TOUR, AN OPERATOR OBSERVED THE CONTAINMENT AIR MONITOR
0 3 | PUMP OVERHEATING. THE PUMP WAS DECLARED INOPERABLE AND LIMITING CONDITIONS
0 4 | FOR OPERATION IN TECH. SPEC. 3.4.6.1 WERE MET. PUBLIC HEALTH AND SAFETY
0 5 | WERE NOT JEOPARDIZED.
0 6 |
0 7 |
0 8 |

SYSTEM CODE B B		CAUSE CODE E		CAUSE SUBCODE F		COMPONENT CODE P U M P X				COMP. SUBCODE H		VALVE SUBCODE Z	
(11)		(12)		(13)		(14)				(15)		(16)	
EVENT YEAR 7 9				SEQUENTIAL REPORT NO. 0 1 2		OCCURRENCE CODE 0 3		REPORT TYPE L				REVISION NO. 0	
(17)		(21)		(23)		(24)		(27)		(28)		(32)	
ACTION TAKEN A	FUTURE ACTION Z	EFFECT ON PLANT Z	SHUTDOWN METHOD Z	HOURS 0 0 0	ATTACHMENT SUBMITTED N	NPRD-4 FORM SUB. N	PRIME COMP. SUPPLIER A	COMPONENT MANUFACTURER W 1 2 0					
(18)	(19)	(20)	(21)	(22)	(23)	(24)	(25)	(26)					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 FAILURE WAS DUE TO RUBBER SPIDER IN THE LOVEJOY 1 1/4 INCH L-100 COUPLING WEARING

1 1 OUT. THE SPIDER WAS REPLACED AND AIR SAMPLER RETESTED. NO FURTHER ACTIONS

1 2 ARE PLANNED.

1 3

1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	NA	44
7	8	9	10	11	12	13	14	15	16
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	44	45	80
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	44
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES NUMBER		DESCRIPTION							
1	8	0	0	0	40	NA	44	45	80
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION							
1	9	Z	42	NA	44	45	80	81	82
7	8	9	10	11	12	13	14	15	16
PUBLICITY ISSUED		DESCRIPTION							
2	0	N	44	NA	44	45	80	81	82
7	8	9	10	11	12	13	14	15	16

NAME OF PREPARER M. S. BROWN

PHONE: 616-465-5901, EXT.398

