

## LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4		5							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35							
LICENSEE CODE														LICENSE NUMBER										LICENSE TYPE										57 CAT 58	

CON'T

0	1	L	6	0	5	0	0	0	3	1	1	5	7	0	3	1	0	7	9	8	0	4	0	9	7	9	9				
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35			
REPORT SOURCE		DOCKET NUMBER										EVENT DATE										REPORT DATE									

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 THE ROOT VALVE FOR LOWER CONTAINMENT PRESSURE TRANSMITTER PPP-300 WAS DISCOVERED

0 3 TO BE IN THE CLOSED POSITION AND UPON DISCOVERY WAS IMMEDIATELY OPENED RESTORING

0 4 THE LOOP TO OPERABLE STATUS. DUE TO THE NATURE OF DISCOVERY AND RESTORATION, ACTION

0 5 REQUIREMENTS 14 AND 16 OF T.S. TABLE 3.3-3 WERE REVIEWED WITH NO FURTHER ACTION

0 6 REQUIRED.

0 7

0 8

0	9	I	B	11	A	12	X	13	V	A	L	V	E	X	14	G	15	D	16	7	9	0	1	8	10	3	L	0	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE										COMP. SUBCODE		VALVE SUBCODE		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
LER/RO REPORT NUMBER		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER											
X		G		Z		Z		0		0		N		N		A		D											
33		34		35		36		37		38		39		40		41		42											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A SPECIFIC CAUSE FOR THIS EVENT COULD NOT BE DETERMINED. PROCEDURES WHICH REQUIRE

1 1 VALVE POSITION VERIFICATION WERE REVIEWED FOR ADEQUACY, ALL OF WHICH SPECIFY PROPER

1 2 POSITIONING. TO PREVENT RECURRENCE, THE LOWER CONTAINMENT PRESSURE ROOT VALVES FOR

1 3 UNITS ONE AND TWO HAVE BEEN SEALED OPEN AND IDENTIFIED AS SUCH IN THE APPROPRIATE

1 4 PROCEDURES TO INSURE THAT THEY REMAIN PROPERLY POSITIONED AT ALL TIMES.

1	5	E	28	1	0	0	29	NA	30	A	31	TECHNICIAN DISCOVERY	32
7	8	9	10	11	12	13	14	15	16	17	18	19	20
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					

1	6	Z	33	Z	34	NA	35	NA	36
7	8	9	10	11	12	13	14	15	16
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			

1	7	0	0	0	37	Z	38	NA	39
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					

1	8	0	0	0	40	NA	41
7	8	9	10	11	12	13	14
PERSONNEL INJURIES		DESCRIPTION					

1	9	Z	42	NA	43
7	8	9	10	11	12
LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION			

2	0	N	44	NA	45
7	8	9	10	11	12
PUBLICATION		DESCRIPTION			

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

NRC USE ONLY

