

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 3 2 3 7 9 8 0 4 1 7 7 9 9
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 WHILE IN MODE 3 A PRESSURIZER RELIEF TANK RUPTURE DISK BLEW OUT. AS A RESULT OF
0 3 THE PRESSURE SURGE CREATED IN THE LOWER CONTAINMENT, THE ICE CONDENSER INLET
0 4 DOORS WERE SHOWN TO BE IN THE OPEN POSITION BY CONTROL PANEL INDICATION. THIS
0 5 IS NOT CONSISTENT WITH THE REQUIREMENTS OF T.S. 3.6.5.3. ALL DOORS WERE MANUALLY
0 6 CLOSED WITHIN 1.5 HOURS. NO PROBABLE CONSEQUENCES.

0 7
0 8
7 8 9 80

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
7 8 9 10 11 12 13 18 19 20
S A 11 X 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
21 22 23 24 26 27 28 29 30 31 32
7 9 0 2 0 0 3 L 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
33 34 35 36 37 40 41 42 43 44 47
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 REPEATED PRESSURE FLUCTUATIONS IN THE PRESSURIZER RELIEF TANK CAUSED THE RUPTURE
1 1 DISK TO WEAKEN AND BLOW BELOW ITS DESIGN PRESSURE. THE RESULTANT PRESSURE SURGE
1 2 CAUSED DOORS TO OPEN SLIGHTLY. NO CORRECTIVE ACTION PLANNED SINCE DOORS FUNCTIONED
1 3 AS DESIGNED.

1 4
7 8 9 80
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
1 5 G 28 0 0 0 29 NA A 31 OPERATOR OBSERVATION
7 8 9 10 12 13 44 45 46 80

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6 Z 33 Z 34 NA
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7 0 0 0 37 Z 38 NA
7 8 9 11 12 13 80

PERSONNEL INJURIES NUMBER DESCRIPTION (41)
1 8 0 0 0 40 NA
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
1 9 Z 42 NA
7 8 9 10 80

PUBLICITY ISSUED DESCRIPTION (45)
2 0 N 44 NA
7 8 9 10 80

NRC USE ONLY

NAME OF PREPARER JAMES DICKSON

PHONE: (616) 465-5901



10