

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 3 2 7 7 9 8 0 4 1 7 7 9 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE IN MODE 1 THE PRESSURE IN THE REACTOR COOLANT SYSTEM WAS BELOW 2220 PSIA

0 3 | CONTRARY TO TECH. SPEC. 3.2.5.b. ACTION STATES RESTORE WITHIN 2 HOURS. PRESSURE

0 4 | WAS BELOW LIMIT FOR 6 MINUTES AND LOWEST PRESSURE ATTAINED WAS 2190 PSIA. NO

0 5 | PROBABLE CONSEQUENCES.

0 6 |

0 7 |

0 8 |

7 8 9 8

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
		C	B	A		A		Z	Z	Z	Z	Z		Z	
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
23	24	25	26	27	28	29	30	31	32	33	34				
		7	9	0	2	1	0	3	L		0				
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED					
35	36	37	38	39	40	41	42	43	44	45	46				
H	H	Z		Z		0	0	0	N	N	Z				
18	19	20	21	22	23	24	25	26	27	28	29				

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | WHEN ATTEMPTING TO BLEED PRESSURE FROM PRESSURIZER RELIEF TANK THE REACTOR

1 1 | OPERATOR INADVERTENTLY OPENED THE AUXILIARY SPRAY VALVE TO THE PRESSURIZER,

1 2 | QRV-51. VALVE WAS CLOSED ON DISCOVERY THAT IMPROPER VALVE WAS OPENED. OPERATORS

1 3 | HAVE BEEN INSTRUCTED THAT CARE MUST BE OBSERVED WHEN OPERATING CONTROLS.

1 4 |

8 9
FACILITY STATUS (1) (5) (E) (28) % POWER (1) (0) (0) (29) OTHER STATUS (30) NA
7 8 9 10 11 12 13 44
ACTIVITY CONTENT
RELEASED OF RELEASE (1) (6) (Z) (33) (Z) (34) AMOUNT OF ACTIVITY (35) NA
7 8 9 10 11 44
PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39) 7904240387
(1) (7) (0) (0) (0) (37) (Z) (38) NA
7 8 9 11 12 13 80
PERSONNEL INJURIES
NUMBER DESCRIPTION (41) NA
(1) (8) (0) (0) (0) (40) NA
7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43) NA
(1) (9) (Z) (42) NA
7 8 9 10 80
PUBLICITY
ISSUED DESCRIPTION (45) NA
(2) (0) (N) (44) NA
7 8 9 10 68 69 80
NRC USE ONLY

NAME OF PREPARER JAMES D. DICKSON

PHONE: (616) 465-5901



100