

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

CON'T

0	1	REPORT SOURCE	L	6	0	5	0	0	0	3	1	5	7	0	2	2	3	7	9	8	0	5	0	7	7	9	9
7	8		60	61	DOCKET NUMBER								68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	DURING SURVEILLANCE TESTING, DIESEL ESSENTIAL SERVICE WATER CHECK VALVES
0	3	1-ESW-111 AND 1-ESW-114 DID NOT FUNCTION PROPERLY. REPAIRS TO THESE
0	4	VALVES RENDERED THE CORRESPONDING EMERGENCY DIESEL INOPERABLE. TECH.
0	5	SPEC. 3.8.1.1 LIMITING CONDITIONS FOR OPERATION WERE SATISFIED AS THE
0	6	COMPANION DIESEL REMAINED OPERABLE. THE PUBLIC HEALTH AND SAFETY WERE
0	7	NOT JEOPARDIZED. PREVIOUS EVENT 79-006/03L-0, DOCKET 0500316.

0 8 | 7 8 9

SYSTEM CODE W A (11)		CAUSE CODE B (12)		CAUSE SUBCODE A (13)		COMP. SUBCODE C (15)		VALVE SUBCODE A (16)	
EVENT YEAR 7 9 (22)		SEQUENTIAL REPORT NO. 0 1 0 (26)		OCCURRENCE CODE 0 3 (29)		REPORT TYPE X (31)		REVISION NO. 1 (32)	
ACTION TAKEN B (18)		FUTURE ACTION F (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 (22)	
ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER C 1 8 2 (26)			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 CAUSE OF FAILURE WAS EXCESSIVE WEAR AT SPLIT DISC HINGE POINTS. THE CAST STEEL

1 1 DISCS ON THESE AND TWO ADDITIONAL VALVES IDENTICAL TO THE VALVES WHICH FAILED

1 2 WERE REPLACED WITH STAINLESS STEEL DISCS FOR BETTER WEAR CHARACTERISTICS.

1 3 PREVENTIVE MAINTENANCE WAS REVISED TO INCLUDE INSPECTING ESW CHECK VALVE

1 4 DISCS DURING 18 MONTH DIESEL ENGINE OVERHAUL.

7 8 9
FACILITY STATUS (28) 1 5 E 2 8
% POWER 1 0 0 29 10 12
OTHER STATUS (30) N/A 13 44
METHOD OF DISCOVERY (31) B 45 46
DISCOVERY DESCRIPTION (32) SURVEILLANCE TESTING 47 8

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 Z 34

AMOUNT OF ACTIVITY (35)

N/A

LOCATION OF RELEASE (36)

N/A

PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION (39)	
1	7	0	0	0	Z	38	N/A

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 N/A

7		8		9		10		11		12	
TYPE		Z ⁹		LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION		(43)			
1	9	Z ⁹	(42)			N/A				7905110124	

7 8 9 10 PUBLICITY (45)
ISSUED (44) DESCRIPTION (45) N/A 68 69 70 71 72 73 74 75 76 77 78 79 80
2 0 1 2 3 4 5 6 7 8 9 0

NAME OF PREPARER M.S. BROWN

PHONE: (616) 465-5901, EXT.398