

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

M	I	D	C	C	1	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5
LICENSEE CODE					14	15	LICENSE NUMBER										25	LICENSE TYPE					30	57	CAT 58		

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			
		L	6	0	5	0	0	0	3	1	5	7	0	4	1	9	7	9	8	0	5	1	6	7	9	9															

02 | DURING A ROUTINE CHANNEL CALIBRATION OF OVERPOWER DELTA-TEMPERATURE BISTABLE

03 | TB-421G, IT WAS DISCOVERED THAT THE BISTABLE TRIP VALUE WAS NON-CONSERVATIVE

04 | WITH RESPECT TO THE LIMIT IMPOSED BY T.S. TABLE 2.2-1 ITEM 8.

0	5
---	---

0	6	
---	---	--

0	7	
---	---	--

0	8
---	---

7 8 9

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

0 9 I A E G I N S T R U S Z

7 8 9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER	EVENT YEAR 7 9	REPORT NO. 0 3 1	CODE 0 3	TYPE L	NO. 0
ACTION TAKEN E	FUTURE ACTION C	EFFECT ON PLANT Z	SHUTDOWN METHOD Z	HOURS 0 0 0	ATTACHMENT SUBMITTED N
(18)	(19)	(20)	(21)	(22)	(23)
(24) NPD-4 FORM SUB.	(25) PRIME COMP. SUPPLIER	(26) COMPONENT MANUFACTURER	(27)	(28)	(29)
N	N	W 1 2 0			
(24)	(25)	(26)			

10 THE CAUSE OF THE NON-CONSERVATIVE TRIP POINT HAS BEEN ATTRIBUTED TO EXCESSIVE DRIFT.

THE BISTABLE WAS RECALIBRATED AND OPERATION WAS MONITORED WITH UNSATISFACTORY

RESULTS. THE BISTABLE WILL BE REPAIRED AND RESTORED TO OPERABLE STATUS PRIOR

 , TO UNIT OPERATION IN THE MODE IN WHICH OPERABILITY IS REQUIRED BY T.S. .

1	4	
---	---	--

1 5 FACILITY STATUS H (28) % POWER 0 0 0 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY B (31) ROUTINE TEST DISCOVERY DESCRIPTION (32)

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

AMOUNT OF ACTIVITY NA

LOCATION OF RELEASE NA

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
1	7	00(37)Z(38)	NA(39)

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1 8	0 0 0 (40)	NA	7905220333

1		2		3		4		5		6		7		8		9		10		11		12	
TYPE		DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT		CIRCUIT	
1	9	Z	(42)	NA																			

8 9 10
PUBLICATION
ISSUED DESCRIPTION (45)
2 0 N (44) NA 68
7 8 9 10
NRC USE ONLY
69 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901