

CONTROL BLOCK: | | | | | | | ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	0	7	0	2	7	9	8	0	7	3	1	7	9	9
60	61								68	69						74	75							80
DOCKET NUMBER										EVENT DATE							REPORT DATE							

0 2 | WHILE UNIT WAS IN MODE 3 (HOT STANDBY) PREPARING TO START UP, THE LAB SAMPLE

0 3 | INDICATED THE SOUTH BORIC ACID STORAGE TANK AND THE BORON INJECTION TANK OUT OF

0 4 | SPEC. LOW AT 19,986 and 19,857 RESPECTIVELY. TECH. SPECS. AFFECTED 3.1.2.8.a.2

0 5 | AND 3.5.4.1.b.

0 6 |

0 7 |

0 8 |

7 8 9

0 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
		S	F	X		Z		Z	Z	Z	Z	Z	Z	Z	Z
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38
		7	9	0	2	4	0	3	L		0				
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER	
39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54
E	Z	Z		Z		Z		0	0	0	N		N	Z	

1 0 | AT THESE HIGH CONCENTRATIONS, IT IS NORMAL FOR SAMPLES TO FLUCTUATE. THIS TANK,
1 1 | OVER A PERIOD OF TIME BECAME LOW. BORIC ACID FROM ANOTHER STORAGE TANK WAS
. 1 2 | TRANSFERRED TO THIS ONE, BRINGING IT BACK IN SPECS. MORE RESTRICTIVE LIMITS WILL
1 3 | BE ADMINISTRATIVELY IMPOSED.
1 4 |
7 2 0 80

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					
1	5	C	28	0	0	0	29	NA	30	B	31	NA	32
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE							
1	6	7	33	7	34	NA	35	NA	36				
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION							
1	7	0	0	0	37	7	38	NA	39				
PERSONNEL INJURIES		NUMBER		DESCRIPTION									
1	8	0	0	0	40	NA	41						
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION									
1	9	7	42	NA	43								
PUBLICITY ISSUED		DESCRIPTION											
2	0	N	44	NA	45								

7908060 316

NRC USE ONLY

PHONE: (616) 465-5901 X-316