

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7910230347 DOC. DATE: 79/10/17 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME: SHALLER, D.V. AUTHOR AFFILIATION: Indiana & Michigan Power Co.
 RECIP. NAME: KEPPLER, J.G. RECIPIENT AFFILIATION: Region 3, Chicago, Office of the Director

SUBJECT: RO: on 791017, only Unit 2 motor driven auxiliary feed pump operable w/emergency power for period of 2-h. 45 minutes. Caused by removal of emergency power from Unit 2 turbine pump w/Unit 1 motor pump out of svc for maint.

DISTRIBUTION CODE: M007S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: LER (Backfit)

NOTES: Send 3 Cys of All MATH. To I + E

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	04 IRE	2	2	MPA	1	1
	NSIC	1	1	S HANAUER	1	1
EXTERNAL:	03 LPDR	1	1			

OCT 24 1979

AOI
4

60

TOTAL NUMBER OF COPIES REQUIRED: LTTR

11 & ENCL

0
2



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

October 17, 1979

Mr. J.G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-74
Docket No. 50-316

Dear Mr. Keppler:

This is to confirm our verbal report to NRC Region III Inspector,
R.E. Masse, at 1010 hours on October 17, 1979.

At that time we reported that emergency power was removed from the
Unit 2 Turbine Driven Auxiliary Feed Pump concurrently with the
Unit 1 Motor Driven Auxiliary Feed Pump being out of service for
routine maintenance. This left only the Unit 2 Motor Driven Auxiliary
Feed Pump operable with emergency power for a time period of two
hours and forty-five minutes. All normal auxiliary power supplies
were available during this time period.

A followup report will be submitted by October 31, 1979, as required
by Technical Specification Section 6.9.1.8.

Sincerely,

D.V. Shaller
Plant Manager

/bab

cc: J.E. Dolan
R.W. Jurgensen
R.F. Kroeger
R. Kilburn
R.J. Vollen BPI
R.E. Masse RO:III
R.C. Callen MPSC
P.W. Steketee, Esq.
R. Walsh, Esq.

G. Charnoff, Esq.
J.M. Hennigan
G. Olson
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE (40 copies)
Dir., MIPC (4 copies)

M007
3/10

7910230 347

5