

Central File HQ

INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

July 28, 1980
AEP:NRC:00441

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR58 and DPR72

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

This letter responds to your letter of June 27, 1980 transmitting IE Bulletin No. 80-16 entitled, "Potential Misapplication of Rosemount Inc. Models 1151 and 1152 Pressure Transmitters with Either 'A' or 'D' Output Codes." We received your letter on July 1, 1980.

A review of our facility with respect to the installation of Rosemount Inc. Model 1151 or 1152 pressure transmitters with output codes "A" or "D" has revealed that no transmitters of the type described are currently installed nor planned for future installation in safety-related applications. Our review did reveal, however, that the NSSS supplier had purchased a total of eight (8) Model 1151 pressure or differential pressure transmitters for use during unit startup to indicate low-range Main Feedwater System flow, a non-safety related application, and that these transmitters are not of the "A" or "D" output code type.

Therefore, no further actions or corrective actions are required as a result of our review.

Very truly yours,



R. S. Hunter
Vice President

cc: Attached

8008130174

AUG 4 1980

AO/E

GD

Mr. J. G. Keppler

-2-

AEP:NRC:00441

cc: R. C. Callen
G. Charnoff
John E. Dolan
R. W. Jurgensen
D. V. Shaller - Bridgman
USNRC - Office of Inspection & Enforcement - Washington, DC 20555
Division of Reactor Operations Inspection

