

*Central  
Files*

# INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18  
BOWLING GREEN STATION  
NEW YORK, N. Y. 10004

August 8, 1980  
AEP:NRC:0165A

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74

Mr. J. G. Keppler, Regional Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137


Dear Mr. Keppler:

This letter serves to provide the information requested in IE Bulletin No. 79-03A, which was received on April 11, 1980, concerning the use of welded stainless steel pipe in safety-related systems at the Donald C. Cook Nuclear Plant.

A312 type Tp 304 seamless or welded pipe is utilized in safety-related systems at the Cook Plant. However, none of the safety-related systems utilizing A312 type Tp 304 pipe are stressed to more than 85% of the maximum allowable stress at the design temperature for pressure design.

Item Nos. 2 and 3 of the Bulletin are not applicable to the Cook Plant. This letter serves to fulfill the reporting requirements of Item No. 4 of the Bulletin.

Very truly yours,

  
R. S. Hunter  
Vice President

cc: John E. Dolan  
R. C. Callen  
G. Charnoff  
R. W. Jurgensen  
D. V. Shaller  
H. D. Thornburg - NRC

8009160/95

Q

AUG 13 1980

AS  
2

60

