

Tic

# INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18  
BOWLING GREEN STATION  
NEW YORK, N. Y. 10004

September 8, 1980  
AEP:NRC:00457

Donald C. Cook Nuclear Plant Units 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR 58 and DPR 74  
IE Bulletin No. 80-20


Mr. James G. Keppler, Director  
Office of Inspection and Enforcement  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

This letter responds to your letter of July 31, 1980 received on August 5, 1980 transmitting the subject bulletin entitled "Failure of Westinghouse Type W-2 Spring Return to Neutral Control Switches". There are no Westinghouse Type W-2 control switches used in safety-related systems at our facility. Hence, no corrective action is required by this IE Bulletin and no further actions will be taken.

In addition, as requested in your letter, our estimate of the manpower required to respond to the subject IE Bulletin amounts to 17 man-hours. However, this figure underestimates the total effort because of the use made in answering the Bulletin of previous review performed in connection with Westinghouse's NSD Technical Bulletin No. NSD-TB-80-9.

Very truly yours,

  
R. S. Hunter  
Vice President

cc: R. C. Callen  
G. Charnoff  
J. E. Dolan  
R. W. Jurgensen  
D. V. Shaller - Bridgman  
NRC Region III Resident Inspector - Bridgman

8009260212

AO  
2

GD

SEP 11 1980

