

**INDIANA & MICHIGAN**  
**ELECTRIC COMPANY**  
**DONALD C. COOK NUCLEAR PLANT**

**Instruction or Procedure Temporary Sheet**

<p>This temporary sheet applies to <b>OFF-SITE RADIOLOGICAL MONITORING</b></p> <p>Instruction or Procedure No. <b>PMP 2081 EPP.012</b></p> <p>Revision No. <b>0</b></p>	<p><b>TEMPORARY SHEET NO.</b></p> <p><b>TP-1</b></p>
<p>The following change ( <input checked="" type="checkbox"/> ) new requirement (    ) shall be instituted effective (Date) <u>25 Februray, 1982</u>.</p> <p>Change step 3.7.2 to read:</p> <p style="padding-left: 40px;">Place a particulate filter and a silver zeolite cartridge in the air sampler and collect a sample of 5 to 10 cubic foot volume at the location where the mRem/hr reading was the highest (found during the traverse).</p> <p>Step 3.7.4 - Change "charcoal" to "silver zeolite".</p> <div style="text-align: center; margin: 20px 0;"><div style="border: 1px solid black; width: 200px; height: 100px; margin: 0 auto; display: flex; align-items: center; justify-content: center;">FEB 27 1982</div></div> <p><b>REASON:</b> Change sample specification from time to total volume. Change re- ferences to charcoal cartridges to silver zeolite.</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES      <input type="checkbox"/> NO      <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>PROCEDURE REVISION</u></p> <p>Originator: <u><i>W. J. Smith</i></u></p> <p>Management Staff: <u><i>W. J. Smith</i></u></p> <p>Senior Reactor Operator: <u><i>W. J. Smith</i></u></p> <p>PNSRC <u><i>E. L. Townley</i></u> Date <u><i>2-25-82</i></u></p> <p>Plant Manager <u><i>W. J. Smith</i></u> Date <u><i>2-25-82</i></u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

1944

**INDIANA & MICHIGAN**  
**ELECTRIC COMPANY**  
**DONALD C. COOK NUCLEAR PLANT**

**Instruction or Procedure Temporary Sheet**

<p>This temporary sheet applies to ENVIRONMENTAL MONITORING &amp; ANALYSIS Instruction or Procedure No. PMP 2081 EPP.013 Revision No. 0</p>	<p>TEMPORARY SHEET NO.  TP-1</p>
<p>The following change ( X )    new requirement (    )    shall be instituted effective (Date) <u>25 February, 1982</u>.</p> <p>Change step 3.2.7 to read:</p> <p style="margin-left: 40px;">Collect air samples of 5 to 10 cubic feet total volume at the location of maximum dose rate (cloud centerline) at various distances (e.g., consider 1, 2, 3, 4, 5, 10, 20 miles from the site).</p> <div style="text-align: center; margin-top: 100px;"><div style="border: 1px dashed black; padding: 10px; display: inline-block;">FEB 27 1982</div></div> <p><b>REASON:</b> Change sample specification from sample time to total sample volume to account for different sample flow rates.</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES      <input type="checkbox"/> NO      <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>PROCEDURE REVISION</u> Originator: <u>[Signature]</u> Management Staff: <u>[Signature]</u> Senior Reactor Operator: <u>[Signature]</u> PNSRC <u>E. L. Townley</u> Date <u>2-25-82</u> Plant Manager <u>[Signature]</u> Date <u>2-25-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p> <div style="text-align: center; margin-top: 50px;"><div style="border: 1px solid black; width: 50px; height: 50px; transform: rotate(45deg); display: inline-block;"></div></div>



X

**INDIANA & MICHIGAN**  
**ELECTRIC COMPANY**  
**DONALD C. COOK NUCLEAR PLANT**

**Instruction or Procedure Temporary Sheet**

<p>This temporary sheet applies to <b>OFF-SITE DOSE ASSESSMENTS</b>.</p> <p>Instruction or Procedure No. <b>PMP 2081 EPP.014</b></p> <p>Revision No. <b>0</b></p>	<p><b>TEMPORARY SHEET NO.</b></p> <p><b>TP-1</b></p>
<p>The following change ( <input checked="" type="checkbox"/> ) <b>new requirement (    )</b> shall be instituted effective (Date) <u><b>25 February, 1982</b></u>.</p> <p>The procedure is defective and is not to be used until the review currently in progress results in the necessary revisions.</p> <div style="text-align: right; margin-top: 100px;"><div style="border: 1px solid black; padding: 5px; display: inline-block;">302 FEB 27 1982</div></div>	
<p><u><b>REASON:</b></u> Current procedure is incomplete and does not agree with other methods of off-site dose assessment.</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input type="checkbox"/> YES      <input checked="" type="checkbox"/> NO      <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u><b>PROCEDURE REVISION</b></u></p> <p>Originator: <u><i>R. Palmer</i></u></p> <p>Management Staff: <u><i>E. J. Amantele</i></u></p> <p>Senior Reactor Operator: <u><i>B. J. Amantele</i></u></p> <p>PNSRC <u><i>E. J. Townley</i></u> Date <u><b>2-25-82</b></u></p> <p>Plant Manager <u><i>W. J. Amantele</i></u> Date <u><b>2-25-82</b></u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY  
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2031 EPP.001	Emergency Telephone Communications	Revision 0 4-1-81	
EPP.002	Barring of the PABX	Revision 0 4-1-81	
EPP.003	Follow-Up Off-Site Communications	Revision 0 4-1-81	
EPP.004	Protective Action Guides (PAGs) and Protective Actions	Revision 0 4-1-81	
EPP.005	Personnel Evacuation	Revision 0 4-1-81	
EPP.006	Activation of the Reentry and Rescue Team	Revision 0 4-1-81	
EPP.007	Security Actions During Emergency Conditions	Revision 0 4-1-81	
EPP.008	Emergency Medical Plan Guidelines	Revision 0 4-1-81	
EPP.009	Health Physics Procedures	Revision 0 4-1-81	
EPP.010	Activation of Radiation Monitoring Teams	Revision 0 4-1-81	
EPP.011	On-Site Radiological Monitoring	Revision 0 4-1-81	
EPP.012	Off-Site Radiological Monitoring	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A
EPP.013	Environmental Monitoring and Analysis	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A

INDIANA & MICHIGAN POWER COMPANY  
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2081 EPP.014	Off-Site Dose Assessments	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A
EPP.015	Sampling and Analysis of Waterborne Releases	Revision 0 4-1-81	
EPP.016	Collection and Analysis of Liquid and Gaseous Samples	Revision 0 4-1-81	
EPP.017	Interpretation of Liquid and Gaseous Samples	Revision 0 4-1-81	
EPP.018	Transportation Accidents Involving Radioactive Material	Revision 0 4-1-81	
EPP.019	AEP Emergency Response Organization Activation and Management	Revision 0 4-1-82	
EPP.020	Activation and Operation of the Technical Support Center (TSC)	Revision 0 4-1-81	TP-1,11-16-81 Exp N/A
EPP.021	Activation and Operation of the Operations Staging Area (OSA) and Personnel Accountability	Revision 0 4-1-81	TP-1,11-16-81 Exp N/A
EPP.022	Activation and Operation of the Recovery Center (RC) (An Emergency Operations Facility)	Revision 0 4-1-81	
EPP.023	Activation and Operation of the Emergency Control Center (ECC) (An Emergency Operations Facility)	Revision 0 4-1-81	
EPP.024	Activation and Operation of the Joint Public Information Center (JPIC) (An Emergency Operations Facility)	Revision 0 4-1-81	

