

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8204060050 DOC. DATE: 82/03/29 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 HUNTER, R.S. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application to amend Licenses DPR-58 & DPR-74, changing Tech Specs to incorporate editorial & organizational changes.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6+12
 TITLE: General Distribution for after Issuance of Operating License

NOTES: I&E: 3 copies all material.
 I&E: 3 copies all material.

05000315
 05000316

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
INTERNAL:	ORB #1 BC	01	13	13					
	ELD		1	0	IE	06	1	1	
	NRR/DHFS DEPY08		1	1	NRR/DL DIR		1	1	
	NRR/DL/QRAB		1	0	NRR/DSI/RAB		1	1	
	REG FILE	04	1	1	RGN3		1	1	
EXTERNAL:	ACRS	09	10	10	LPDR	03	2	2	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					

W/CHECK: \$3200.00

TOTAL NUMBER OF COPIES REQUIRED: LTTR

39

36

ENCL

37

34


INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

March 29, 1982
AEP:NRC:0659

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
TECHNICAL SPECIFICATIONS CHANGE REQUEST

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Dear Mr. Denton:

This letter and its Attachments request several changes to the Donald C. Cook Nuclear Plant, Unit No. 1 and No. 2 Appendix A Technical Specifications. Attachment No. 1 to this letter contains the description of the changes. Attachment No. 2 contains the revised Technical Specification pages for Unit No. 1 and Attachment No. 3 contains the revised Technical Specification pages for Unit No. 2. All changes are indicated by a vertical line on the right hand side of the page in Attachment Nos. 2 and 3.

The proposed Technical Specification changes contained herein have been reviewed and approved by the Plant Nuclear Safety Review Committee (PNSRC). Change No. 1 has been approved by the AEPSC Nuclear Safety and Design Review Committee (NSDRC) and Change Nos. 2, 3, and 4 will be presented to the NSDRC at their next meeting.

Four proposed Technical Specification revisions are contained in this submittal. Change Nos. 2 and 3 are considered to be Class II amendments (\$1,200.00 fee each). Class I duplicate fees also apply for these changes. Change Nos. 1 and 4 are editorial in nature. Enclosed, therefore, is a check in the amount of \$3,200.00 for NRC processing of the aforementioned requests.

*Acc'd
5
w/check!
\$1 3200.00*

8204060050 820329
PDR ADDCK 05000315
PDR

100-100000

100-100000

100-100000

100-100000

100-100000


100-100000

100-100000

100-100000

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



R. S. Hunter
Vice President

/md

cc: John E. Dolan - Columbus
R. W. Jurgensen
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Charnoff
Joe Williams, Jr.
NRC Resident Inspector at Cook Plant - Bridgman

ATTACHMENT NO. 1 TO AEP:NRC:00659
DESCRIPTION OF PROPOSED TECHNICAL SPECIFICATION CHANGES
FOR D. C. COOK UNIT NOS. 1 AND 2

Change No. 1

Unit 1; Page 3/4 3-9; Table 3.3-1

Unit 2; Page 3/4 3-8; Table 3.3-1

This change is editorial in nature. For Unit Nos. 1 and 2, it is requested to change the words "Turbine impulse chamber pressure" under Designation P-7 of the Reactor Trip System Interlocks of Table 3.3-1 ("Reactor Trip System Instrumentation") to more accurately describe these channels. For Unit No. 1, it is requested that these words be changed to "Turbine First Stage Pressure" which is the control room nameplate terminology used for these channels. For Unit No. 2, it is requested to change these words to "Pressure Before the First Stage" which is a technically accurate description of these channels. The Unit No. 2 control room nameplate terminology will be changed to coincide with the proposed wording. The above changes will result in accurate and consistent Technical Specification and control room nameplate terminology descriptions of these channels. These changes will not adversely affect the health and safety of the general public.

Change No. 2

Unit 1; Page 6-2; Figure 6.2-1

Unit 2; Page 6-2; Figure 6.2-1

Figure 6.2-1 is the "Offsite Organization for Facility Management and Technical Support". This Figure has been revised to incorporate the most recent offsite organizational management changes. The proposed changes will result in a Figure which more accurately describes our current organization. These changes will not adversely affect the health and safety of the general public.

Change No. 3

Unit 1; Page 6-3; Figure 6.2-2

Page 6-5; Section 6.3

Page 6-6; Section 6.5.1.2

Unit 2; Page 6-3; Figure 6.2-2

Page 6-5; Section 6.3

Page 6-5; Section 6.5.1.2

Figure 6.2-2 of both Units' Technical Specifications is the "Facility Organization" of the Donald C. Cook Nuclear Plant. This Figure has been amended to show current position titles and the addition of the following five supervisory positions:

Fire Protection Coordinator
Chief Security Supervisor
Shift Security Supervisor
Environmental Coordinator
Shift Technical Advisor

Three footnotes have also been added to the legend of the chart to more accurately describe the reporting nature of the QA Supervisor and to indicate the Unit Supervisor's present operating license. The indicated changes will make the Facility Organization chart current.

In addition, Specification 6.3.2 has been added under Specification 6.3, "Facility Staff Qualifications", of both Units. Specification 6.3.2 has been added to accommodate our new Operations Superintendent, who does not presently hold a Senior Reactor Operator's License (SOL).

Specification 6.5.1.2, which identifies the Chairman and Members of the Plant Nuclear Safety Review Committee (PNSRC), has been amended to reflect present position titles. In addition, the Shift Supervisor and Environmental Coordinator have been included as PNSRC members.

These changes will not adversely affect the health and safety of the general public.

Change No. 4

Unit 1; Page 6-13; Section 6.7.1.d

Unit 2; Page 6-13; Section 6.7.1.d

Specification 6.7.1.d identifies to whom a Safety Limit Violation Report shall be submitted in the event a Safety Limit is violated. This change is editorial in nature and serves to reflect the present position title of the previous Vice President, Nuclear Engineering. Thus, in addition to the Commission and the Chairman of the NSDRG, a Safety Violation Report shall also be submitted to the Executive Vice President, Construction and New York Engineering, AEPSC. This change will not adversely affect the health and safety of the general public.

ATTACHMENT NO. 2 TO AEP:NRC:00659
REVISED TECHNICAL SPECIFICATION PAGES FOR D.C. COOK UNIT NO. 1