REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8207210235 DOC.DATE: 82/07/12 NOTARIZED: NO DOCKET #
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
AUTH.NAME AUTHOR AFFILIATION
HUNTER,R.S. Indiana & Michigan Electric Co.
RECIP.NAME RECIPIENT AFFILIATION
DENTON,H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application to amend Licenses DPR-58 & DPR-74,changing App A Tech Specs re power distribution limits.Class III amend fee encl.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5+19
TITLE: General Distribution for after Issuance of Operating License

NOTES: w/check: $4,400.00

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
	ORB #1 BC	01	7	7				
INTERNAL:	ELD/HDS3		1	0	NRR/DHFS DEPY08		1	1
	NRR/DL DIR		1	1	~~NRR/DL/ORAB~~		1	0
	NRR/DSI/RAB		1	1	REG FILE	04	1	1
	RGN3		1	1				
EXTERNAL:	ACRS	09	10	10	LPDR	03	2	2
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 27

INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

July 12, 1982
AEP:NRC:0710

Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
TECHNICAL SPECIFICATIONS CHANGE REQUEST

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

This letter and its Attachments request changes to several Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2 Appendix A Technical Specifications which affect the operating procedures involving the power distribution limits. Attachment No. 1 to this letter contains a brief description of the changes. Attachment No. 2 contains the revised Technical Specification pages for Unit No. 1 and Attachment No. 3 contains the revised Technical Specification pages for Unit No. 2. All changes are indicated by a vertical line on the right-hand side of the page in Attachment Nos. 2 and 3.

The proposed Technical Specification changes contained herein have been reviewed by the Plant Nuclear Safety Review Committee (PNSRC) and will be reviewed by the Nuclear Safety and Design Review Committee (NSDRC) at their next meeting.

The proposed Technical Specification revisions contained in this submittal are considered to be a Class III amendment ($4,000.00 fee). A Class I duplicate fee also applies to the proposed revisions. Enclosed, therefore, is a check in the amount of $4,400.00 for NRC processing of the aforementioned requests.

A001 w/check: $4400.00

This document has been prepared following Corporate Procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,

R. S. Hunter
Vice President

/md

cc: (attached)

cc: John E. Dolan
R. W. Jurgensen
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Charnoff
Joe Williams, Jr.
NRC Resident Inspector at Cook Plant - Bridgman

ATTACHMENT NO. 1 TO AEP:NRC:0710
DESCRIPTION OF PROPOSED TECHNICAL SPECIFICATION
CHANGES FOR D. C. COOK UNIT NOS. 1 AND 2

ATTACHMENT NO. 1 TO AEP:NRC:0710

Unit No. 1

Revised Pages: 3/4 2-1, 3/4 2-2, 3/4 2-3, 3/4 2-4 (Figure 3.2-1), 3/4 2-6, 3/4 2-7, 3/4 2-8(a) (Figure 3.2-3), 3/4 2-17, and B 3/4 2-2.

Unit No. 2

Revised Pages: 3/4 2-1, 3/4 2-2, 3/4 2-3, 3/4 2-4 (Figure 3.2-1), 3/4 2-6, 3/4 2-7, 3/4 2-8(a) (Figure 3.2-3), 3/4 2-18, and B 3/4 2-2.

The proposed changes to the Technical Specifications affecting the operating procedures involving the power distribution limits will allow operation of D. C. Cook Unit Nos. 1 and 2 with Exxon Nuclear Company (ENC) power distribution control procedures which utilize a ±3% target band in addition to the current target band of ±5%. These changes are based on ENC Report XN-NF-77-57, Supplement 2(P) entitled "Exxon Nuclear Power Distribution Control for Pressurized Water Reactors - Phase II" dated September 28, 1981 submitted to the NRC by ENC on October 16, 1981.

All changes have been indicated by vertical bars on the right hand margin.

ATTACHMENT NO. 2 TO AEP:NRC:0710
REVISED TECHNICAL SPECIFICATION PAGES FOR
D. C. COOK UNIT NO. 1