

DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2  
TECHNICAL SPECIFICATIONS CHANGE REQUEST  
ATTACHMENT TO AEP:NRC:0631A

---

8210050160 820929  
PDR ADCK 05000315  
P PDR



10-11-68

10-11-68

CONTAINMENT SYSTEMS

3/4.6.4 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

---

3.6.4.1 Two containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2

ACTION:

With one hydrogen analysis device inoperable, restore the inoperable analysis device to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

---

4.6.4.1 Each hydrogen analysis device shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using a zero and span gas.



CONTAINMENT SYSTEMS

3/4.6.4 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

---

3.6.4.1 Two containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2

ACTION:

With one hydrogen analysis device inoperable, restore the inoperable analysis device to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours..

SURVEILLANCE REQUIREMENTS

---

4.6.4.1 Each hydrogen analysis device shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using a zero and span gas.

