

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS):

ACCESSION: NBR: 93051601217 DDCI DATE: 83/05/10 NOTARIZED: NO DOCKET #: 05000315  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000316  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME: AUTHOR: AFFILIATION: Indiana & Michigan Electric Co.  
 HERING, R. F. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director.  
 RECIPIENT NAME: DENTON, H. R.

SUBJECT: Application to amend Licenses DPR-58 & DPR-74, adding Tech Spec Section 4.0.5 to incorporate inservice insp & testing requirements of ASME Code Section XI, Class III, fee for Unit 1 & Class I, fee for Unit 2, encl.

DISTRIBUTION CODE: A047S COPIES RECEIVED: LTR: 1 ENCL: 1 SIZE: 4432  
 TITLE: OR: Submittals Inservice Inspection/Testing

NOTES: w/ check \$4,400

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR ORB1, BCI 01:	7 7		
INTERNAL:	ELD/HDS3:	1 0	NRR/DEV/MEB:	15 1
	NRR/DEV/MTB 14:	1 1	REG FILE:	04 1
	RGN3:	1 1		
EXTERNAL:	ACRS 16:	10 10	LPOR:	03 2
	NRCI POR: 02:	1 1	NSIC:	05 1
	NTIS:	1 1		

[illegible]

# INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18  
BOWLING GREEN STATION  
NEW YORK, N. Y. 10004

May 10, 1983  
AEP:NRC:0433

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
TECHNICAL SPECIFICATION CHANGE REQUESTS-  
IN-SERVICE TESTING PROGRAM

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Reference (1) Letter No. AEP:NRC:0433A dated February 25, 1983  
(2) Amendments No. 71 (Unit 1) and No. 53 (Unit 2), dated  
April 13, 1983

Dear Mr. Denton:

This letter and its three Attachments request changes in several Appendix 'A' Technical Specifications for the Donald C. Cook Nuclear Plant. Attachments 2 and 3 contain the revised Technical Specification pages, with the proposed revisions marked by a vertical line on the right hand side. We request that the NRC file and process this Technical Specification Change package as a single Amendment for each Unit.

The changes proposed in Attachment No. 2 to this letter incorporate the reference to the new T/S No. 4.0.5 which was submitted to the NRC in Reference (1) and issued via Reference (2). Attachment No. 3 requests some small changes to the Unit No. 2 Technical Specifications.

These proposed Technical Specifications have been reviewed by the Plant Nuclear Safety Committee and will be reviewed by the AEPSC Nuclear Safety and Design Review Committee at its next scheduled meeting.

8305160121 830510  
PDR ADDCK 05000315  
P PDR

A047  
w/check  
\$4,400



AEPSA interprets 10 CFR 170.22 as requiring that a Class III Amendment Fee for Unit No. 1 and a Class I duplicate Amendment fee for Unit No. 2 accompany this submittal. A check in the amount of \$4,400. is hereby attached for the NRC processing of this document.

This document has been prepared following Corporate Procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



R. F. Hering  
Vice President

/os

cc: John E. Dolan - Columbus  
R. S. Hunter  
M. P. Alexich  
R. W. Jurgensen  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Charnoff  
NRC Resident Inspector at Cook Plant - Bridgman

Attachment No. 1 to AEP:NRC:0433

This Attachment provides a summary description and listing of the changes being proposed in Attachments 2 and 3.

Attachment No. 2 (Unit No. 1)

The Unit No. 1 Technical Specifications are being revised to reflect issuance of the new T/S No. 4.0.5 via Reference (2) of the cover letter. The new section 4.0.5 incorporates the Inservice Inspection and Testing requirements of the ASME Code Section XI for the Donald C. Cook Plant, Unit No. 1 and is identical to the section with the same number in the Unit No. 2 Technical Specifications. The proposed changes will replace the individual testing procedures of various components by a standard reference to Section XI of the ASME Code. Some changes are being proposed to make the Unit 1 and Unit 2's Technical Specifications equal in content.

Revised Pages for Unit No. 1

<u>Pages No.</u>	<u>Section Revised</u>
3/4 0-2	Footnote deleted
3/4 1-11	4.1.2.3.1
3/4 1-12	4.1.2.4
3/4 1-13	4.1.2.5
3/4 1-14	4.1.2.6
3/4 4-7	4.4.5.0; 4.4.5.2
3/4 4-8	4.4.5.6.3, 4.4.5.2.c
3/4 4-9	4.4.5.3.b
3/4 4-10	4.4.5.a.5
3/4 4-11	No change, added for continuity
3/4 4-12	Table 4.4-1
3/4 4-33	3.4.10.1, 4.4.10.1
3/4 4-34	Deleted
3/4 4-35 through 4-42 (Table 4.4-6)	Deleted
3/4 4-43, 44	Renumbered Pages
3/4 5-4 through 5-6	4.5.2 - subsections rearranged
3/4 5-6a	Deleted
3/4 6-10	4.6.2.1
3/4 6-11	Intentionally left blank
3/4 7-5, 7-6	4.7.1.2
3/4 7-15	4.7.3.1
3/4 7-16	Intentionally left blank
3/4 7-17	4.7.4.1
3/4 7-18	Intentionally left blank
B 3/4 0-5	4.0.5 - this is a new page
B 3/4 4-12	3/4.4.10
B 3/4 4-13	Deleted

Attachment No. 3 (Unit No. 2)

Surveillance requirement No. 4.1.2.3.1 for the centrifugal charging pumps has been changed from 2405 psig to 2390 psig, to reflect the difference in volume control tank pressure in Modes 5 and 6 from that in Modes 1 to 4. Surveillance requirement No. 4.7.1.2 is being changed to reference the existence of T/S No. 4.0.5.

Revised Pages for Unit No. 2

<u>Page No.</u>	<u>Section Revised</u>
3/4 1-11	4.1.2.3.1
3/4 7-5	4.7.1.2
3/4 7-6	4.7.1.2