

ATTACHMENT TO AEP:NRC:0890

PROPOSED REVISION TO TECHNICAL  
SPECIFICATION PAGE

B404300026 B40424  
PDR ADDCK 05000316  
P PDR



## REFUELING OPERATIONS

### INSTRUMENTATION

### LIMITING CONDITION FOR OPERATION

3.9.2 As a minimum, two source range neutron flux monitors shall be operating, each with continuous visual indication in the control room and one with audible indication in the containment and control room.

APPLICABILITY: MODE 6.

### ACTION:

With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes.\* The provisions of Specification 3.0.3 are not applicable.

### SURVEILLANCE REQUIREMENTS

4.9.2 Each source range neutron flux monitor shall be demonstrated OPERABLE by performance of:

- a. A CHANNEL FUNCTIONAL TEST at least once per 7 days, and
- b. A CHANNEL FUNCTIONAL TEST within 8 hours prior to the initial start of CORE ALTERATIONS, and
- c. A CHANNEL CHECK at least once per 12 hours during CORE ALTERATIONS.

\*During the 1984 refueling outage only, removal of the last 30 assemblies is allowed with only one source range neutron flux monitor operating.