

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8501230293. DOC. DATE: 85/01/15 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME: ALEXICH, M.P. AUTHOR AFFILIATION: Indiana & Michigan Electric Co.  
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director

SUBJECT: Responds to 841126 request for addl info re. schedule for providing addl info on spray additive sys surveillance requirements. Schedule for Items 1-3 not available until 850628, Item 4 re procedures will be completed by 850331.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL. 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

## NOTES:

OL: 10/25/74

05000315

OL: 12/23/72

05000316

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB1 BC	01	7				
INTERNAL:	ACRS	09	6		ADM/LFMB		1
	ELD/HDS3		1		NRR/DE/MTEB		1
	NRR/DL DIR		1		NRR/DL/ORAB		1
	NRR/DL/TSRG		1		NRR/DSI/METB		1
	NRR/DSI/RAB		1		REG FILE	04	1
	RGN3		1				
EXTERNAL:	LPDR	03	2		NRC PDR	02	1
	NSIC	05	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL. 2



# INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631  
COLUMBUS, OHIO 43216

January 15, 1985

AEP:NRC:0914

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
SPRAY ADDITIVE SYSTEM TECHNICAL SPECIFICATION  
RESPONSE TO REQUEST FOR FURTHER INFORMATION

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Denton:

This letter is in response to your November 26, 1984 letter requesting a schedule for providing further information on spray additive system surveillance requirements. As discussed with your staff, we will be unable to provide a complete schedule for items 1-3 until June 28, 1985. Prior to providing such a schedule, we need time to evaluate a proposal to analyze the consequences of operating without the addition of sodium hydroxide to the containment through the spray system, during the initial phase of an accident.

Should the results of that evaluation indicate analyses can be performed to demonstrate that an operable system capable of delivering sodium hydroxide through the containment spray system is not essential to public health and safety, we will then transmit a schedule for the completion of those analyses. If the evaluation indicates this approach is not feasible, we will transmit a schedule for the specific information you requested.

With respect to item 4, emergency procedure revisions which address spray system malfunctions will be completed by the end of March, 1985.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



M. P. Alexich  
Vice President

7000  
1-15-85

8501230293 850115  
PDR ADOCK 05000315  
P PDR

cm

cc: John E. Dolan  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Bruchmann  
G. Charnoff  
NRC Resident Inspector - Bridgman

Acc  
1/10

