DMB

American Electric Power System
INDIANA & MICHIGAN ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

PRIORITY ROUTING

First		Second	
RA		RC	
DRA		RIC	
DRP		SG	
DRS		RL	
DRSS		OL	
DRMA		OI	
		PAD	

FILE

Orig + 2

September 20, 1985

Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58/74
Docket Nos. 50-315/50-316

Dear Mr. Keppler:

Pursuant to the requirements of Appendix B, Part II, Nonradiological, Environmental Protection Plan, Section 3.2, a copy of the report to the Michigan Water Resources Commission notifying them of a high pH on August 17, 1985 while draining the #23 Steam Generator, is attached. This report is required by Amendment No. 54 to Facility Operating License No. DPR-58 and Amendment No. 40 to Facility Operating License No. DPR-74 dated May 6, 1982.

Sincerely,

for W.G. Smith, Jr.
Plant Manager

/bab

Attachment

cc: John E. Dolan
M.P. Alexich
R.F. Kroeger
H.B. Brugger
R.W. Jurgensen
NRC Resident Inspector
R.C. Callen, MPSC
G. Charnoff, Esq.
D. Hahn
H.R. Denton, NRC
J.F. Stietzel
Dottie Sherman, ANI Library
INPO
PNSRC
A.A. Blind

IE25 delete RIII

SEP 26 1985

American Electric Power System
INDIANA & MICHIGAN ELECTRIC COMPANY
ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801
Telephone (219) 425-2111

September 9, 1985
(Corrected Copy)

RICHARD C. MENGE
Vice President

Valdas Adamkus, Regional Administrator
U.S. EPA, Region V
230 South Dearborn Street
Chicago, Illinois 60604

Dear Mr. Adamkus:

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. 0005827
Steam Generator Blowdown

Anticipating a return to service after a maintenance outage, the Number 23 steam generators on the Unit 2 nuclear steam supply system was drained. A grab sample of the effluent taken on August 17, 1985 had a pH of 10.58.

The elevated pH is likely due to the addition of ammonia during the outage to prevent steam generator degradation.

Very truly yours,

Richard C. Menge

Richard C. Menge
Vice President

RCM/df
c: W. G. Smith, Jr.

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge

Richard C. Menge

American Electric Power System
INDIANA & MICHIGAN ELECTRIC COMPANY
ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801
Telephone (219) 425-2111

September 9, 1985
(Corrected Copy)

RICHARD C. MENGE
Vice President

Paul D. Zugger, Executive Secretary
Michigan Water Resources Commission
Stevens D. Mason Building, Box 30026
Lansing, Michigan 48909

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. 0005827
Steam Generator Blowdown

Anticipating a return to service after a maintenance outage, the Number 23 steam generators on the Unit 2 nuclear steam supply system was drained. A grab sample of the effluent taken on August 17, 1985 had a pH of 10.58.

The elevated pH is likely due to the addition of ammonia during the outage to prevent steam generator degradation.

Very truly yours,

Richard C. Menge

Richard C. Menge
Vice President

RCM/df
c: W. G. Smith, Jr.

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge

Richard C. Menge