

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8606260352 DDC DATE: 86/06/20 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Clarifies 830510 application to amend Licenses DPR-58 &
 DPR-74, revising Tech Specs re inservice insp & testing
 requirements, boric acid transfer pumps & auxiliary feedwater
 pumps. Revised Tech Specs encl.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4 + 30
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-A ADTS	1 1	PWR-A EB	1 1
PWR-A PD4 LA	1 0	PWR-A PD4 PD 01	5 5
WIGGINGTON, D	1 1		
INTERNAL: ADM/LFMB	1 0	ELD/HDS3	1 0
NRR/DSRO/EIB	1 1	NRR/TAMB	1 1
<u>REG FILE</u> 04	1 1	RGN3	1 1
EXTERNAL: LPDR 03	2 2	NRC PDR 02	1 1
NSIC 05	1 1		

The following information was obtained from the records of the
 Department of the Interior, Bureau of Land Management, on the
 subject of the proposed project. The information is being
 furnished to you for your information and use.

The proposed project is located on the land owned by the
 Department of the Interior, Bureau of Land Management, and is
 situated in the State of California. The project is being
 conducted in accordance with the provisions of the National
 Antiquities Act.

The project is being conducted in accordance with the
 provisions of the National Antiquities Act.

Project Name	Location	Area (Acres)	Year	Status
Project A	Location A	100	1950	Completed
Project B	Location B	200	1951	In Progress
Project C	Location C	300	1952	Planned
Project D	Location D	400	1953	Completed
Project E	Location E	500	1954	In Progress
Project F	Location F	600	1955	Planned
Project G	Location G	700	1956	Completed
Project H	Location H	800	1957	In Progress
Project I	Location I	900	1958	Planned
Project J	Location J	1000	1959	Completed

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631
COLUMBUS, OHIO 43216

June 20, 1986
AEP:NRC:0433K

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
CLARIFICATION TO OUR SUBMITTAL AEP:NRC:0433

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:


Pursuant to discussion with your staff, this letter and its attachment are being submitted as a clarification to our earlier submittal AEP:NRC:0433, dated May 10, 1983 regarding Inservice Inspection and Testing for the Donald C. Cook Nuclear Plant.

The Technical Specification (T/S) pages contained in the attachment to this letter are the same pages that were submitted with our earlier submittal noted above, but are updated to the current amendment. In addition to resubmitting these pages we are retaining the current T/S test frequency for inservice testing of pumps pending our submittal of additional information requested by your staff. The T/S change request for pump test frequency pursuant to ASME Boiler and Pressure Vessel Code Section XI requirements will be resubmitted at a later date. The request for change on the rest of the items remains unchanged from our AEP:NRC:0433 submittal.

This revision to the T/S change request has been reviewed by the Plant Nuclear Safety Committee (PNSRC) and will be reviewed by the Nuclear Safety and Design Review Committee (NSDRC) at the next regularly scheduled meeting.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,


M. P. Alexich
Vice President
PBK
6/20/86

8606260352 860620
PDR ADDCK 05000315
P PDR

cm

Attachments

cc: John E. Dolan
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Bruchmann
G. Charnoff
NRC Resident Inspector - Bridgman

A047
11

bc: J. G. Feinstein/T. R. Satyan-Sharma/P. E. Infanger
S. H. Horowitz/T. O. Argenta/R. C. Carruth
J. J. Markowsky/S. H. Steinhart/J. A. Kobyra
R. W. Jurgensen
R. F. Kroeger
M. L. Horvath - Bridgman
J. F. Stietzel - Bridgman
C. A. Erikson
J. B. Shinnock
D. L. Wigginton, NRC - Washington, D.C.
AEP:NRC:0433K
AEP:NRC:0433
DC-N-6015.1
DC-N-6500.1
NRCD:0433.TRS

Attachment No. 1 to AEP:NRC:0433K

This Attachment provides a summary description and listing of the changes being proposed in Attachment 2.

These pages include the same change requests as our previous submittal but have been updated to include amendments issued since our initial submittal.

The Unit No. 1 Technical Specifications are being revised to reflect issuance of the new T/S No. 4.0.5 via Reference (2) of our letter AEP:NRC:0433. The new section 4.0.5 incorporates the Inservice Inspection and Testing requirements of the ASME Boiler & Pressure Vessel Code Section XI for the Donald C. Cook Plant, Unit No. 1 and is identical to the section with the same number in the Unit No. 2 Technical Specifications. The proposed changes will replace the individual testing procedures of various components by a standard reference to Section XI of the ASME Code. Some changes are being proposed to make the Unit 1 and Unit 2 Technical Specifications equal in content.

The T/S change requests for the boric acid transfer pumps and the auxiliary feedwater pumps, located on pages 3/4 1-13, 3/4 1-14, 3/4 7-5 and 3/4 7-6 for Unit 1 and pages 3/4 7-5 and 7-6 for Unit 2 have been withdrawn. These changes will be resubmitted at a later date pending further evaluation.

In addition, we have withdrawn our request to use the test frequency specified in ASME Boiler and Pressure Vessel Code Section XI for pump testing requirements on Unit 1 pages 3/4 1-11, 3/4 1-12, 3/4 5-5, 3/4 6-10, 3/4 7-15 and 3/4 7-16 and will retain the 31-day surveillance frequency of the current T/Ss. The attached T/S pages incorporate these changes.

Revised Pages for Unit No. 1Current Page No.Section Revised

3/4 0-2	Footnote deleted
3/4 1-11	4.1.2.3.1
3/4 1-12	4.1.2.4
3/4 4-7	4.4.5.0; 4.4.5.2
3/4 4-8	4.4.5.6.3, 4.4.5.2.c
3/4 4-9	4.4.5.3.b
3/4 4-10	4.4.5.a.5
3/4 4-11	No change, added for continuity
3/4 4-12	Table 4.4-1
3/4 4-33	3.4.10.1, 4.4.10.1
3/4 4-34	Deleted
3/4 4-35 through 4-42 (Table 4.4-6)	Deleted
3/4 4-43 through 4-48	Renumbered Pages 4-34 through 4-40
3/4 5-4 through 5-6	4.5.2 - subsections rearranged

Revised Pages for Unit No. 1 (cont.)

<u>Current Page No.</u>	<u>Section Revised</u>
3/4 5-6a	Deleted
3/4 6-10	4.6.2.1
3/4 6-11	Intentionally left blank
3/4 7-15	4.7.3.1
3/4 7-16	Intentionally left blank
3/4 7-17	4.7.4.1
3/4 7-18	Intentionally left blank
B 3/4 0-5	4.0.5 - this is a new page
B 3/4 4-12	3/4.4.10
B 3/4 4-13	Deleted

Revised Pages for Unit No. 2

Surveillance requirement No. 4.1.2.3.1 for the centrifugal charging pumps has been changed from 2405 psig to 2390 psig, to reflect the difference in volume control tank pressure in Modes 5 and 6 from that in Modes 1 to 4.

<u>Current Page No.</u>	<u>Section Revised</u>
3/4 1-11	4.1.2.3.1