

POWER DISTRIBUTION LIMITS

QUADRANT POWER TILT RATIO

LIMITING CONDITION FOR OPERATION

---

3.2.4 THE QUADRANT POWER TILT RATIO shall not exceed 1.02.

APPLICABILITY: MODE 1 ABOVE 50% OF RATED THERMAL POWER\*

ACTION:

- a. With the QUADRANT POWER TILT RATIO determined to exceed 1.02 but  $\leq 1.09$ :
  1. Within 2 hours:
    - a) Either reduce the QUADRANT POWER TILT RATIO to within its limit, or
    - b) Reduce THERMAL POWER at least 3% from RATED THERMAL POWER for each 1% of indicated QUADRANT POWER TILT RATIO in excess of 1.0 and similarly reduce the Power Range Neutron Flux-High Trip Setpoints within the next 4 hours.
  2. Verify that the QUADRANT POWER TILT RATIO is within its limit within 24 hours after exceeding the limit or reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within the next 2 hours and reduce the Power Range Neutron Flux-High Trip setpoints to  $\leq 55\%$  of RATED THERMAL POWER within the next 4 hours.
  3. Identify and correct the cause of the out of limit condition prior to increasing THERMAL POWER; subsequent POWER OPERATION above 50% of RATED THERMAL POWER may proceed provided that the QUADRANT POWER TILT RATIO is verified within its limit at least once per hour for 12 hours or until verified acceptable at 95% or greater RATED THERMAL POWER.
- b. With the QUADRANT POWER TILT RATIO determined to exceed 1.09 due to misalignment of either a shutdown or control rod:
  1. Reduce THERMAL POWER at least 3% from RATED THERMAL POWER for each 1% of indicated QUADRANT POWER TILT RATIO in excess of 1.0, within 30 minutes.
  2. Verify that the QUADRANT POWER TILT RATIO is within its limit within 2 hours after exceeding the limit or

\*See Special Test Exception 3.10.2

D. C. COOK - UNIT 1

3/4 2-14

Amendment No.

8612110138 861205  
PDR ADDCK 05000315  
PDR

## POWER DISTRIBUTION

### LIMITING CONDITION FOR OPERATION (Continued)

---

reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within the next 2 hours and reduce the Power Range Neutron Flux-High Trip Setpoints to  $\leq 55\%$  of RATED THERMAL POWER within the next 4 hours.

3. Identify and correct the cause of the out of limit condition prior to increasing THERMAL POWER; subsequent POWER OPERATION above 50% of RATED THERMAL POWER may proceed providing that the QUADRANT POWER TILT RATIO is verified within its limit at least once per hour for 12 hours or until verified acceptable at 95% of greater RATED THERMAL POWER.
- c. With the QUADRANT POWER TILT RATIO determined to exceed 1.09 due to causes other than the misalignment of either a shutdown or control rod:
  1. Reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within 2 hours and reduce the Power Range Neutron Flux-High Trip Setpoints to  $\leq 55\%$  of RATED THERMAL POWER within the next 4 hours.
  2. Identify and correct the cause of the out of limit condition prior to increasing THERMAL POWER; subsequent POWER OPERATION above 50% of RATED THERMAL POWER may proceed provided that the QUADRANT POWER TILT RATIO is verified within its limit at least once per hour for 12 hours or until verified at 95% or greater RATED THERMAL POWER.

### SURVEILLANCE REQUIREMENTS

---

4.2.4 The QUADRANT POWER TILT RATIO shall be determined to be within the limit above 50% of RATED THERMAL POWER by:

- a. Calculating the ratio at least once per 7 days when the alarm is OPERABLE.
- b. Calculating the ratio at least once per 12 hours during steady state operation when the alarm is inoperable.
- c. Using the movable incore detectors to determine the QUADRANT POWER TILT RATIO at least once per 12 hours when one Power Range Channel is inoperable and THERMAL POWER is  $> 75$  percent of RATED THERMAL POWER.