

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8701290188 DOC. DATE: 87/01/22 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME AUTHOR AFFILIATION  
 ALEXICH, M. P. Indiana & Michigan Electric Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application to State of MI Dept of Natural Resources for mod of NPDES Permit MI 0005827 to allow discharge of make up plant prefilter backwash water into Lake Michigan.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 40  
 TITLE: OR Submittal: General Distribution

## NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-A EB	1 1	PWR-A EICSB	2 2
PWR-A FOB	1 1	PWR-A PD4 LA	1 0
PWR-A PD4 PD 01	5 5	WIGGINGTON, D	1 1
PWR-A PSB	1 1	PWR-A RSB	1 1
INTERNAL: ADM/LFMB	1 0	ELD/HDS3	1 0
NRR/DNET/TSCB	1 1	NRR/ORAS	1 0
REG FILE 04	1 1		
EXTERNAL: EG&G BRUSKE, S	1 1	LPDR 03	2 2
NRC PDR 02	1 1	NSIC 05	1 1

ADD: NRR/PRA/ADTS

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 20

REPORT OF THE COMMISSIONER OF THE GENERAL LAND OFFICE  
IN RESPONSE TO A RESOLUTION OF THE HOUSE OF REPRESENTATIVES  
PASSED MAY 1, 1890, RELATIVE TO THE LANDS BELONGING TO THE  
UNITED STATES IN THE STATE OF TEXAS

THE LANDS BELONGING TO THE UNITED STATES IN THE STATE OF TEXAS  
AS OF JANUARY 1, 1890, AND THE LANDS BELONGING TO THE  
UNITED STATES IN THE STATE OF TEXAS AS OF JANUARY 1, 1891

UNITED STATES DEPARTMENT OF AGRICULTURE  
WASHINGTON, D. C.

STATE	SECTION	ACRES	VALUE	REMARKS
TEXAS	1	100	100	100
TEXAS	2	100	100	100
TEXAS	3	100	100	100
TEXAS	4	100	100	100
TEXAS	5	100	100	100
TEXAS	6	100	100	100
TEXAS	7	100	100	100
TEXAS	8	100	100	100
TEXAS	9	100	100	100
TEXAS	10	100	100	100
TEXAS	11	100	100	100
TEXAS	12	100	100	100
TEXAS	13	100	100	100
TEXAS	14	100	100	100
TEXAS	15	100	100	100
TEXAS	16	100	100	100
TEXAS	17	100	100	100
TEXAS	18	100	100	100
TEXAS	19	100	100	100
TEXAS	20	100	100	100
TEXAS	21	100	100	100
TEXAS	22	100	100	100
TEXAS	23	100	100	100
TEXAS	24	100	100	100
TEXAS	25	100	100	100
TEXAS	26	100	100	100
TEXAS	27	100	100	100
TEXAS	28	100	100	100
TEXAS	29	100	100	100
TEXAS	30	100	100	100
TEXAS	31	100	100	100
TEXAS	32	100	100	100
TEXAS	33	100	100	100
TEXAS	34	100	100	100
TEXAS	35	100	100	100
TEXAS	36	100	100	100
TEXAS	37	100	100	100
TEXAS	38	100	100	100
TEXAS	39	100	100	100
TEXAS	40	100	100	100
TEXAS	41	100	100	100
TEXAS	42	100	100	100
TEXAS	43	100	100	100
TEXAS	44	100	100	100
TEXAS	45	100	100	100
TEXAS	46	100	100	100
TEXAS	47	100	100	100
TEXAS	48	100	100	100
TEXAS	49	100	100	100
TEXAS	50	100	100	100
TEXAS	51	100	100	100
TEXAS	52	100	100	100
TEXAS	53	100	100	100
TEXAS	54	100	100	100
TEXAS	55	100	100	100
TEXAS	56	100	100	100
TEXAS	57	100	100	100
TEXAS	58	100	100	100
TEXAS	59	100	100	100
TEXAS	60	100	100	100
TEXAS	61	100	100	100
TEXAS	62	100	100	100
TEXAS	63	100	100	100
TEXAS	64	100	100	100
TEXAS	65	100	100	100
TEXAS	66	100	100	100
TEXAS	67	100	100	100
TEXAS	68	100	100	100
TEXAS	69	100	100	100
TEXAS	70	100	100	100
TEXAS	71	100	100	100
TEXAS	72	100	100	100
TEXAS	73	100	100	100
TEXAS	74	100	100	100
TEXAS	75	100	100	100
TEXAS	76	100	100	100
TEXAS	77	100	100	100
TEXAS	78	100	100	100
TEXAS	79	100	100	100
TEXAS	80	100	100	100
TEXAS	81	100	100	100
TEXAS	82	100	100	100
TEXAS	83	100	100	100
TEXAS	84	100	100	100
TEXAS	85	100	100	100
TEXAS	86	100	100	100
TEXAS	87	100	100	100
TEXAS	88	100	100	100
TEXAS	89	100	100	100
TEXAS	90	100	100	100
TEXAS	91	100	100	100
TEXAS	92	100	100	100
TEXAS	93	100	100	100
TEXAS	94	100	100	100
TEXAS	95	100	100	100
TEXAS	96	100	100	100
TEXAS	97	100	100	100
TEXAS	98	100	100	100
TEXAS	99	100	100	100
TEXAS	100	100	100	100

# INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631  
COLUMBUS, OHIO 43216

January 22, 1987

AEP:NRC:0170C  
10 CFR 50.36 (b)

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
NATIONAL POLLUTANT DISCHARGE ELIMINATION  
SYSTEM (NPDES) PERMIT

Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Dear Sirs:

In accordance with Section 3.2 of Appendix B (Environmental Protection Plan) of the Donald C. Cook Nuclear Plant Unit Nos. 1 and 2 Facility Operating License, attached is a copy of an application to the State of Michigan Department of Natural Resources for modification of the D. C. Cook NPDES Permit No. MI 0005827. This application is for your information only and has been submitted to the State of Michigan for approval of a facility change which would allow discharge of make-up plant prefilter backwash water to Lake Michigan.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



M. D. Alexich  
Vice President

RBK  
1/22/87

cm

Attachment

cc: John E. Dolan  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Bruchmann  
G. Charnoff  
NRC Resident Inspector - Bridgman  
J. G. Keppler - Region III

8701290188 870122  
PDR ADCK 05000315  
PDR

ADD. NRR/PRA/ADTS  
1/1

ATTACHMENT TO AEP:NRG:0170C


NPDES PERMIT APPLICATION

LETTER FROM JACK A. DRUCKEMILLER (I&MECo)

TO PAUL D. ZUGGER (MICHIGAN DEPARTMENT OF NATURAL RESOURCES),

DATED DECEMBER 23, 1986





**INDIANA & MICHIGAN ELECTRIC COMPANY**

ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801

Telephone (219) 425-2111

December 23, 1986

Paul D. Zugger, Executive Secretary  
Water Resources Commission  
Department of Natural Resources  
P. O. Box 30028  
Lansing, Michigan 48909

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant  
NPDES Permit No. MI0005827

Enclosed is a revised Industrial and Commercial Wastewater Discharge Application for the Donald C. Cook Nuclear Plant. This application is submitted for approval of a facility change.

The facility change involves rerouting of Makeup Plant Prefilter backwash water to Lake Michigan via outfalls 001 or 002 (Unit 1 and Unit 2 discharges). The filter backwash water is currently discharged to the Plant's Turbine Room Sump, which subsequently discharges to an onsite Absorption Pond. The ability to discharge this effluent to Lake Michigan would aid us in performing repairs to the sump and would allow us to reduce the volume of groundwater discharges. Screening data for this waste stream is provided in the enclosed application.

Note that the line diagram flowsheet for Section 1, Item 6 is as proposed, reflecting the planned rerouting of the filter backwash water.

Your timely consideration of the request for facility modification is appreciated since repairs of the Turbine Room Sump are scheduled for early 1987. Please call me if you require information or have any questions regarding the information provided. We would be happy to meet with the people responsible for drafting the permit modification.

Very truly yours,

Jack A. Druckemiller  
Manager of Environmental Affairs

JAD/df  
Enclosure

c: W. G. Smith, Jr.

## SECTION I

EPA I.D. NUMBER

MI10198161476211

PERMIT  
NUMBER

MI10100518127

SEE INSTRUCTIONS  
ON REVERSE SIDE

APPLICATION FOR DISCHARGE PERMIT IS:

MODIFICATION

EXISTING

NEW

INCREASED USE

REISSUANCE

☒☐☐☐☐ITEM  
1PHYSICAL  
LOCATION  
ADDRESS  
AND  
INFORMATION

A. PARENT COMPANY/DEPT./OFFICE		INDIANA & MICHIGAN ELECTRIC	
B. DIV./BUREAU		IN : A	
C. PLANT OR FACILITY		D. TYPE OF FACILITY	
D. IC: IC1010K1PILANT		E. STANDARD INDUSTRIAL CLASSIFICATION (REFER TO TABLE II)	
F. STREET NUMBER		G. STREET NAME	
NIA		REDI ARROW HIGHWAY	
H. CITY NAME		I. ZIP CODE	
BRITIDGMANI		MI 4911016J	
J. TOWNSHIP		K. COUNTY (REFER TO TABLE I)	
LIAKIE		CO. NAME BERRIEN CO. NUMBER 111	
L. NAME OF AUTHORIZED CONTACT PERSON		M. TITLE	
LIAICKIA DIRUCKE MITTLEER		MGR ENVI AFFAIRS	
N. TELEPHONE NUMBER		O. ADDRESS (IF DIFFERENT FROM ABOVE)	
2119 4215 211118		P101 B10X 1610	
P. CITY NAME		Q. STATE	R. ZIP CODE
F10RTI WAYNE		IN	4618101J
S. TYPE OF TREATMENT FACILITY (REFER TO TABLE II)		T. PROGRAM FOR EFFECTIVE RESIDUALS MANAGEMENT DATE SUBMITTED	
TIL 151A 41G 51P		<input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N.A. DATE IMPLEMENTED	
U. BACK-UP POWER SOURCE		V. POLLUTION INCIDENT PREVENTION PLAN DATE SUBMITTED	
<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N.A.		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N.A. DATE IMPLEMENTED 6/12/80	
X. TYPE OF DISCHARGE		Y. DO YOU HAVE A CERTIFIED OPERATOR?	
GROUNDWATER <input type="checkbox"/>		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
BOTH <input checked="" type="checkbox"/> SURFACE WATER <input type="checkbox"/>		OPERATOR'S NAME D. Fitzgerald-Stuart# 131019 710 4181012	
		FACILITY # 11110101514 CERTIFICATION # 11101012181613J	

ITEM  
2MAILING  
ADDRESS  
OF  
APPLICANT

A. NAME		B. NAME	
RICHARD C MENGINE		INDIANA & MICHIGAN ELECTRIC CO	
C. STREET ADDRESS OR POST OFFICE BOX			
P101 B10X 1610			
D. CITY NAME		E. STATE	F. ZIP CODE
F10RTI WAYNE		IN	46801

## REQUIRED SIGNATURE

I, the applicant, certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

SIGNATURE OF APPLICANT

SIGNATURE: R.C. Menge DATE: 12/23/86

NAME: R. C. Menge TITLE: Vice President

SIGNATURE OF LOCAL GOVERNMENTAL REPRESENTATIVE (SEE NOTE ON REVERSE SIDE)

SIGNATURE: DATE:

NAME: TITLE:

INSTRUCTIONS FOR COMPLETING SECTION I  
ITEMS 1 AND 2

This form requires information about the facility address, discharge location, plant controls, type of disposal facility and name, address, and signature of the applicant and local governmental representative.

Enter Environmental Protection Agency I.D. Number if available.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

In the box titled "Request for Discharge Is" check one of the five categories (modification, existing unpermitted, new, increased use, or reissuance) which your permit application falls into (see page 14 for definitions).

ITEM 1

PHYSICAL LOCATION ADDRESS AND INFORMATION

A.-C. Enter the naming information in accordance with the following:

- For industrial facilities, provide the parent company name (A.), the division name (B.), and the plant name (C.).
- For federal and state facilities provide the department name (A.), the division or the bureau name (B.), and the facility name (C.).
- For commercial facilities provide the owner's name, doing business as (d.b.a.) (A.) and the facility name (C.).

D. Enter type of facility. Examples of this are: foundry; high school; automatic car wash; dry cleaners; self-serve laundromat.

E. Refer to Table III (page 5) for the list of Standard Industrial Classification Code (SIC). Enter the code number that best describes the major product or service produced.

F.-I. Enter the physical location of the facility. DO NOT use post office box number.

J.-K. Enter the township and county in which this facility is located. The county code number can be found in Table I (page 3).

L.-R. Enter the name, title, address and telephone number of the facility's authorized contact person. This person should be thoroughly familiar with the facts reported on these forms in the event that contact regarding the permit application must be made.

S. Refer to Table II (page 4) for the list of Treatment Facility Types, enter up to five methods used by the facility to treat the wastewater.

T. Indicate whether this facility has a "Residuals Management Plan". If so, enter date plan was submitted and the date the plan was or is to be implemented. Such a plan may be needed as deemed appropriate by the proper Division staff.

U. Indicate whether the waste treatment facilities have a back-up source of power or whether emergency procedures have been developed in case of a power outage to the waste treatment facility. If the waste treatment facility is not dependent on a source of power, check the "NA" box.

V. Indicate whether this facility has submitted a Pollution Incident Prevention Plan as required under the Michigan Water Resources Commission Part 5 Rules for the "Spillage of Oil and Polluting Materials".

W. If facility has sanitary wastewater (water used for domestic purposes; e.g., toilets, sinks, showers), enter the number of people using this facility.

X. Check the type of discharge(s) from this facility.

Y. Indicate whether your waste treatment or control facilities are under the supervision of a certified operator. If yes, please provide the person's name, social security number, and certificate number plus the company's facility number.

ITEM 2

MAILING ADDRESS FOR ALL CORRESPONDENCE

A. Provide the name of the applicant. For the purposes of this application the applicant is defined as the person signing below in accordance with the directions provided on page 14. Correspondence regarding this application and future permit matters will be sent to the applicant.

B. Provide the name of the facility, company, or organization which the applicant in "A." above uses for receipt of mail.

C.-D. Provide the applicant's address to be used for future correspondence.

SIGNATURE OF LOCAL GOVERNMENTAL REPRESENTATIVE

NOTE: If sanitary sewage is to be discharged from housing developments, apartment buildings, shopping centers, or other commercial developments, into a system other than an approved municipal sanitary waste collection system, this application shall be co-signed by an authorized municipal official or township officer.

It is the rule of the Commission that applications involving the disposal of sewage of human origin from any entity other than local government should include the local government as a co-signer of the statement, and that all proceedings and hearings against said entity will include the local unit of government as a party by appropriate notice, and all permits issued as a result of such hearings and proceedings will be filed jointly against the said unit and entity (Water Resources Commission Part 3 Rules R 325.1038(3) and the Michigan Water Resources Commission Act 245 P.A. of 1929 as amended Section 6(b)). This co-signature requirement is only applicable to sanitary sewage discharges and is not for any nonsanitary waste streams from this facility.



## SECTION 1

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
3SOURCE  
OF  
WATER  
SUPPLY

A. MUNICIPAL

NAME

QUANTITY (MAX.)

GALLONS/DAY

B. SURFACE WATER INTAKE

NAME OF WATERWAY

QUANTITY (MAX.)

GALLONS/DAY

C. PRIVATE WELL

QUANTITY (MAX.)

GALLONS/DAY

D. OTHER

SPECIFY

QUANTITY (MAX.)

GALLONS/DAY

ITEM  
4FACILITY  
WATER  
USAGEA. PROCESS WATER (INCLUDING CONTACT  
COOLING WATER)

QUANTITY (MAX.)

GALLONS/DAY

B. NONCONTACT COOLING WATER

QUANTITY (MAX.)

GALLONS/DAY

C. SANITARY WATER

QUANTITY (MAX.)

GALLONS/DAY

D. OTHER

SPECIFY

QUANTITY (MAX.)

GALLONS/DAY

ITEM  
5CRITICAL  
MATERIALS  
&  
PRIORITY  
POLLUTANTS  
USEDSTORED  
PRODUCEDREFER  
TO  
TABLES  
IV & V

## UNITS CODE

- 1 POUNDS  
2 GALLONS  
3 CUBIC  
YARDS  
4 TONS

MATERIAL  
1

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
2

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
3

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
4

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
5

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
6

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

MATERIAL  
7

NAME OF SUBSTANCE

PARAMETER NUMBER

QUANTITY

UNITS

/YEAR

No change from information previously provided.

INSTRUCTIONS FOR COMPLETING SECTION I  
ITEMS 3, 4, AND 5

This form requires information about the water supply to the facility, the facility's water usage, and critical materials and priority pollutants used, stored, or produced at this facility.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

ITEM 3

SOURCE OF WATER SUPPLY

List all water supplies used. The volume may be estimated from water supply meter readings or from billing statements from a water supply utility. If water is not metered, estimate from pump capacity. Where a name is required, enter name of water supply; e.g., Mud Lake, Huron River, or the City of Millpond.

ITEM 4

FACILITY WATER USAGE

List amounts of water to be used for various purposes as:

Process Water - see Glossary for definition (page 48).

Noncontact Cooling Water - see Glossary for definition (page 48).

Sanitary Water - Water used for domestic purposes; e.g., toilets, sinks, showers.

If water is first used for one purpose and the same water is subsequently used for one or more other purposes, indicate the volume per day of the last designated use before treatment and/or discharge. For example, if water is initially used as noncontact cooling water and then as process water, the quantity of water given should be indicated as process water.

The total of Item 4 should equal the total of Item 3. Any difference in these totals should be explained in an attached sheet of this application.

ITEM 5

CRITICAL MATERIALS AND PRIORITY POLLUTANTS USED, STORED, PRODUCED

List all chemical substances which are in Michigan's Critical Materials Register Table IV (page 6) and/or U.S. EPA's Priority Pollutant List Table V (page 7) that are currently used, stored, or produced by this facility.

SEE INSTRUCTIONS  
ON REVERSE SIDE

# ITEM 6

DESCRIPTION

AND

DIAGRAM

- A. PROVIDE A BRIEF DESCRIPTION AND LINE DIAGRAM SHOWING THE WATER FLOW THROUGH YOUR FACILITY FROM INTAKE TO DISCHARGE. SHOW ALL OPERATIONS CONTRIBUTING WASTEWATER, INCLUDING PROCESS AND PRODUCTION AREAS, SANITARY FLOWS, COOLING WATER, AND STORMWATER RUNOFF. YOU MAY GROUP SIMILAR OPERATIONS INTO A SINGLE UNIT. THE WATER BALANCE SHOULD SHOW AVERAGE FLOWS. SHOW ALL SIGNIFICANT LOSSES OF WATER TO PRODUCTS, ATMOSPHERE, AND DISCHARGE. YOU SHOULD USE ACTUAL MEASUREMENTS WHENEVER AVAILABLE; OTHERWISE USE YOUR BEST ESTIMATE.

See line diagram on following page.

# INSTRUCTIONS FOR COMPLETING SECTION I

## ITEM 6

This form requires information about the water flow through your facility from intake to discharge.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXISTING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.


## ITEM 6

### DESCRIPTION AND LINE DIAGRAM OF FACILITY'S PROCESSES AND TREATMENT SCHEME


A. Briefly describe the route taken by water in your facility from the intake to the discharge and also provide a line drawing.


#### Example Description and Diagram

Narrative: The rinse water from the various plating operations is collected in one of the two 35,000 gallon tanks. Calcium chloride and alum are added to assist in fluoride removal and aid in coagulation. The water is adjusted to a pH of about 5.5 using dilute sulfuric acid. The pH is then raised to a pH of about 10.3 with lime to precipitate the metals as hydroxide. Polymer is added to flocculate the metal hydroxides. The waste stream flows through a clarifier, the metal hydroxide settles to the bottom as "sludge". The treated water flows from the clarifier to a manhole where it commingles with contact cooling water from the strip line. This commingled water is discharged to the Buck River. The sludge from the clarifier goes to a vacuum filter where it is dewatered. The sludge is later taken to a landfill.



John Doe, Inc., Deertown, manufactures sleeve bearings for automotive and truck engines. Production is divided into 3 phases. Metal powder is produced in the first phase. This is accompanied by melting copper, tin and lead into ingots in an electric furnace and applying a jet of water to quench and solidify the molting metal into powder form. The second phase consists of adhering the fine metal powder to a coil of steel by passing the two slowly through furnaces. Water used to cool the strip constitutes the contact cooling water. Bearings are then formed and machined from the coated steel. In the third phase, most bearings receive a nickel strike and lead, tin copper electroplate. The remaining bearings are aluminum or babbitt and receive a tin or lead plate. Rinse water before and after the various plating operations constitutes the process water.





Section I, Item 6, cont'd.  
Outfall Descriptions

Outfall 00F - Pre-Filter Backwash

Make-up water of ultra-high purity is required for the steam generators. The first step in treating intake lake water is solids removal using multi-media filters. The filters are called pre-filters since they are the initial step in the treatment process.

Alum (aluminum sulfate) is injected into the water supply upstream of the pre-filters to act as a coagulant on the filter media. When the pre-filters are saturated with solids removed from the lake water, the pre-filters are backwashed with additional lake water, and the solids are flushed to the turbine room sump then discharged to an on-site absorption pond.

The proposed plant modification would reroute the pre-filter backwash to Lake Michigan. There would be a small net increase in the amount of solids returned to Lake Michigan as a result of the alum added during treatment. The design maximum amount of alum which could be used is 624 lb alum per day which would cause a net increase of 0.05 ppm solids when discharged through Outfall 001 or 0.04 ppm solids when discharged through Outfall 002. The attached screening data show that the typical pre-filter backwash contains only 1.7  $\mu\text{g/l}$  aluminum and 25  $\mu\text{g/l}$  sulfate.

SECTION I

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDE

ITEM  
7

LOCATION

MAP

- A. PROVIDE A MAP OF THE TREATMENT FACILITY LOCATION, SHOWING THE LOCATION OF THE DISCHARGE POINT(S) AND OTHER INFORMATION REQUESTED ON REVERSE SIDE OF PAGE.

See topo map on following page.

INSTRUCTIONS FOR COMPLETING SECTION I

ITEM 7

This form requires a location map of the treatment facility showing discharge point(s).

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

ITEM 7


LOCATION MAP

- A. Provide a detailed location map of the treatment facility, showing the location of the discharge point(s) for all surface water and groundwater discharges, and all known supply and drinking water wells of adjacent properties to the facility. For both surface and groundwater discharge applicants, indicate the location and identification number of any groundwater monitoring wells relative to the facility which are currently being used by the applicant to monitor the groundwater. Also, include the receiving stream, lake, or storm sewer and the streets and roads in the area.



Note:  
 00A Unit 1 Steam Generator Blowdown  
 00B Unit 2 Steam Generator Blowdown  
 00C Air Heating Boiler Blowdown  
 Are all discharged thru 001 or 002  
 00F Makeup Plant Prefitter Backwash  
 discharged thru 001 or 002

BRIDGMAN, MICH.  
 NE 1 THREE OAKS 15' QUADRANGLE  
 N4152.5-W8630/7.5  
 1970  
 AMS 3667 I NF-SERIES V862



Drinking Water Wells at Residences

Plant Drinking Water Wells

S01 STORMWATER DISCHARGE NORTH

- 001 UNIT 1 NONCONTACT COOLING
- 003 UNITS 1 & 2 DEICING
- 002 UNIT 2 NONCONTACT COOLING
- 00D ONSITE ABSORPTION POND
- 00E SEWAGE ABSORPTION FIELDS

S02 STORMWATER DISCHARGE SOUTH

Groundwater Monitoring Wells

Drinking Water Wells at Residences

I C H I G A N  
 ELEVATION 380



## SECTION 1

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
8CONCENTRATED  
ANIMAL  
FEEDING  
OPERATION

A. DO YOU OPERATE A CONCENTRATED ANIMAL FEEDING FACILITY? (IF NO CONTINUE TO ITEM 10)	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
B. NUMBER OF ACRES USED FOR CONFINEMENT FEEDING?	_____ ACRES
C. IF THERE IS OPEN CONFINEMENT, HAS A RUNOFF DIVERSION AND CONTROL SYSTEM BEEN CONSTRUCTED? (IF NO, CONTINUE TO ITEM 9)	<input type="checkbox"/> YES <input type="checkbox"/> NO
D. WHAT IS THE DESIGN BASIS FOR THE CONTROL SYSTEM? CHECK ONE OF THE FOLLOWING AND ENTER NUMBER OF INCHES OF RAIN?	<input type="checkbox"/> 10 YEAR, 24 HOUR STORM _____ INCHES <input type="checkbox"/> 25 YEAR, 24 HOUR STORM _____ INCHES <input type="checkbox"/> OTHER (SPECIFY) _____ INCHES
TYPE _____	
E. WHAT IS THE NUMBER OF ACRES OF CONTRIBUTING DRAINAGE?	_____ ACRES
F. WHAT IS THE DESIGN SAFETY FACTOR FOR THIS CONTROL SYSTEM?	_____

ITEM  
9TYPE  
&  
NUMBER  
OF  
ANIMALS  
IN  
OPEN  
AND  
HOUSED  
CONFINEMENT

TYPE 1	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 2	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 3	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 4	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 5	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 6	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 7	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____
TYPE 8	A. LIST TYPE OF ANIMAL.	_____
	B. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN OPEN CONFINEMENT.	_____
	C. GIVE THE NUMBER OF THIS TYPE OF ANIMAL IN HOUSED CONFINEMENT.	_____

INSTRUCTIONS FOR COMPLETING SECTION I  
ITEMS 8 AND 9

This form requires information about the design, size, and type and numbers of animals in a concentrated animal feedlot.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

GENERAL INFORMATION

Not all animal feeding operations are required to obtain NPDES permits. Exclusions are based on size and occurrence of discharge. In particular, for animal feeding operations, the size cutoffs depend on whether or not pollutants are discharged through a manure device or by direct contact with the facility or animals. A facility for laying hens or broilers is not required to have a permit unless it has a liquid manure handling system or continuous overflow watering. Also, facilities which discharge only in the case of a 25 year, 24 hour storm event are not required to have a permit.

ITEM 9-B

Give only the area used for the animal confinement or feeding facility. Do not include any area used for growing or operating feed.

ITEM 9-C

Check "yes" if any system for collection of runoff has been constructed. Supply the information under D, E, and F to the best of your knowledge.

ITEM 10-B AND C

Give the maximum number of each type of animal in open confinement or housed under roof (either partially or totally) which are held at your facility for a total of 45 days or more in any 12 month period.

Use the following categories for type of animals:

- |  |               |
|--|---------------|
| - Slaughter Cattle                     | - Lambs       |
| - Feeder Cattle                        | - Turkeys     |
| - Mature Dairy Cattle (milked or dry)  | - Laying Hens |
| - Swine (each weighing over 55 pounds) | - Broilers    |
| - Horses                               | - Ducks       |
| - Sheep                                |               |

A permit is not required unless the facility has a liquid manure handling system or continuous overflow watering.

ANIMAL FEEDING OPERATION means a lot or facility (other than an aquatic animal production facility) where the following conditions are met:

- (A) Animals (other than aquatic animals) have been, are, or will be stabled or confined and fed or maintained for a total of 45 days or more in any 12 month period; and
- (B) Crops, vegetation, forage growth, or post-harvest residues are not sustained in the normal growing season over any portion of the lot or facility.

Two or more animal feeding operations under common ownership are a single animal feeding operation if they adjoin each other or if they use a common area or system for the disposal of wastes.

ANIMAL UNIT means a unit of measurement for any animal feeding operation calculated by adding the following numbers: The number of slaughter and feeder cattle multiplied by 1.0; plus the number of mature dairy cattle multiplied by 1.4; plus the number of swine weighing over 25 kilograms (approximately 55 pounds) multiplied by 0.4; plus the number of sheep multiplied by 0.1; plus the number of horses multiplied by 2.0.

CONCENTRATED ANIMAL FEEDING OPERATION means an animal feeding operation which meets the criteria set forth in either (A) or (B) below or which the Director designates as such on a case-by-case basis.

A. More than the numbers of animals specified in any of the following categories are confined (REGARDLESS OF WHETHER A SURFACE WATER DISCHARGE EXISTS):

1. 1,000 slaughter or feeder cattle.
2. 700 mature dairy cattle (whether milked or dry cows).
3. 2,500 swine each weighing over 25 kilograms (approximately 55 pounds).
4. 500 horses.
5. 10,000 sheep or lambs.
6. 55,000 turkeys.
7. 100,000 laying hens or broilers (if the facility has a continuous overflow watering).
8. 30,000 laying hens or broilers (if the facility has a liquid manure handling system).
9. 5,000 ducks.
10. 1,000 animal units.

OR

B. More than the following numbers and types of animals are confined (WITH SURFACE WATER DISCHARGE AS DESCRIBED BELOW):

1. 300 slaughter or feeder cattle.

## SECTION I

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
10AQUATIC  
ANIMAL  
PRODUCTION  
FACILITYA. DO YOU OPERATE AN AQUATIC ANIMAL PRODUCTION FACILITY?  
(IF NO, CONTINUE TO ITEM 12)☐ YES☒ NOB. INDICATE THE TOTAL NUMBER OF PONDS, RACEWAYS AND SIMILAR  
STRUCTURES AT YOUR FACILITY.

\_\_\_\_\_. PONDS

\_\_\_\_\_. RACEWAYS

\_\_\_\_\_. OTHER

C. INDICATE IN WHICH CALENDAR MONTH MAXIMUM FEEDING OCCURS.

\_\_\_\_\_

D. ENTER THE TOTAL NUMBER OF POUNDS OF FOOD FED DURING THIS  
MONTH?

\_\_\_\_\_ POUNDS

ITEM  
11SPECIES  
OF  
AQUATIC  
ANIMALS  
PRODUCED  
AT THIS  
FACILITYSPECIES 1  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ COLD

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

SPECIES 2  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ COLD

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

SPECIES 3  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ COLD

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

SPECIES 4  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ COLD

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

SPECIES 5  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ COLD

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

SPECIES 6  
A. IS THIS SPECIE A WARM OR COLD WATER SPECIE?☐ WARM☐ POUNDS

B. GIVE THE NAME OF THIS SPECIE.

\_\_\_\_\_

C. ENTER THE TOTAL HARVESTABLE WEIGHT OF THIS SPECIE  
PRODUCED BY THIS FACILITY PER YEAR IN POUNDS.

\_\_\_\_\_ POUNDS

D. ENTER THE MAXIMUM WEIGHT PRESENT FOR THIS SPECIE WHICH  
WOULD REPRESENT YOUR NORMAL OPERATION.

\_\_\_\_\_ POUNDS

INSTRUCTIONS FOR COMPLETING SECTION I  
ITEMS 10 AND 11

This form requires information about the design, size, and type and numbers of animals in an aquatic animal production facility.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

GENERAL INFORMATION

Not all fish farms are required to obtain NPDES permits. Exclusions are based on size and occurrence of discharge. For aquatic animal production facilities, the size cutoffs are based on whether the species are warm water or cold water, on the production weight per year in harvestable pounds, and on the amount of feeding in pounds of food (for cold water species). Also, facilities which discharge less than 30 days per year, or only during periods of excess runoff (for warm water fish) are not required to have a permit.

CONCENTRATED AQUATIC ANIMAL PRODUCTION FACILITY means a hatchery, fish farm, or other facility which contains, grows or holds aquatic animals in either of the following categories, or which the Director designates as such on a case-by-case basis.

- A. Cold water fish species or other cold water aquatic animals including, but not limited to, the Salmonidae family of fish (e.g., trout and salmon) in ponds, raceways or other similar structures which discharge at least 30 days per year but does not include:
1. Facilities which produce less than 9,090 harvest weight kilograms (approximately 20,000 pounds) of aquatic animals per year.
  2. Facilities which feed less than 2,272 kilograms (approximately 5,000 pounds) of food during the calendar month of maximum feeding.
- B. Warm water fish species or other warm water aquatic animals including, but not limited to, the Ameluridae, Cetrachidae, and Cyprinidae families of fish (e.g., respectively, catfish, sunfish, and minnows) in ponds, raceways, or other similar structures which discharge at least 30 days per year, but does not include:
1. Closed ponds which discharge only during periods of excess runoff.
  2. Facilities which produce less than 45,454 harvest weight kilograms (approximately 100,000 pounds) of aquatic animals per year.

ITEM 11-B

Give the total number of discrete ponds or raceways in your facility. Under "other" give a descriptive name of any structure which is not a pond or a raceway but which results in discharge to waters of the United States.

ITEM 11-D

The value given for maximum monthly pounds of food should be representative of your normal operation.

ITEM 12-B

The name of fish species should be proper, common, or scientific names.

ITEM 12-C AND D

The values given for total weight produced by your facility per year and the maximum weight present at any one time should be representative of your normal operation.

NOTE: The permittee shall continue with Section II and address Items 1, 2, 4, and 5 on pages 31, 33, and 35.

SECTION I

PERMIT  
NUMBER

MI0005827

LIST NAME AND MAILING ADDRESS OF ALL PROPERTY OWNERS ADJACENT TO THE TREATMENT FACILITY AND OR DISCHARGE/DISPOSAL AREA.

ITEM  
12

MAILING

LIST

OF

ADJACENT

PROPERTY

OWNERS

No change from information previously provided.





## SECTION II

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
1DISCHARGE  
LOCATION

SCHEDULE

FLOW  
RATEWASTEWATER  
TYPE CODE1 CONTACT  
COOLING2 NONCONTACT  
COOLING

3 PROCESS

4 SANITARY

5 STORMWATER

UNIT CODE

1 MGY

2 MGD

3 GPD

ITEM  
2WATER  
TREATMENT  
ADDITIVES

UNITS CODE

1 Mg/l

2 Ug/l

OUTFALL NUMBER

010.F

A. LOCATION OF DISCHARGE

N.W. &amp; S.W. &amp; SECTION 10.6, TOWN 10.6 S, RANGE 1.9 W

B. NAME OF RECEIVING WATER (IE, GROUNDWATER OR NAME OF SURFACE WATER)

LAKE MICHIGAN

C. DO YOU DISCHARGE SEASONALLY?  
(IF NO, CONTINUE TO E)☐ YES☒ NO

D. IF YES, LIST DISCHARGE PERIODS

NA

MO. / DAY

MO. / DAY

THROUGH

THROUGH

THROUGH

THROUGH

THROUGH

THROUGH

E. LAND APPLICATION RATE

NA

IN./HR.

HR./DAY

IN./WK.

☐

F. TYPE OF WASTE-WATER DISCHARGE

3

WASTEWATER TYPE CODE

G. DISCHARGE SCHEDULE (YEARLY AVERAGE)

HOURS/DAY

10 12

DAY/YEAR

31615

H. DISCHARGE FLOW RATE

TOTAL YEARLY

510

UNIT CODE

1

DAILY MINIMUM

0 0 9 7 2

2

DAILY MAXIMUM

0 5 8 3 2

2

I. THE MAXIMUM DISCHARGE FLOW RATE TO BE AUTHORIZED IN PERMIT.

AUTHORIZED

10 51 8 3 2

UNIT CODE

12

J. MAXIMUM DESIGN DISCHARGE FLOW RATE.

DESIGN

10 51 8 3 2

UNIT CODE

12

A. DO YOU USE WATER TREATMENT ADDITIVES TO TREAT YOUR DISCHARGE?  
(IF NO, CONTINUE TO ITEM 3)☐ YES☒ NOB. NAME, FUNCTION, AND CHEMICAL COMPOSITION  
OF THESE ADDITIVES.

NAME

FUNCTION

C. NAME AND ADDRESS OF MANUFACTURERS  
OF THESE ADDITIVES.

D. EXPECTED DISCHARGE CONCENTRATION OF ADDITIVES.

MINIMUM

UNITS  
CODE

AVERAGE

UNITS  
CODE

MAXIMUM

UNITS  
CODE

ADDITIVE NAME

ADDITIVE NAME

ADDITIVE NAME

E. DO YOU TREAT THE DISCHARGE TO REMOVE ADDITIVES?

☐ YES☒ NO

F. WHAT IS THE REMOVAL EFFICIENCY AND DISCHARGE FREQUENCY?

% REMOVAL

DISCHARGE FREQUENCY

HRS./DAY

DAYS/WK.

ADDITIVE NAME

ADDITIVE NAME

ADDITIVE NAME

G. AS AN ATTACHMENT TO THIS APPLICATION PROVIDE SPECIFIC MAMMALIAN OR AQUATIC TOXICOLOGICAL DATA OR REFERENCE WHICH ARE AVAILABLE AND INFORMATION ON THE RATE OF DEGRADATION OF THE PRODUCTS FOR EACH ADDITIVE.

# INSTRUCTIONS FOR COMPLETING SECTION II

## ITEMS 1 AND 2

This form requires information on the facility's discharge location, discharge schedule, volume flow rate and water treatment additives.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

Enter the outfall number in space provided for each page of Section II. For each individual discharge point a separate set of Section II forms must be filled out.

### ITEM 1

#### DISCHARGE LOCATION, SCHEDULE AND FLOW RATES

- A. Enter the location of discharge, this should include quarter-quarter section, quarter section, town, and range.
- B. List name of receiving water (if surface water discharge).
- C. Indicate whether facility discharges on a seasonal basis.
- D. If yes, list discharge periods.
- E. Provide the land application rates used or expected to be used in terms of inches per hour, hours per day, and inches per week.
- F. Indicate the type of wastewater to be discharged from this outfall. Refer to the wastewater type code given in the left margin. More than one code may be applicable.
- G. Provide the average number of hours per day in which the facility discharges treated wastewater and the total number of days per year in which the discharge occurs.
- H. Provide current (from the last 12 months) or expected flow rates as requested. Refer to unit code given in the left margin for the appropriate flow units. MGY - million gallons per year; MGD - million gallons per day; GPD - gallons per day.
- I. Provide the maximum discharge flow rate which you want to have authorized within the permit. NOTE: For NPDES permits only, the use of such a flow rate will not place an actual limit restriction on the flow but will be the flow rate used to develop effluent limits. Also, when the Monthly Operating Reports are reviewed by Compliance staff it will help them to determine if any new or increased uses might have occurred at the facility.
- J. Provide the design flow for this specific outfall discharge (e.g. batch treatment system flow, packaged treatment system flow, or some other finite treatment system flow).

### ITEM 2

#### WATER TREATMENT ADDITIVES

- A. Indicate whether discharge is treated with conditioners, inhibitors, or microbicide. If not, continue to Item 3.
- B. Give name, function, and chemical composition of additives used.
- C. Give name and address of the manufacturer(s) of the additives used.
- D. Indicate expected minimum, average and maximum discharge concentrations of the additive(s) for this discharge.
- E. Indicate whether you treat the discharge to remove the additive(s) before discharge of wastewater.
- F. Indicate the removal efficiency of each additive from the wastewater and the discharge frequency of each additive to the surface water or groundwater.
- G. NOTE: It is the responsibility of the applicant to supply the product information as requested in this Item 4. Information requested but not supplied may result in the application being returned to the applicant for completion.

## SECTION II

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
3PROCESS  
STREAMS  
CONTRIBUTING  
TO  
OUTFALL  
DISCHARGE

## UNITS CODE

- 1 POUNDS  
2 GALLONS  
3 CUBIC  
YARDS  
4 TONS  
5 MGY  
6 MGD  
7 GPD

## TIME

- 1 HOUR  
2 DAY  
3 WEEK  
4 MONTH  
5 YEAR

## OUTFALL BUFFER

[0,0,E]

PROCESS  
1A. NAME OF PROCESS CONTRIBUTING TO THE DISCHARGE  
THROUGH THIS OUTFALL AND SIC CODE

FILLITER BLAICK WSH 14911

B. PROCESS SCHEDULE (YEARLY AVERAGE)

HOURS/DAY 10121 DAYS/YEAR 131615

C. PROCESS VOLUME FLOW RATE

TOTAL YEARLY 510 UNIT CODE 5  
DAILY MINIMUM 101091712 16  
DAILY MAXIMUM 1015181312 16

D. PROCESS PRODUCTION RATE

NA

UNITS/TIME

PROCESS  
2A. NAME OF PROCESS CONTRIBUTING TO THE DISCHARGE  
THROUGH THIS OUTFALL AND SIC CODE

B. PROCESS SCHEDULE (YEARLY AVERAGE)

HOURS/DAY DAYS/YEAR

C. PROCESS VOLUME FLOW RATE

TOTAL YEARLY UNIT CODE  
DAILY MINIMUM  
DAILY MAXIMUM

D. PROCESS PRODUCTION RATE

UNITS/TIME

PROCESS  
3A. NAME OF PROCESS CONTRIBUTING TO THE DISCHARGE  
THROUGH THIS OUTFALL AND SIC CODE

B. PROCESS SCHEDULE (YEARLY AVERAGE)

HOURS/DAY DAYS/YEAR

C. PROCESS VOLUME FLOW RATE

TOTAL YEARLY UNIT CODE  
DAILY MINIMUM  
DAILY MAXIMUM

D. PROCESS PRODUCTION RATE

UNITS/TIME

PROCESS  
4A. NAME OF PROCESS CONTRIBUTING TO THE DISCHARGE  
THROUGH THIS OUTFALL AND SIC CODE

B. PROCESS SCHEDULE (YEARLY AVERAGE)

HOURS/DAY DAYS/YEAR

C. PROCESS VOLUME FLOW RATE

TOTAL YEARLY UNIT CODE  
DAILY MINIMUM  
DAILY MAXIMUM

D. PROCESS PRODUCTION RATE

UNITS/TIME

PROCESS  
5A. NAME OF PROCESS CONTRIBUTING TO THE DISCHARGE  
THROUGH THIS OUTFALL AND SIC CODE

B. PROCESS SCHEDULE (YEARLY AVERAGE)

HOURS/DAY DAYS/YEAR

C. PROCESS VOLUME FLOW RATE

TOTAL YEARLY UNIT CODE  
DAILY MINIMUM  
DAILY MAXIMUM

D. PROCESS PRODUCTION RATE

UNITS/TIME

INSTRUCTIONS FOR COMPLETING SECTION II

ITEM 3

This form requires information on the process streams which contribute to this discharge.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

Enter outfall number in space provided for each page of Section II. For each individual discharge point a separate set of Section II forms must be filled out.

ITEM 3

PROCESS STREAMS CONTRIBUTING TO DISCHARGE: FOR EACH SEPARATE PROCESS PROVIDE THE FOLLOWING INFORMATION

- A. Enter the name of the process which contributes to this discharge. Also provide the proper SIC code.
- B. Indicate the yearly average process schedule in hours per day and days-per-year.
- C. Provide the flow rate information as requested based on your last 12 months of operations. Refer to unit code given in the left margin for the appropriate flow units.
- D. Process Production Rate - Certain permit limitations may be based on production rates. The production rates used to determine permit limits shall be represented by a reasonable measure of actual production of the facility, such as the production during the high month of the previous year, or the monthly average for the highest of the previous five years, or other reasonable measure as stated in applicable U.S.E.P.A. categorical rules and regulations.

For new sources or new dischargers, actual production shall be estimated using projected production.

Record your production rates in the terms and units used in the applicable U.S.E.P.A. categorical rules and regulations for your type of facility.

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
4GROUNDWATER  
DISCHARGE  
INFORMATION

## OUTFALL NUMBER

## 10 (OLE)

A. IS THE DISCHARGE FROM THIS OUTFALL DIRECTED TO THE GROUND OR  
GROUNDWATERS? (IF NO, CONTINUE TO ITEM 5)☐ YES ☒ NOB. HAS A HYDROGEOLOGICAL STUDY OR ITS EQUIVALENT BEEN PERFORMED OR IS THERE SUFFICIENT  
CURRENT HYDROGEOLOGICAL INFORMATION AVAILABLE AS REQUIRED BY THE WATER RESOURCES  
COMMISSION PART 22 GROUNDWATER RULES OF AUGUST 14, 1980 R. 323.2207 (PAGE 45) FOR  
THIS EXISTING OR PROPOSED DISCHARGE? IF YES ATTACH A COPY OF THE REPORT.☐ YES ☐ NOC. ARE YOU REQUESTING AN EXEMPTION FROM SUBMITTING A HYDROGEOLOGICAL REPORT UNDER  
RULE R. 323.2207 (13) (PAGE 45) OR FROM GROUNDWATER MONITORING REQUIREMENTS  
UNDER RULE R. 323.2235 (5) (PAGE 47) OF THE PART 22 RULES. IF YES ATTACH  
DOCUMENTS AND EXPLANATION TO DEMONSTRATE THAT YOUR DISCHARGE WOULD QUALIFY FOR  
AN EXEMPTION.☐ YES ☐ NOD. ARE YOU REQUESTING A VARIANCE FROM RULE 323.2205 (PAGE 45) (NONDEGRADATION) OF  
THE WATER RESOURCES COMMISSION PART 22 GROUNDWATER RULES? IF YES, ATTACH SUCH  
DOCUMENTS AS NECESSARY TO DEMONSTRATE THE NEED FOR A VARIANCE IN TERMS OF THE  
CRITERIA SPECIFIED IN RULE 323.2210 (PAGE 47) OF THE PART 22 RULES.☐ YES ☐ NOE. LIST ALL CHEMICAL SUBSTANCES WHICH ARE IN MICHIGAN'S CRITICAL MATERIALS REGISTER TABLE IV  
(PAGE 6) AND/OR U.S. EPA'S PRIORITY POLLUTANT LIST TABLE V (PAGE 7) OR ANY OTHER SUBSTANCES  
WHICH ARE OR MAY BECOME INJURIOUS TO THE DESIGNATED USES OF THE GROUNDWATER OR TO THE  
PUBLIC HEALTH THAT ARE DISCHARGED OR EXPECTED TO BE DISCHARGED TO THE GROUNDWATER BY THIS  
FACILITY. ESTIMATE THE FINAL EFFLUENT CONCENTRATION AND RECORD ALL DATA IN ITEM 7 OF  
SECTION II IN THIS BOOKLET.☐ NOT APPLICABLE/BELIEVED ABSENT

THE APPLICANT MAY BE REQUIRED TO DO ADDITIONAL WASTE ANALYSES.

☐ PRESENT, DATA PROVIDED IN ITEM 7ITEM  
5EXPECTED  
WASTEWATER  
CHARAC-  
TERISTICS

## UNITS CODE

- 1 Mg/l  
2 Ug/l  
3 COUNTS/  
100 ml  
4 S.U.  
5 °F  
6 LBS/DAY

## A. DISCHARGE CHARACTERISTICS

## CONCENTRATION

UNITS CODE # ANALYSES SAMPLE TYPE  
CODE

AVE

MAX

\*BOD<sub>5</sub> (FIVE DAY BIOLOGICAL OXYGEN DEMAND)

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

\*COD (CHEMICAL OXYGEN DEMAND)

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

\*TOC (TOTAL ORGANIC CARBON)

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

\*AMMONIA NITROGEN (AS N)

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

\*TOTAL SUSPENDED SOLIDS

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

TOTAL PHOSPHORUS (AS P)

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

TOTAL RESIDUAL CHLORINE

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

DISSOLVED OXYGEN

MIN

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

1 \_\_\_\_\_

\*pH

\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_

4 \_\_\_\_\_

FECAL COLIFORM BACTERIA

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

3 \_\_\_\_\_

\*TEMPERATURE (SUMMER)

\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_

5 \_\_\_\_\_

\*TEMPERATURE (WINTER)

\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_

5 \_\_\_\_\_

## B. OTHER WASTEWATER CHARACTERISTICS

OIL &amp; GREASE

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_.\_\_\_\_\_

\_\_\_\_\_

## SAMPLE

## TYPE

- 1 GRAB  
2 24 HOUR  
COMPOSITE

See attached sheets for data.

INSTRUCTIONS FOR COMPLETING SECTION II  
ITEMS 4 AND 5

This form requires information on a specific outfall discharging to either the groundwaters or the surface waters.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

Enter the outfall number in the space provided for each page of Section II. For each individual discharge point a separate set of Section II forms (Items 4 and 5) must be filled out.

ITEM 4

GROUNDWATER DISCHARGE INFORMATION (DO NOT INCLUDE DEEP WELL INJECTION INFORMATION IN THIS ITEM)

A.-D. The applicant shall address each of these parts if the discharge from this outfall is to the groundwater.

ITEM 5

EXISTING OR EXPECTED (FOR A NEW DISCHARGE) WASTEWATER CHARACTERISTICS OF GROUNDWATER OR SURFACE WATER DISCHARGE (DO NOT INCLUDE DEEP WELL INJECTION INFORMATION IN THIS FORM)

A. The applicant shall report available discharge data (real data for existing discharge or expected data for a proposed discharge) for the parameters as listed. These parameters shall be addressed for either a surface water discharge or as appropriate for a groundwater discharge. For assistance in determining appropriate parameters a groundwater discharge applicant may contact the Groundwater Quality Division, Permits Section or the appropriate Groundwater Quality Division's District office.

The applicant shall report the sample type code best describing each reported piece of data. See coding on the left margin of this form.

If this outfall is a surface water discharge, the applicant must report quantitative data for each parameter identified by an asterisk. The applicant may, however, request that the reporting of data for one or more of these required parameters be waived. Such request must be supported by adequate rationale. Make such a request an attachment to this application.

B. If data is available for other parameters not listed above in A. or other parts of this application the applicant should report that data in the blank spaces provided in this part.

NOTES: 1. Unit codes for parameters reported in parts A and B can be found on the left hand side of this form.

2. Grab sample shall be used to analyze for pH, temperature, total phenols, residual chlorine, oil and grease, and fecal coliform in a surface water discharge unless other frequency-sample type analyses are available. See Glossary (page 46) for definition of grab sample.
3. 24-hour composite samples shall be used to analyze for Total BOD<sub>5</sub>, COD, TOC, Ammonia Nitrogen, and Total Suspended Solids in a surface water discharge unless other frequency-sample type analyses are available. See Glossary (page 46) for definition of composite sample.
4. REPORTING OF INTAKE DATA. You are not required to report unless you wish to demonstrate your eligibility for a "net" effluent limitation for one or more pollutants, that is, an effluent limitation adjusted by subtracting the average level of the pollutant(s) present in your intake water. NPDES regulations allow net limitations only in certain circumstances. To demonstrate your eligibility, report the average of the results of analyses on your intake water (if your water is treated before use, test the water after it is treated), and attach a separate sheet containing the following for each pollutant:
  - (a) A statement that the intake water is drawn from the body of water into which the discharge is made. (Otherwise, you are not eligible for net limitations.)
  - (b) A statement of the extent to which the level of the pollutant is reduced by treatment of your wastewater. (Your limitations will be adjusted only to the extent that the pollutant is not removed.)
  - (c) When applicable (for example, when the pollutant represents a class of compounds), a demonstration of the extent to which the pollutants in the intake vary physically, chemically, or biologically from the pollutants contained in your discharge. (Your limitations will be adjusted only to the extent that the intake pollutants do not vary from the discharged pollutants.)
5. If you have two or more substantially identical outfalls, you may request permission from your permitting authority to sample and analyze only one outfall and submit the results of the analysis for other substantially identical outfalls. If your request is granted by the permitting authority, on a separate sheet attached to the application form identify which outfall you did test, and describe why the outfalls which you did not test are substantially identical to the outfall which you did test.

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
6PRIORITY  
POLLUTANTS  
AND  
ADDITIONAL  
INFORMATION  
FOR  
SURFACE  
WATER  
DISCHARGE  
ONLY

## OUTFALL WATER

LOIOLF

THE FOLLOWING REQUESTED INFORMATION SHALL BE ADDRESSED BY ALL SURFACE WATER DISCHARGERS.  
NOTE! NEW USE DISCHARGERS SHALL PROVIDE EXPECTED VALUES FOR THE QUANTITATIVE AND QUALITATIVE INFORMATION REQUESTED BELOW.A. IS THIS FACILITY A PRIMARY INDUSTRY? (REFER TO TABLE IA PAGE 41)  
(IF NO, GO TO E) (IF YES, GO TO B)☒ YES ☐ NOB. INDICATE TYPE OF PRIMARY INDUSTRY AS LISTED IN TABLE IA PAGE 41.  
(CONTINUE WITH C.)

LSITMI IELLIC I PLWRJ

C. DOES THIS OUTFALL DISCHARGE CONTAIN ANY PROCESS WASTEWATER?  
(IF NO, GO TO E) (IF YES, GO TO D)☒ YES ☐ NOD. INDICATE WHICH GC/MS FRACTIONS MUST BE TESTED FOR.  
(REFER TO TABLE IA PAGE 41)

NOTE! FOR EACH GC/MS FRACTION CHECKED, EACH SPECIFIC ORGANIC TOXIC POLLUTANT WITHIN EACH FRACTION MUST BE ANALYZED FOR (SEE TABLE IIA PAGE 42). IN ADDITION, ALL PRIMARY INDUSTRY APPLICANTS WITH A PROCESS WASTEWATER DISCHARGE MUST PROVIDE QUANTITATIVE DATA FOR EACH TOXIC POLLUTANT IN TABLE IIA PAGE 43.

RECORD ALL DATA ON FORMS PROVIDED (ITEM 7) IN THIS BOOKLET.

(CONTINUE WITH E-K BELOW)

☒ VOLATILE  
☒ BASE/NEUTRAL  
☒ ACID  
☐ PESTICIDE

E. IF ANY SURFACE WATER DISCHARGE APPLICANT (PRIMARY OR SECONDARY INDUSTRY), REGARDLESS OF THE TYPE OF DISCHARGE, KNOWS OR HAS REASON TO BELIEVE THAT ANY POLLUTANT LISTED IN TABLE IIA AND IVA PAGES 42-43 IS DISCHARGED FROM ANY OUTFALL, THE QUANTITATIVE DATA MUST BE PROVIDED.

RECORD ALL DATA ON FORMS PROVIDED (ITEM 7) IN THIS BOOKLET.

☐ NOT APPLICABLE/BELIEVED ABSENT  
☒ PRESENT/DATA IS ATTACHED

F. IF ANY SURFACE WATER DISCHARGE APPLICANT (PRIMARY OR SECONDARY INDUSTRY), REGARDLESS OF TYPE OF DISCHARGE, KNOWS OR HAS REASON TO BELIEVE ANY POLLUTANTS LISTED IN TABLE VA PAGE 45 ARE DISCHARGED FROM ANY OUTFALL, THE APPLICANT MUST DESCRIBE REASONS FOR THE POLLUTANT BEING PRESENT AND PROVIDE ANY AVAILABLE QUANTITATIVE DATA.

RECORD ALL DATA ON FORMS PROVIDED (ITEM 7) IN THIS BOOKLET.

☒ NOT APPLICABLE/BELIEVED ABSENT  
☐ PRESENT/DATA IS ATTACHED

G. ALL SURFACE WATER DISCHARGE APPLICANTS (PRIMARY AND SECONDARY INDUSTRIES) WHO:

USES OR MANUFACTURES 2, 4, 5 - TRICHLOROPHOXY ACETIC ACID (2, 4, 5-T);  
2-(2, 4, 5-TRICHLOROPHOXY) PROPANOIC ACID (SILVEX, 2, 4, 5, TP);  
2-(2, 4, 5-TRICHLOROPHOXY) ETHYL 2, 2-DICHLOROPROPIONATE (ERBON); O,  
O-DIMETHYL O-(2, 4, 5-TRICHLOROPHENYL) PHOSPHOROTHIOATE (RONNEL);  
2, 4, 5-TRICHLOROPHENOL (TCP); OR HEXACHLOROPHENOL (HCP); (ALL DATA FOR THE ABOVE MUST BE GENERATED USING STANDARD ANALYTICAL CALIBRATION PROCEDURES) OR

KNOWS OR HAS REASON TO BELIEVE THAT TCDD IS OR MAY BE PRESENT IN THEIR DISCHARGE. MUST REPORT QUALITATIVE DATA, GENERATED WHICH USED A SCREENING PROCEDURE NOT CALIBRATED WITH ANALYTICAL STANDARDS, FOR 2, 3, 7, 8 - TETRACHLORODIBENZO-P-DIOXIN (TCDD). RECORD ALL DATA ON FORMS PROVIDED (ITEM 7) IN THIS BOOKLET.

☒ NOT APPLICABLE/BELIEVED ABSENT  
☐ PRESENT/DATA IS ATTACHED

J. IF THE SURFACE WATER DISCHARGE APPLICANT KNOWS OR HAS REASON TO BELIEVE THAT BIOLOGICAL TOXICITY TESTS WERE MADE IN THE LAST THREE (3) YEARS ON ANY OF THE APPLICANT'S DISCHARGES OR ON A RECEIVING WATER IN RELATION TO A DISCHARGE, PROVIDE THIS INFORMATION AS AN ATTACHMENT TO THIS APPLICATION.

☒ NOT APPLICABLE  
☐ APPLICABLE/SEE ATTACHED

K. IF A CONTRACT LABORATORY OR CONSULTING FIRM PERFORMED ANY OF THE ANALYSES REQUIRED BY THIS APPLICATION, PROVIDE THE NAME AND ADDRESS OF EACH LABORATORY OR FIRM AND THE ANALYSES PERFORMED AS AN ATTACHMENT TO THIS APPLICATION.

☐ NOT APPLICABLE  
☒ APPLICABLE/SEE ATTACHED BELOW

L. DO YOU DISCHARGE ANY OTHER TOXIC OR INJURIOUS CHEMICAL SUBSTANCES NOT LISTED IN TABLES IV PAGE 6 AND IIA THROUGH IVA PAGES 42-43. IF YES, THEN IDENTIFY THE CHEMICAL SUBSTANCES AND ESTIMATE THE FINAL EFFLUENT CONCENTRATIONS. SUBMIT THIS INFORMATION AS AN ATTACHMENT TO THIS APPLICATION.

☒ NOT APPLICABLE  
☐ APPLICABLE/SEE ATTACHEDK. NUS Corporation  
Laboratory Services Division  
5350 Campbells Run Road  
Pittsburgh, PA 15205

# INSTRUCTIONS FOR COMPLETING SECTION II

## ITEM 6

This form requires information on a specific outfall discharging to the surface waters.

ENTER THE PERMIT NUMBER IN THE BOX AT THE TOP OF THIS FORM. THE PERMIT NUMBER CAN BE FOUND ON THE FRONT PAGE OF YOUR EXPIRING PERMIT. If this is a new or not previously permitted facility, then leave blank and a number will be assigned.

Enter the outfall number in the space provided for each page of Section II. For each individual discharge point a separate set of Section II, Item 6 forms must be filled out.

## ITEM 6

### PRIORITY POLLUTANTS AND ADDITIONAL INFORMATION

**NOTE:** If you have two or more substantially identical outfalls, you may request permission from your permitting authority to sample and analyze only one outfall and submit the results of the analysis for other substantially identical outfalls. If your request is granted by the permitting authority, on a separate sheet attached to the application form identify which outfall you did test, and describe why the outfalls which you did not test are substantially identical to the outfall which you did test.

**NOTE:** 40 CFR Part 122.21(g)(3), Friday, April 1, 1983, provides for a Small Business Exemption from the reporting of quantitative data for organic toxic pollutants and toxic pollutants as required by Part 122.21(g)(7)(ii)(A) or 122.21(g)(7)(iii)(A).

A.-C. and E.-J. These parts are self-explanatory and do not require further instructions. Simply go through each part and do as indicated.

- D. Several industrial categories and subcategories have been exempted from submitting data on certain GC/MS Fractions (40 CFR Part 122, Vol. 43, No. 64, Friday, April 1, 1983, Notes 1, 2, and 3).

Review the following list to determine whether your facility qualifies to be exempt from reporting GC/MS (Gas Chromatography/Mass Spectroscopy) Fractions.

### GC/MS Fraction Testing and Reporting Exemptions

#### Textile Mills Industry

- All four GC/MS organic fractions in the Greige Mills Subcategory.
- Pesticide fraction in all other subparts of this industry.

#### Ore Mining and Dressing Industry

- Volatile, base/neutral, and pesticide fractions in the Base and Precious Metals Subcategory.
- All four GC/MS organic fractions in all other subcategories of this industry.

#### Porcelain Enameling Industry

- All four GC/MS organic fractions.

#### Gum and Wood Chemicals Industry

- Pesticide fraction in the Tall Oil Rosin Subcategory and the Rosin Based Derivatives Subcategory.
- Pesticide and base/neutral fractions in all other subcategories of this industry.

#### Leather Tanning and Finishing Industry

- Pesticide fraction in all subparts.

#### Paint and Ink Formulation Industry

- Pesticide fraction in all subparts.

#### Photographic Supplies Industry

- Pesticide fraction in all subparts.

#### Petroleum Refining Industry

- Acid, base/neutral, and pesticide fractions.

#### Pulp and Paper Industry

- Pesticide fraction in Papergrade Sulfite subcategories (subparts J and U).
- Base/neutral and pesticide fractions in Deink Subpart Q, Dissolving Kraft Subpart F, and Paperboard from Waste Paper Subpart E.
- Volatile, base/neutral, pesticide fractions in the BCT Bleached Kraft Subpart H, Semi-chemical Subparts B and C, and Nonintegrated-Fine Papers Subpart R.
- Acid, base/neutral, and pesticide fractions in Fine Bleached Kraft Subpart I, Dissolving Sulfite Pulp Subpart K, Groundwood Fine Papers Subpart O, Market Bleached Kraft Subpart G, Tissue from Wastepaper Subpart T, and Nonintegrated Tissue Papers Subpart S.

#### Steam Electric Power Plant Industry

- Base/neutral fraction in the Once-Through Cooling Water, Fly Ash, and Bottom Ash Transport Water process wastestreams.



## SECTION 11

PERMIT  
NUMBER

MI0005827

SEE INSTRUCTIONS  
ON REVERSE SIDEITEM  
7CRITICAL  
MATERIALSTOXIC  
POLLUTANTSHAZARDOUS  
SUBSTANCES  
IN  
DISCHARGE

OUTFALL NUMBER

10101F

A. USE THIS DATA SHEET TO RECORD INFORMATION AS REQUIRED IN: (CHECK APPROPRIATE BOX FOR WHICH INFORMATION THIS DATA SHEET REPRESENTS.)

☐1. SECTION 11, ITEM 4-E. GROUNDWATER DISCHARGE INFORMATION (PAGE 35)☒2. SECTION 11, ITEM 6. PRIORITY POLLUTANTS IN SURFACE WATER DISCHARGE (PAGE 37) See attached data sheets.☐3. B. BELOW: CRITICAL MATERIALS (TABLE IV) IN SURFACE WATER DISCHARGE (PAGE 39)

B. LIST ANY CRITICAL MATERIAL (TABLE IV PAGE 6) NOT ADDRESSED IN SECTION 11 ITEM 6 PRIORITY POLLUTANTS WHICH YOU KNOW OR HAVE REASON TO BELIEVE TO BE PRESENT IN THE DISCHARGE. SEE REVERSE SIDE OF THIS PAGE FOR FURTHER DIRECTIONS.

☒

NOT APPLICABLE

☐

APPLICABLE (SEE BELOW)

MATERIAL	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT			UNIT CODE			SAMPLE TYPE			# OF ANALYSES		
MATERIAL 1	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 2	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 3	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 4	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 5	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 6	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 7	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											
MATERIAL 8	A. NAME OF CRITICAL MATERIAL OR PRIORITY POLLUTANT											
	B. AVERAGE CONCENTRATION; SAMPLE TYPE; # OF ANALYSES											
	C. MAXIMUM CONCENTRATION AND MASS											

## UNITS CODE

1 Mg/l  
2 Ug/l  
3 LBS/DAY  
4 KG/DAY

## SAMPLE TYPE

1 GRAB  
2 24 HR.COMP

ADDITIONAL PAGES OF THIS ITEM 7 ARE ATTACHED FOR THE REST OF THE CRITICAL MATERIALS AND/OR PRIORITY POLLUTANTS REQUIRED TO BE REPORTED.

☐ YES  
☒ NO

INSTRUCTIONS FOR COMPLETING SECTION II

ITEM 7

This form is to be used by both surface and groundwater applicants to record information on any Michigan critical material, E.P.A. priority pollutant, or hazardous substance in which this application requires data to be provided. This would include any chemical substance from the Michigan Critical Materials Register (Table IV), the E.P.A. Priority Pollutant Listing (Table V), or Tables IIA-VA which lists Organic Toxic Pollutants, Other Toxic Pollutants, Conventional and Nonconventional Pollutants and Hazardous Substances.

ITEM 7

CRITICAL MATERIALS, PRIORITY POLLUTANTS, AND/OR HAZARDOUS SUBSTANCES IN THE DISCHARGE

Material 1, 2, 3 . . . 8

- A. List the name of the chemical substance (critical material, priority pollutant, or hazardous substance) from Tables IV, V and IIA-VA as required in the box which you checked in A.1-3. above. Enter each chemical substance's parameter number as listed in Tables IV, V and IIA-VA if provided.
- B. Provide the average concentration of the chemical substance named in A. Indicate the sample type used and the number of analyses made to provide the concentration data for the chemical substance named in A.
- C. Provide the maximum concentration and determine the mass loading of the chemical substance named in A.

- NOTES:
1. If only one analysis was made for a chemical substance then record that data as a maximum value. If more than one analysis has been made for a chemical substance then provide an average value of those analyses and the maximum value.
  2. This Section II, Item 7, Data Sheet provides space for recording data for 8 chemical substances (Materials). Additional space for recording of data for more than 8 Materials can be made by making copies of this Item 7 Data Sheet as needed. It is also important to use a separate set of Data Sheets for each applicable reporting requirement as listed in A.1-3. and for each outfall.
  3. Refer to the left margin for the code number representing the sample type used and the appropriate unit codes.



Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEMAN, MI 49106

REPORT DATE: 08/29/86

ATTENTION: D FITZGERALD/STEWART

NUS CLIENT NO: 010904  
NUS SAMPLE NO: 16080400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP 08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
M360	NPDES PART V-A REQUIRED		
M032	Ammonia as N (distillation)	< 0.1	mg/l
M050	BOD, 5-day (O2)	2	mg/l
M116	Organic Carbon(non-purgeable)	3.8	mg/l
M120	COD (O2)	10	mg/l
M490	pH	7.9	
M610	Solids, suspended at 103 C	16	mg/l
M361	NPDES PART V-B		
M010	Aluminum (Al)	1.7	mg/l
M040	Barium (Ba)	< 0.1	mg/l
M150	Cobalt (Co)	< 0.01	mg/l
M190	Iron, total (Fe)	0.08	mg/l
M230	Magnesium (Mg)	9.9	mg/l
M240	Manganese (Mn)	< 0.01	mg/l
M260	Molybdenum (Mo)	< 0.03	mg/l
M340	Tin (Sn)	< 1	mg/l
M350	Titanium (Ti)	< 0.5	mg/l
M055	Boron (B)	< 0.2	mg/l
M060	Bromide (Br)	< 2.0	mg/l
M225	Color, True	5	Pt-Co
M310	Fluoride, total (F)	2.7	mg/l
M390	Nitrate (N)	0.3	mg/l
M410	Nitrite (N)	< 0.01	mg/l
M435	Nitrogen, Kjeldahl (N)	0.4	mg/l
M440	Nitrogen, Organic (N)	0.4	mg/l
M540	Phosphorus, total (P)	0.34	mg/l
M730	Sulfate, turbidimetric (SO4)	25	mg/l
M740	Sulfide (S)	< 0.1	mg/l
M760	Sulfite (SO3)	< 1	mg/l
M770	Surfactants (MBAS)	< 0.05	mg/l
M362	NPDES PART V-C TOXIC METALS		
M020	Antimony (Sb)	< 0.1	mg/l



Laboratory Services Division  
5350 Campbells Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEHAM, MI 49106

REPORT DATE: 08/29/86

ATTENTION: D FITZGERALD/STEWART

MUS CLIENT NO: 010904  
MUS SAMPLE NO: 16080400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP 08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
M030	Arsenic (As)	0.002	ug/l
M050	Beryllium (Be)	< 0.002	ug/l
M090	Cadmium (Cd)	< 0.005	ug/l
M140	Chromium (Cr)	< 0.01	ug/l
M160	Copper (Cu)	< 0.01	ug/l
M200	Lead (Pb)	< 0.03	ug/l
M250	Mercury (Hg)	< 0.0002	ug/l
M270	Nickel (Ni)	< 0.03	ug/l
M290	Selenium (Se)	< 0.004	ug/l
M300	Silver (Ag)	< 0.01	ug/l
M330	Thallium (Tl)	< 0.1	ug/l
M390	Zinc (Zn)	0.07	ug/l
M270	Cyanide, total (CN)	< 0.005	ug/l
M500	Phenolics	< 0.02	ug/l
0110	VOLATILES-PP IN WATER		
OV01	Acrolein	< 100	ug/l
OV02	Acrylonitrile	< 100	ug/l
OV03	Benzene	< 5	ug/l
OV05	Bromoform	< 5	ug/l
OV06	Carbon Tetrachloride	< 5	ug/l
OV07	Chlorobenzene	< 5	ug/l
OV08	Chlorodibromomethane	< 5	ug/l
OV09	Chloroethane	< 10	ug/l
OV10	2-Chloroethylvinyl Ether	< 10	ug/l
OV11	Chloroform	< 5	ug/l
OV12	Dichlorobromomethane	< 5	ug/l
OV14	1,1-Dichloroethane	< 5	ug/l
OV15	1,2-Dichloroethane	< 5	ug/l
OV16	1,1-Dichloroethylene	< 5	ug/l
OV17	1,2-Dichloropropane	< 5	ug/l
OV18	1,3-Dichloropropylene	< 5	ug/l
OV19	Ethylbenzene	< 5	ug/l

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEMAN, MI 49106

NUS CLIENT NO: 010904  
NUS SAMPLE NO: 16080400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

ATTENTION: D FITZGERALD/STEWART

REPORT DATE: 08/29/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP

08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
OV20	Methyl Bromide	< 10	ug/l
OV21	Methyl Chloride	< 10	ug/l
OV22	Methylene Chloride	38	ug/l
OV23	1,1,2,2-Tetrachloroethane	< 5	ug/l
OV24	Tetrachloroethylene(Perchloro)	< 5	ug/l
OV25	Toluene	< 5	ug/l
OV26	1,2-Trans-Dichloroethylene	< 5	ug/l
OV27	1,1,1-Trichloroethane	< 5	ug/l
OV28	1,1,2-Trichloroethane	< 5	ug/l
OV29	Trichloroethylene	< 5	ug/l
OV30	Trichlorofluoroethane	< 5	ug/l
OV31	Vinyl chloride	< 10	ug/l
0120	ACIDS - PP IN WATER		
0A01	2-Chlorophenol	< 10	ug/l
0A02	2,4-Dichlorophenol	< 10	ug/l
0A03	2,4-Dimethylphenol	< 10	ug/l
0A04	4,6-Dinitro-o-cresol	< 50	ug/l
0A05	2,4-Dinitrophenol	< 50	ug/l
0A06	2-Nitrophenol	< 10	ug/l
0A07	4-Nitrophenol	< 50	ug/l
0A08	p-Chloro-o-cresol	< 10	ug/l
0A09	Pentachlorophenol	< 50	ug/l
0A10	Phenol	< 10	ug/l
0A11	2,4,6-Trichlorophenol	< 10	ug/l
0E30	Acid Extraction-Water		
0130	BASE NEUTRALS - PP IN WATER		
0B01	Acenaphthene	< 10	ug/l
0B02	Acenaphthylene	< 10	ug/l
0B03	Anthracene	< 10	ug/l
0B04	Benidine	< 50	ug/l
0B05	Benzo(a)Anthracene	< 10	ug/l
0B06	Benzo(a)Pyrene	< 10	ug/l

See attached  
data sheet dat  
11/7/86. Retes  
indicates less  
than detectable  
methylene chlorid



Laboratory Services Division  
5350 Camp Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COCK PLANT  
BRIDGEHAM, MI 49106

MUS CLIENT NO: 010904  
MUS SAMPLE NO: 16060400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

REPORT DATE: 08/29/86

ATTENTION: D FITZGERALD/STEWART

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP 08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
0807	3,4-Benzofluoranthene	< 10	ug/l
0808	Benzo(a,h)Perylene	< 10	ug/l
0809	Benzo(k)Fluoranthene	< 10	ug/l
0810	Bis(2-Chloroethoxy)Methane	< 10	ug/l
0811	Bis(2-Chloroethyl)Ether	< 10	ug/l
0812	Bis(2-Chloroisopropyl)Ether	< 10	ug/l
0813	Bis(2-Ethylhexyl)Phthalate	< 10	ug/l
0814	4-Bromophenyl Phenyl Ether	< 10	ug/l
0815	Butyl Benzyl Phthalate	< 10	ug/l
0816	2-Chloronaphthalene	< 10	ug/l
0817	4-Chlorophenyl Phenyl Ether	< 10	ug/l
0818	Chrysene	< 10	ug/l
0819	Dibenzo(a,h)Anthracene	< 10	ug/l
0820	1,2-Dichlorobenzene	< 10	ug/l
0821	1,3-Dichlorobenzene	< 10	ug/l
0822	1,4-Dichlorobenzene	< 10	ug/l
0823	3,3'-Dichlorobenzidine	< 20	ug/l
0824	Diethyl Phthalate	< 10	ug/l
0825	Dimethyl Phthalate	< 10	ug/l
0826	Di-N-Butyl Phthalate	< 10	ug/l
0827	2,4-Dinitrotoluene	< 10	ug/l
0828	2,6-Dinitrotoluene	< 10	ug/l
0829	Di-N-Octyl Phthalate	< 10	ug/l
0830	1,2-Diphenylhydrazine(Azobz)	< 20	ug/l
0831	Fluoranthene	< 10	ug/l
0832	Fluorene	< 10	ug/l
0833	Hexachlorobenzene	< 10	ug/l
0834	Hexachlorobutadiene	< 10	ug/l
0835	Hexachloro-cyclopentadiene	< 10	ug/l
0836	Hexachloroethane	< 10	ug/l
0837	Indeno(1,2,3 cd)Pyrene	< 10	ug/l
0838	Isoxanthone	< 10	ug/l



Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEHAM, MI 49106

REPORT DATE: 08/29/86

ATTENTION: B FITZGERALD/STEWART

MUS CLIENT NO: 010904  
MUS SAMPLE NO: 16080400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP 08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
0839	Naphthalene	< 10	ug/l
0840	Nitrobenzene	< 10	ug/l
0841	N-Nitrosodimethylamine	< 10	ug/l
0842	N-Nitrosodi-N-Propylamine	< 10	ug/l
0843	N-Nitrosodiphenylamine	< 10	ug/l
0844	Phenanthrene	< 10	ug/l
0845	Pyrene	< 10	ug/l
0846	1,2,4-Trichlorobenzene	< 10	ug/l
0E25	Base Neutral Extraction-Water		
0142	PESTICIDES/PCB'S - PP IN WATER		
0E10	Pesticide/PCB Extraction-Water		
OP01	Aldrin	< 0.05	ug/l
OP02	alpha BHC	< 0.05	ug/l
OP03	beta BHC	< 0.05	ug/l
OP04	delta BHC	< 0.05	ug/l
OP05	gamma BHC (Lindane)	< 0.05	ug/l
OP06	Chlordane	< 0.50	ug/l
OP07	4-4'DDB	< 0.10	ug/l
OP08	4-4'DDE	< 0.10	ug/l
OP09	4-4'DBT	< 0.10	ug/l
OP10	Dieldrin	< 0.10	ug/l
OP11	Endosulfan I	< 0.05	ug/l
OP12	Endosulfan II	< 0.10	ug/l
OP13	Endosulfan Sulfate	< 0.10	ug/l
OP14	Endrin	< 0.10	ug/l
OP15	Endrin Aldehyde	< 0.10	ug/l
OP16	Hertachlor	< 0.05	ug/l
OP17	Hertachlor Epoxide	< 0.05	ug/l
OP18	Toxaphene	< 1.0	ug/l
OP19	PCB-1016	< 0.5	ug/l
OP20	PCB-1221	< 0.5	ug/l
OP21	PCB-1232	< 0.5	ug/l



Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/B.C. COOK PLANT  
BRIDGEHAM, MI 49106

ATTENTION: B FITZGERALD/STEWART

REPORT DATE: 08/29/86

MUS CLIENT NO: 010904  
MUS SAMPLE NO: 16080400  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH COMP 08/06 0930

TEST	DETERMINATION	RESULTS	UNITS
OP22	PCB-1242	< 0.5	ug/l
OP23	PCB-1248	< 0.5	ug/l
OP24	PCB-1254	< 1.0	ug/l
OP25	PCB-1260	< 1.0	ug/l
R450	RADIUM 226 AND 228		
R804	Radium-226	< 0.5	pCi/l
R805	Radium-228	< 3	pCi/l
R800	Gross Alpha	< 4	pCi/l
R801	Gross Beta	< 6	pCi/l
W150	Chlorine, Total Res DPD (C12)	< 0.1	mg/l

COMMENTS:

Reviewed and Approved by: JMS A Halliburton Company

CLIENT ORIGINAL





Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/B.C. COOK PLANT  
BRIDGE MAN, MI 49106

ATTENTION: J FITZGERALD/STEWART

REPORT DATE: 08/29/86

MUS CLIENT NO: 010904  
MUS SAMPLE NO: 16080403  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKELP PLANT PREFILTER BACKWASH-GRAB III 08/06 0300

TEST	DETERMINATION	RESULTS	UNITS
BA34	Fecal Coliform (MPN)3	43	col/100ml
W682	Oil, extraction-gravimetric(3)	< 3.0	mg/l

COMMENTS:



Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEHAM, MI 49106

ATTENTION: D FITZGERALD/STEWART

REPORT DATE: 08/29/86

NUS CLIENT NO: 010904  
NUS SAMPLE NO: 16080404  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH-GRAB IV 08/06 0920

TEST	DETERMINATION	RESULTS	UNITS
BA35	Fecal Coliform (MPN)4	23	col/100ml
M683	Oil, extraction-gravimetric(4)	< 3.0	mg/l

COMMENTS:

Reviewed and Approved by: JMS  A Halliburton Company

CLIENT ORIGINAL



Laboratory Services Division  
5350 Camp Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/B.C. COOK PLANT  
BRIDGEHAM, MI 49106

REPORT DATE: 08/29/86

ATTENTION: B FITZGERALD/STEHART

NUS CLIENT NO: 010904  
NUS SAMPLE NO: 16080402  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH GRAB II 08/05 1645

TEST	DETERMINATION	RESULTS	UNITS
9A33	Fecal Coliform (MPN)2	( 3	col/100ml
H681	Oil, extraction-gravimetric (2)	3.4	mg/l

COMMENTS:

Reviewed and Approved by: JNS  A Halliburton Company

CLIENT ORIGINAL



Laboratory Services Division  
5350 Camp Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1080

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/B.C. COOK PLANT  
BRIDGEHAM, MI 49106

REPORT DATE: 08/29/86

ATTENTION: B FITZGERALD/STEWART

NUS CLIENT NO: 010904  
NUS SAMPLE NO: 16080401  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 08/08/86

SAMPLE IDENTIFICATION: MAKEUP PLANT PREFILTER BACKWASH-GRAB I 08/05 1125

TEST	DETERMINATION	RESULTS	UNITS
BA32	Fecal Coliform - MPN	< 3	col/100ml
W680	Oil, extraction-gravimetric	< 3.0	mg/l

COMMENTS:





Laboratory Services Division  
5350 Campbell Run Road  
Pittsburgh, PA 15205

REMIT TO:  
Park West Two  
Cliff Mine Road  
Pittsburgh, PA 15275

412-788-1060

## LAB ANALYSIS REPORT

CLIENT NAME: INDIANA & MICHIGAN ELECTRIC CO.  
ADDRESS: P.O. BOX 312/D.C. COOK PLANT  
BRIDGEMAN, MI 49106

REPORT DATE: 11/07/86

HUS CLIENT NO: 010904  
HUS SAMPLE NO: 16101256  
VENDOR NO: 05411000  
WORK ORDER NO: 55830  
DATE RECEIVED: 10/17/86

ATTENTION: B FITZGERALD/STEWART

SAMPLE IDENTIFICATION: MAKEUP PLANT PRE-FILTER BACKWASH COMP

10/13-14

TEST	DETERMINATION	RESULTS	UNITS
0110	VOLATILES-PP IN WATER		
OV01	Acrolein	< 100	ug/l
OV02	Acrylonitrile	< 100	ug/l
OV03	Benzene	< 5	ug/l
OV05	Bromoform	< 5	ug/l
OV06	Carbon Tetrachloride	< 5	ug/l
OV07	Chlorobenzene	< 5	ug/l
OV08	Chlorodibromomethane	< 5	ug/l
OV09	Chloroethane	< 10	ug/l
OV10	2-Chloroethylvinyl Ether	< 10	ug/l
OV11	Chloroform	< 5	ug/l
OV12	Dichlorobromomethane	< 5	ug/l
OV14	1,1-Dichloroethane	< 5	ug/l
OV15	1,2-Dichloroethane	< 5	ug/l
OV16	1,1-Dichloroethylene	< 5	ug/l
OV17	1,2-Dichloroethane	< 5	ug/l
OV18	1,3-Dichloropropylene	< 5	ug/l
OV19	Ethylbenzene	< 5	ug/l
OV20	Methyl Bromide	< 10	ug/l
OV21	Methyl Chloride	< 10	ug/l
OV22	Methylene Chloride	< 5	ug/l
OV23	1,1,2,2-Tetrachloroethane	< 5	ug/l
OV24	Tetrachloroethylene(Perchloro)	< 5	ug/l
OV25	Toluene	< 5	ug/l
OV26	1,2-Trans-Dichloroethylene	< 5	ug/l
OV27	1,1,1-Trichloroethane	< 5	ug/l
OV28	1,1,2-Trichloroethane	< 5	ug/l
OV29	Trichloroethylene	< 5	ug/l
OV30	Trichlorofluoroethane	< 5	ug/l
OV31	Vinyl chloride	< 10	ug/l

COMMENTS:

Reviewed and Approved by: JMC



A Halliburton Company

CLIENT ORIGINAL