

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704130216 DDC DATE: 87/04/02 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC request for confirmation of status of
 Generic Ltr 83-28, Items 3.2.1 & 3.2.2, "Post-Maint Testing."
 Review indicates 97% of procedures have post-maint testing
 enhancements. Remaining 3% will be enhanced by 871201.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1	PD3-3 PD	3
	WIGGINGTON, D	1		
INTERNAL:	ADM/LFMB	1	NRR LASHER, D	1
	NRR/ADT	1	NRR/DEST/ICSB	1
	NRR/DEST/PSB	1	NRR/DEST/RSB	1
	NRR/DLPQ/QAB	1	NRR/DOEA/GCB	1
	NRR/PMAS/ILRB	1	NRR/PMAS/PMSB	1
	OGC/HDS1	1	REG FILE 01	1
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR .20 ENCL 0

1-10-50
1-10-50
1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

1-10-50

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631
COLUMBUS, OHIO 43216

April 2, 1987
AEP:NRC:0838K

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
GENERIC LETTER 83-28
COMPLETION INFORMATION ON ITEMS 3.2.1 AND 3.2.2

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: H. R. Denton

Dear Mr. Denton:

This letter is in response to your staff's request to confirm the status of Generic Letter (GL) 83-28, Items 3.2.1 and 3.2.2 (Post Maintenance Testing).

The AEPSC Engineering review of D. C. Cook maintenance procedures for Post Maintenance Testing has been completed. A review by the Plant Staff indicates that 97 percent (289) of the affected procedures have had the post maintenance testing enhancements incorporated or did not require revision. The remaining three percent (9) of the affected procedures are on administrative hold and cannot be used until the post maintenance testing enhancements are incorporated. The remaining procedures will have the post maintenance testing enhancements incorporated by December 1, 1987.

Based on the above we believe that we have met the requirements of Generic Letter 83-28, Items 3.2.1 and 3.2.2 (Post Maintenance Testing).

8704130216 870402
PDR ADCK 05000315
PDR

A055
1/0

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



M. P. Alexich
Vice President

cm

cc: John E. Dolan
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Bruchmann
G. Charnoff
NRC Resident Inspector - Bridgman

w/o enclosure
 DISTRIBUTION: Docket File Local HDR
~~XXXXXX~~ NRC HDR
 FWR#4 Reading
 BJYoungblood Reading
 MDuncan
 DWigginton
 ACRS(10)
 EJordan
 JPartlow
 BGrimes
~~XXXXXX~~ Nihompson

k

April 2, 1987

DOCKET NO(S). 50-315 and 50-316
 Mr. John Dolan, Vice President
 Indiana and Michigan Electric Company
 c/o American Electric Power Service Corporation
 AnRiverside Plaza
 Columbus, Ohio 43216

SUBJECT: D.D. ~~Nook~~ Nuclear Plant, Units 1 and 2

The following documents concerning our review of the subject facility are transmitted for your information.

- ☐ Notice of Receipt of Application, dated _____.
- ☐ Draft/Final Environmental Statement, dated _____.
- ☐ Notice of Availability of Draft/Final Environmental Statement, dated _____.
- ☐ Safety Evaluation Report, or Supplement No. _____ dated _____.
- ☐ Environmental Assessment and Finding of No Significant Impact, dated _____.
- ☐ Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License, dated _____.
- ☒ Bi-Weekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations, dated 3/25/87 [see page(s)] 9671.
- ☐ Exemption, dated _____.
- ☐ Construction Permit No. CPPR-_____, Amendment No. _____ dated _____.
- ☐ Facility Operating License No. _____, Amendment No. _____ dated _____.
- ☐ Order Extending Construction Completion Date, dated _____.
- ☐ Monthly Operating Report for _____ transmitted by letter dated _____.
- ☐ Annual/Semi-Annual Report- _____
 _____ transmitted by letter dated _____.

Office of Nuclear Reactor Regulation

Enclosures:
 As stated

cc: See next page

OFFICE	FWR#4/DWR-A	FWR#4/DWR-A					
SURNAME	MDuncan/rad	DWigginton					
DATE	03/30/87	03/ /87					

