

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707170229 DOC. DATE: 87/07/09 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 SMITH, W. G. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DAVIS, A. B. Document Control Branch (Document Control Desk)

SUBJECT: RO: on 870709, fire suppression water sys declared inoperable
 due to planned isolation required to facilitate installation
 of fire protection supply piping. Installation expected to be
 completed within 30 days & sys returned to svc by 870808.

DISTRIBUTION CODE: A006D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Fire Protection

NOTES:

	RECIPIENT ID CODE/NAME	COPIES			RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL			LTTR	ENCL
	PD3-3 LA	1	0		PD3-3 PD	5	0
	WIGGINGTON, D	1	1				
INTERNAL:	ARM/DAF/LFMB	1	0		NRR WERMEIL, J	1	0
	NRR WHITNEY, L	1	1		NRR/DEST/ADS	1	1
	NRR/DEST/PSB	1	1		OGC/HDS1	1	0
	<u>REG FILE</u> 01	1	1		RES/DE/EIB	1	
EXTERNAL:	LPDR	1	1		NRC PDR	1	
	NSIC	1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 0



INDIANA & MICHIGAN ELECTRIC COMPANY

Donald C. Cook Nuclear Plant
P.O. Box 458, Bridgman, Michigan 49106

July 9, 1987

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: A. B. Davis

Dear Mr. Davis:

This is to confirm a verbal report made to Mr. Bruce Burgess of your staff 0921 hours on July 9, 1987. At that time Mr. Burgess was informed that the Fire Suppression Water System was not operable as required by Technical Specification 3.7.9.1.b due to the planned isolation of a portion of the east and south legs of the outside fire protection ring header. This isolation was required to facilitate installation of fire protection supply piping to the new contractors access control building that is being constructed for the Steam Generator Replacement Project. The installation of the Fire Protection piping is expected to be completed within thirty days and the Fire Protection System returned to service by August 8, 1987.

No safety related Fire Protection Systems were removed from service due to the isolation of this section of Fire Protection piping. Backup fire protection is available from nearby fire hydrants and the plant fire truck.

This letter will fulfill the requirements of Technical Specification 3.7.9.1 action b.2b which requires a follow up report within twenty-four hours of the telephone call to Region III and Technical Specification 3.7.9.1 action b.2c that requires a follow up report within fourteen days.

Respectfully,

W. G. Smith, Jr.
W. G. Smith, Jr.
Plant Manager

/krb

cc: See attached distribution list.

8707170229 870709
PDR ADOCK 05000315
S PDR

A006
1/0

cc: A. B. Davis, Region III
D. L. Wigginton, NRC
J. E. Dolan
M. P. Alexich
R. F. Kroeger
H. B. Brugger
R. W. Jurgensen
NRC Resident Inspector
R. C. Callen, MPSC
G. Charnoff, Esq.
D. Hahn, MDPH
INPO
PNSRC
Dottie Sherman, ANI Library
J. G. Feinstein/B. P. Lauzau
A. A. Blind
File