

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8712210235 DOC. DATE: 87/12/11 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 SMITH, W. G. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)
 DAVIS, A. B. Region 3, Ofc of the Director

SUBJECT: Confirms 871211 verbal rept informing that fire protection
 water sys not operable as required by Tech Spec 3.7.9.1.b.
 Ltr fulfills requirements of Tech Spec 3.7.9.1 Action b.2.b
 & Action b.2c.

DISTRIBUTION CODE: A006D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Fire Protection

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	5 5
	WIGGINGTON, D	1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR WERMEIL, J	1 0
	NRR/DEST/ADS	1	NRR/DEST/PSB	1
	OGC/HDS1	1 0	<u>REG FILE</u> 01	1
EXTERNAL:	LPDR	1	NRC PDR	1 1
	NSIC	1		

Indiana Michigan
Power Company
Cook Nuclear Plant
P.O. Box 458
Bridgman, MI 49106
616 465 5901



December 11, 1987

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555


Attn: A. B. Davis

Dear Mr. Davis:

This is to confirm a verbal report made to Mr. Ray Smith of your staff at 1505 hours on December 11, 1987. At that time Mr. Smith was informed that the Fire Protection Water System was not operable as required by Technical Specification 3.7.9.1.b due to the planned isolation of a portion of the east leg of the outside fire protection ring header. The affected portion of the outside ring header was isolated at 0836 hours on December 11, 1987, to facilitate repositioning a fire protection isolation valve for the new Contractor's Access Control Building which is being constructed for the Steam Generator Replacement Project. The repositioning of the isolation valve was completed and the Fire Protection System was returned to service at 1620 hours on December 11, 1987.

The Deluge System for the Preferred Reserve Source Power Transformer (TR-201-AB) was removed from service due to the isolation of this section of fire protection piping. Two fire hydrants within the protected area were also removed from service. Backup fire protection is available from nearby fire hydrants and the Plant Fire Truck.

This letter will fulfill the requirements of Technical Specification 3.7.9.1 Action b.2b which requires a follow-up report no later than the first working day following the




A006
1/0

A.B. Davis, Region III
December 11, 1987
Page 2 of 2

event and Technical Specification 3.7.9.1 Action b.2c which requires a follow-up report within fourteen days.

Respectfully,


W.G. Smith, Jr.
Plant Manager

/bab

cc: J.E. Dolan
A.B. Davis, RO:III
M.P. Alexich
R.F. Kroeger
H.B. Brugger
R.W. Jurgensen
NRC Resident Inspector
D.L. Wigginton, NRC
R.C. Callen
G. Charnoff, Esq.
D. Hahn
INPO
PNSRC
A.A. Blind
Dottie Sherman, ANI Library
P.A. Barrett, B.P. Lauzau