

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8712230059 DOC. DATE: 87/12/16 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Document Control Branch (Document Control Desk)

SUBJECT: Inservice test - withdrawal of request for code relief of
 containment spray HX.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1	PD3-3 PD	5
	WIGGINGTON, D	1		
INTERNAL:	AEOD/DOA	1	AEOD/DSP/TPAB	1
	ARM/DAF/LFMB	1	NRR/DEST/MEB	1
	NRR/DEST/MTB	1	NRR/PMAS/ILRB	1
	OGC/HDS1	1	REG FILE 01	1
	RES/DE/EIB	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 0



AEP:NRC:0969K

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
INSERVICE TEST (IST) - WITHDRAWAL OF REQUEST FOR
CODE RELIEF OF CONTAINMENT SPRAY HEAT EXCHANGER

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

December 16, 1987

Dear Dr. Murley:

The purpose of this letter is to withdraw our request for temporary code relief for the Donald C. Cook Nuclear Plant Units 1 and 2 containment spray heat exchangers.

In our letter, AEP:NRC:0969J, dated October 29, 1987, we requested this temporary code relief to be granted until we could pressure test the heat exchangers in accordance with the ASME Boiler and Pressure Vessel Code Section XI, 1983 Edition, Subsection IWD, Article IWD-5000. At that time we were planning to test the heat exchangers during the next scheduled outages, which are April 1988 for Unit 1 and May 1988 for Unit 2

In November 1987 the heat exchangers were pressure tested at the 1983 Code required value of 165 psig, which is 110% of the lowest safety valve setting (150 psig). Therefore, the request for temporary code relief for the Cook Nuclear Plant Units 1 and 2 containment spray heat exchangers is being withdrawn.

8712230059 871216
PDR ADOCK 05000315
P DCD

A047
110

103

103

103

103

103

103

103

103

103

103


Dr. T. E. Murley

-2-

AEP:NRC:0969K

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,


M. P. Alexich
Vice President

cm

cc: John E. Dolan
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Bruchmann
G. Charnoff
NRC Resident Inspector - Bridgman
A. B. Davis - Region III