

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8803080332 DOC.DATE: 88/03/02 NOTARIZED: NO DOCKET #  
 FACIL:50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316

AUTH.NAME AUTHOR AFFILIATION  
 ALEXICH,M.P. Indiana Michigan Power Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 MURLEY,T.E. Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-74, recovering part of  
 bases to Tech Specs inadvertently omitted.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2+2  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL	
	PD3-3 LA		1	0	PD3-3 PD		5	5	
	WIGGINGTON,D		1	1					/
INTERNAL:	ARM/DAF/LFMB		1	0	NRR/DEST/ADS7E4		1	1	A
	NRR/DEST/CEB8H7		1	1	NRR/DEST/MTB 9H		1	1	
	NRR/DEST/RSB 8E		1	1	NRR/DOEA/TSB11F		1	1	D
	NRR/PMAS/ILRB12		1	1	OGC 15-B-18		1	0	
	REG FILE 01		1	1	RES/DE/EIB		1	1	D
EXTERNAL:	LPDR		1	1	NRC PDR		1	1	S
	NSIC		1	1					

A

1/1

880315

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 17

R  
I  
D  
S  
/  
A  
D  
D  
S



AEP:NRC:0931D

Donald C. Cook Nuclear Plant Unit 2  
Docket No. 50-316  
License No. DPR-74  
SUPPLEMENTAL REQUEST FOR AEP:NRC:0931B

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Attn: T. E. Murley

March 2, 1988

Dear Dr. Murley:

This letter constitutes a request to recover part of the Bases to the Technical Specifications (T/Ss) for the Donald C. Cook Nuclear Plant Unit 2 which was inadvertently deleted. In our letter AEP:NRC:0931, dated August 19, 1986, we submitted a T/S change request which included Bases page B 3/4 7-6 for Unit 2. During preparation of that submittal, the portion of the second paragraph of Section 3/4.7.9 appearing at the bottom of page B 3/4 7-6 was inadvertently deleted. The deleted portion addressed the situation in which a low pressure CO<sub>2</sub> system is isolated for personnel protection to permit entry<sup>2</sup> for routine tours, maintenance, construction, or surveillance testing. The first part of the deleted paragraph repeats the requirements specified under Action a of T/S 3.7.9.3; and the second part outlines qualifications for a person serving on a roving fire watch patrol. The Cook Nuclear Plant has a plant procedure which ensures that appropriate qualifications are maintained by personnel serving on a roving fire watch patrol by requiring that these personnel receive periodic fire watch training. Since no procedural changes were made as a result of the deleted paragraph, the deletion has not impacted our compliance with the T/S Bases.

Documents impacted by this deleted portion include the SER for Amendment 91 to the Unit 2 T/Ss (dated April 7, 1987) and AEP:NRC:0931B (dated July 27, 1987) which is still pending with the NRC.

To resolve this issue we are requesting that approval be granted to replace the current Bases page (B 3/4 7-6) for Unit 2 with the revised Bases page included in the attachment to this letter. The revised page includes the changes submitted in AEP:NRC:0931B.

8803080332 880302  
PDR ADCK 05000316  
P DCD

A001  
11



Dr. T. E. Murley

-2-


AEP:NRC:0931D

We believe that this request will not result in (1) a significant change in the types of effluents or a significant increase in the amounts of any effluent that may be released offsite, or (2) a significant increase in individual or cumulative occupational radiation exposure.

An application fee was paid for the proposed amendment submitted in AEP:NRC:0931B; therefore, we have not included an application fee for this letter.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



M. P. Alexich  
Vice President

cm

Attachments

cc: D. H. Williams, Jr.  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Bruchmann  
G. Charnoff  
NRC Resident Inspector - Bridgman  
A. B. Davis - Region III