

ATTACHMENT 2 TO AEP:NRC:1078

PROPOSED REVISED TECHNICAL SPECIFICATION PAGES

8904040230 890329  
PDR ADOCK 05000315  
P PDC



TABLE 3.3-2

## REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME</u>
1. Manual Reactor Trip	NOT APPLICABLE
2. Power Range, Neutron Flux (High and Low Setpoint)	Less than or equal to 0.5 seconds*
3. Power Range, Neutron Flux, High Positive Rate	NOT APPLICABLE
4. Power Range, Neutron Flux, High Negative Rate	Less than or equal to 0.5 seconds*
5. Intermediate Range, Neutron Flux	NOT APPLICABLE
6. Source Range, Neutron Flux	NOT APPLICABLE
7. Overtemperature delta T	Less than or equal to 6.0 seconds*
8. Overpower delta T	NOT APPLICABLE
9. Pressurizer Pressure--Low	Less than or equal to 1.0 seconds
10. Pressurizer Pressure--High	Less than or equal to 1.0 seconds
11. Pressurizer Water Level--High	NOT APPLICABLE

---

\* Neutron detectors are exempt from response time testing. Response time of the neutron flux signal portion of the channel shall be measured from detector output or input of first electronic component in channel.