

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8906230063 DOC.DATE: 89/06/09 NOTARIZED: NO DOCKET #  
 FACIL:50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH.NAME AUTHOR AFFILIATION  
 SMITH,W.G. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP.NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Advises that failure of valve 1-CCM-458 to close not reportable per 10CFR50.73.LER 89-005-00 retracted.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

## NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD3-1 LA	1 1	PD3-1 PD	1 1
STANG,J	1 1		
INTERNAL: ACRS MICHELSON	1 1	ACRS MOELLER	2 2
ACRS WYLIE	1 1	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
DEDRO	1 1	IRM/DCTS/DAB	1 1
NRR/DEST/ADE 8H	1 1	NRR/DEST/ADS 7E	1 0
NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/PEB 10	1 1
NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	2 2
NUDOCS-ABSTRACT	1 1	<del>REG-ETTES</del> 02	1 1
RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
RGN3 FILE 01	1 1		
EXTERNAL: EG&G WILLIAMS,S	4 4	FORD BLDG HOY,A	1 1
L ST LOBBY WARD	1 1	LPDR	1 1
NRC PDR	1 1	NSIC MAYS,G	1 1
NSIC MURPHY,G.A	1 1		

## NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 43 ENCL 42

*AGP*



June 9, 1989

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Operating License DPR-74  
Docket No. 50-316

Document Control Manager:

Licensee Event Report No. 50-315/89-005-00 was submitted as an interim report concerning a Unit 1 component cooling water (CCW) containment isolation valve (1-CCM-458) failure. The valve failed to close during surveillance testing being performed during the current refueling outage. While completing the evaluation in preparation for submittal of the updated event report, the determination was made that the event is not reportable under 10 CFR 50.73 based on guidance provided in NUREG-1022, Supplement No. 1, Question 2.3, for the following reasons:

- 1) The gear failure is believed to have occurred at the time of discovery, while the valve was being cycled for testing and with the plant in Mode 6 (refueling). This valve is required to be operable in Modes 1, 2, 3 and 4 and functioned correctly during the previous surveillance test. This valve is tested during refueling outages and is never operated during reactor coolant pump (RCP) operation.
- 2) The purpose of the phase-B isolation of valve 1-CCM-458 is for flow conservation of Component Cooling Water (CCW) and not for containment isolation purposes. The entire CCW system, including RCP thermal barrier and motor oil coolers, is a Seismic Class I closed loop system.
- 3) Valve 1-CCM-458 is included in Technical Specification Table 3.6-1 because it receives a phase-B isolation signal, not because it's a containment isolation valve. The valve is not subject to Appendix J testing.
- 4) 1-CCM-458 is one of two isolation valves in the CCW supply line.

For these reasons, it is concluded that the failure of 1-CCM-458 to close is not reportable per 10 CFR 50.73. This event did not constitute an unreviewed safety question as defined in 10 CFR 50.59, nor did it create a substantial hazard to the health and safety of the public.


8906230063 890609  
PDR ADDCK 05000316  
S PNU

FE22  
1/1

United States Nuclear Regulatory Commission  
June 9, 1989  
Page Two

LER 50-315/89-05 is herewith being retracted, the LER number will not be reissued. Please update your records accordingly.

Sincerely,

A handwritten signature in dark ink, appearing to read "W. G. Smith, Jr.", written in a cursive style.

W. G. Smith, Jr.  
Plant Manager

/jn

cc: D. H. Williams, Jr.  
A. B. Davis, Region III  
M. P. Alexich  
P. A. Barrett  
J. E. Borggren  
R. F. Kroeger  
NRC Resident Inspector  
J. F. Stang, NRC  
R. C. Callen  
G. Charnoff, Esq.  
Dottie Sherman, ANI Library  
D. Hahn  
INPO  
PNSRC  
A. A. Blind  
S. J. Brewer/B. P. Lauzau