

DOCKET NO: 50-315  
UNIT NAME: D. C. Cook Unit 1  
COMPLETED BY: T. R. Stephens  
TELEPHONE: (616) 465-5901  
DATE: August 4, 1989  
PAGE: 1 of 1

MAJOR SAFETY-RELATED MAINTENANCE

JUNE, 1989

- 1-IC-1 Replaced pressure transmitter IPA-120 for accumulator tank #2.
- 1-IC-2 Replaced Relay 42-6 DGCD for CD diesel generator starting air valve.

8908150198 890804  
PDR ADOCK 05000315  
R PDC